

Research GAHP Screening Criteria and Design

Project Number ET23SWG0012

GAS EMERGING TECHOLOGIES (GET) PROGRAM November 2024



Prepared by ICF for submission to Southern California Gas Company

Contents

Acknowledgements	vii
Disclaimer	vii
Abbreviations and Acronyms	viii
Executive Summary	9
Introduction	
Background	11
Assessment Objectives	
DHW Sizing Methods	14
Common DHW Sizing Methods	14
Preliminary Research for Water Heater Sizing Methods	14
Analysis of Methods	
ASHRAE and ASPE	
Sizing Method Findings	
Subject Matter Expert Interviews	
Survey Participants	
Survey Questionnaire	
SME Responses	
DHW System Sizing Issues and Causes for Replacement	
Key Parameters for DHW System Sizing	51
System Sizing Resources	
Key Parameters for DHW System Selection	62
Accounting for Demand Increase in DHW System Sizing	
Survey Response Variation	73
SME Findings	73
Compare Sizing Methods with Actual Site Data	74
Site Data	
Sizing Analysis	77
Comparisons of Sizing Tools to Site Data	81

Site Screening, Sizing, and Design Criteria for GAHPs	
GAHP Background	103
Screening, Sizing, and Design Criteria for GAHPs Findings	
Conclusions	123
References	127
Appendices	129
Appendix 1: Raw SME Responses:	129
Appendix 2: Site Specific Sizing Tool Screenshots	

List of Tables

Table 1: Example Heat Rate and Storage Tank Volumes for a 100-person, Middle-Income Multifamily Building with an 80% Efficient Water Heater	20
Table 2: Inputs Needed for Different Sizing Methods	
Table 3: Outputs from Different Sizing Methods	
Table 4: Average Daily Hot Water use per Household REUW [10]	
Table 5: Hot water demand as a function of consumption profile and peak minutes (gallor per person per day)	
Table 6: Key Assumption used in manufacturing tools to size water heater	37
Table 7: SME Survey Question 3	44
Table 8: SME Survey Question 4	45
Table 9: SME Survey Question 5	46
Table 10: SME Survey Question 6	47
Table 11: SME #12 Question 3 Responses	49
Table 12: Key Components for DHW System Sizing SME Responses Summary	52
Table 13: Key Components for DHW System Sizing SME Responses Part 1	53
Table 14: Key Components for Water Heater Sizing SME Responses Part 2	55
Table 15: Water Heater Sizing Resources SME Responses	59
Table 16: Key Components for DHW System Selection SME Responses Summary	63
Table 17: Features in Selecting Water Heaters SME Responses Part 1	64
Table 18: Features in Selecting Water Heaters SME Responses Part 2	66
Table 19 : Ways to Account for Demand Increase in Water Heater Sizing SME Responses	70
Table 20: Site Data	75
Table 21: Site Occupant Demographics	77
Table 22: Site-Specific Gas bill end-uses	81
Table 23: Site 1 DHW Comparison (Per Apartment Unit)	84
Table 24: Site 2 DHW Comparison (Per Apartment Unit)	87
Table 25: Site 3 DHW Comparison (Per Apartment Unit)	90
Table 26: Site 4 DHW Comparison (Per Apartment Unit)	93
Table 27: Site 5 DHW Comparison (Per Apartment Unit)	96

Table 28: Site 6 DHW Comparison (Per Apartment Unit)	99
Table 30: Percent Difference: 100 th percentile vs Sizing Tools	100

List of Figures

Figure 1: ASPE Hot Water Demands Based on Demographic LMH (Low, Medium, High) Factor [5]
Figure 2: ASPE Hot Water Demands (gallons) Based on Figure 1 [5]16
Figure 3: ASHRAE Hot Water Demands (gallons) [6]17
Figure 4: ASHRAE Hot Water Demand based on Demographics and Values from Figure 3 [6] 17
Figure 5: Example Heat Rate and Storage Tank Volumes for a 100-Person, Middle-Income Multifamily Building with an 80% Efficient Water Heater20
Figure 6: MFG Tool 1 Inputs 1
Figure 7: MFG Tool 1 Inputs 2
Figure 8: MFG Tool 1 Outputs
Figure 9: MFG Sizing Tool 2 Inputs 1
Figure 10: MFG Sizing Tool 2 Inputs 227
Figure 11: MFG Sizing Tool 2 Outputs
Figure 12: MFG Tool 3 Inputs
Figure 13: MFG Tool 3 Outputs
Figure 14: Water Heater Capacity and Storage Tank Sizing Method
Figure 15: Updated ASHRAE Hot Water Demand Profile
Figure 16: ASHRAE/ASPE Calculated Heat Rate Based at Different Consumption Profiles 38
Figure 17: ASHRAE vs MFG Tool 1 Recommended Water Heater Sizes as a function of Units in a Multifamily Building
Figure 18: ASHRAE vs MFG Tool 2 Recommended Water Heater Sizes as a function of Units in a Multifamily Building40
Figure 19: ASHRAE vs MFG Tool 3 Recommended Water Heater Sizes as a function of Units in a Multifamily Building41
Figure 20: Key Components for DHW System Sizing SME Responses Summary

Figure 21: Water Heater Sizing Resources SME Responses Summary	61
Figure 22: Key Components for DHW System Selection SME Responses Summary	68
Figure 23: Ways to Account for Demand Increase in Water Heater Sizing SME Responses Summary	
Figure 24: DEER water heater calculator v5.1 inputs part 1	78
Figure 25: DEER water heater calculator v5.1 inputs part 2	78
Figure 26: DEER Water Heater Calculator Summer to Winter Scaling Factor	79
Figure 27: Summer to Winter DHW load projection vs actual comparison	80
Figure 28: Site 1 Comparison (Per Apartment Unit)	83
Figure 29: Site 2 DHW Comparison (Per Apartment Unit)	86
Figure 30: Site 3 DHW Comparison (Per Apartment Unit)	89
Figure 31: Site 4 DHW Comparison (Per Apartment Unit)	92
Figure 32: Site 5 DHW Comparison (Per Apartment Unit)	95
Figure 33: Site 6 DHW Comparison (Per Apartment Unit)	98
Figure 36: Preheat configuration of GAHP and boiler system: GAHP 1	105
Figure 37: Preheat configuration of GAHP and boiler system: GAHP 2	106
Figure 36: Comparison of GAHP Capacity and Site #1 Summer DHW Loads	107
Figure 37: Comparison of GAHP Capacity and Site #5 Summer DHW Loads	108
Figure 38: Commercial Indirect Storage Tank with Heat Exchanger [14]	112
Figure 39 Stratified Solar Thermal Storage Tank [15]	113
Figure 40: Preheat GAHP 2 and stratified IST with Heat Exchanger	114
Figure 41: Preheat GAHP 2 and stratified IST with Recirculation Line	115
Figure 42: Preheat GAHP 1 and Stratified IST with Heat Exchanger	116
Figure 43: GAHP 2 and Indirect Storage Tank diagram	117
Figure 44: GAHP 1 (max delivery temp of 120 F) Indirect Storage Tank volume vs Incomin temperature for a 45-minute GAHP run time	-
Figure 45: GAHP 2 (max delivery temp of 130F) Indirect Storage Tank volume vs Incomin temperature for a 45-minute GAHP run time	-
Figure 46: GAHP 2 (max delivery temp of 140F) Indirect Storage Tank volume vs Incomin temperature for a 45-minute GAHP run time	•

List of Equations

Equation 1: Total Daily Hot Water Gallons Required Based on Consumption Profile, Peak Period, and Number of People	17
Equation 2: Volumetric Hot Water Flowrate of Water Based on Consumption Profile and Peak Period	18
Equation 3: Heat Rate Formula:	18
Equation 4: Storage Tank Volume Formula:	18
Equation 5: DHW Summer to Winter Scale Factor	79
Equation 6: Minimum Flow Rate	.109
Equation 7: Tank Volume	110
Equation 8: Tank Charge Time	110
Equation 9: Minimum Flow Rate	111
Equation 10: Min Flowrate for 12 cycles per day	111
Equation 11: Buffer Tank Volume	.120

Acknowledgements

ICF and Lincus Inc. are responsible for this project. This project, ET23SWG0012, was developed as part of the statewide Gas Emerging Technologies (GET) Program under the auspices of SoCalGas as the Statewide Lead Program Administrator. Cristalle Mauleon, Ramanujan Vetrivel, and Alyza Khan conducted this technology evaluation with overall guidance and management from Steven Long. For more information on this project, contact <u>steven.long@icf.com</u>.

Disclaimer

This report was prepared by ICF and funded by California utility customers under the auspices of the California Public Utilities Commission. Reproduction or distribution of the whole or any part of the contents of this document without the express written permission of ICF is prohibited. This work was performed with reasonable care and in accordance with professional standards. However, neither ICF nor any entity performing the work pursuant to ICFs authority make any warranty or representation, expressed or implied, with regard to this report, the merchantability or fitness for a particular purpose of the results of the work, or any analyses, or conclusions contained in this report. The results reflected in the work are generally representative of operating conditions; however, the results in any other situation may vary depending upon particular operating conditions.

Abbreviations and Acronyms

Abbreviation	Meaning
ACEEE	American Council for an Energy-Efficient Economy
ASHRAE	American Society of Heating, Refrigeration and Air-Conditioning Engineers
ASPE	American Society of Plumbing Engineers
CPC	California Plumbing Code
COP	Coefficient of Performance
CV	Coefficient of Variation
С	Contractors
DWHC	DEER Water Heater Calculator
DOE	Department of Energy
DHW	Domestic Hot Water
EHPWH	Electric Heat Pump Water Heater
EE	Energy Efficiency
GAHP	Gas Absorption Heat Pump
GET	Gas Emerging Technology
GHPWH	Gas Heat Pump Water Heater
GPM	Gallons Per Minute
HPWH	Heat Pump Water Heater
HVAC	Heating, Ventilation, and Air Conditioning
IST	Indirect Storage Tank
IAPMO	International Association of Plumbing and Mechanical Officials
ICC	International Code Council
IECC	International Energy Conservation Code
IPC	International Plumbing Code
MFG	Manufacturer
M&V	Measurement and Verification
REUW	Residential End Uses of Water
SME	Subject Matter Experts
TE	Technical Experts
UPC	Uniform Plumbing Code

Executive Summary

Evidence suggests that domestic hot water (DHW) systems in multifamily buildings are frequently oversized, despite revised sizing standards from organizations like the American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE). At the outset of this study, it was unknown how sites can be screened for gas absorption heat pump (GAHP) implementation and what, if any, existing DHW sizing tools could be used to screen or design GAHP systems. This hinders market adoption because customers and installers do not know what criteria makes an ideal GAHP site. This Gas Emerging Technology (GET) Project focused on addressing these challenges by examining available DHW sizing methods, interviewing DHW subject matter experts (SMEs), comparing DHW sizing methods with actual site data, and providing basic site screening criteria and design considerations for GAHPs. The study identified several areas where more research is needed for site screening of GAHP systems.

Project Goal: The goal of this study was to research and develop/update site screening criteria and sizing methods for GAHP in DHW systems after analyzing currently available sizing tools and expert insights. This includes addressing the challenges of oversizing in current DHW systems and providing contractors with the tools needed for GAHP system design and installation.

Key Project Findings:

- The DHW sizing tools examined in this study sized DHW systems anywhere from 57% undersized to 252% oversized compared to the actual maximum DHW demand, using site data. In other words, they were very inconsistent.
- ASHRAE is the closest to the actual maximum DHW demand (without undersizing the system) at three out of six sites, which is more consistent than the other tools.
- The number of occupants and heat rate are consistently identified by SMEs as the most important factors for accurate DHW sizing.
- Existing DHW sizing tools cannot be used to screen sites for GAHPs because they size for the peak DHW load, which happens in winter when many people are using hot water. Conversely, a GAHP screening tool needs to know what the minimum DHW load is, which happens during the summer when few people are using hot water. This is an entirely new way of thinking about DHW sizing and there is no tool that can do it, at this point.
- Designers and installers should calculate minimum required flow rates for the GAHP to run continuously. If the minimum flow rate is not met at a site, they should use an indirect storage tank (IST) and determine the minimum number of cycles per day.

- The minimum number of cycles per day and the IST size are affected by the following factors:
 - GAHP run time
 - Target GAHP COP
 - Cost of natural gas
 - Cost of the GAHP retrofit
 - Value of CO₂ emissions reductions (if any)
- GAHP units can be effectively integrated with traditional boilers, with GAHPs managing base hot water load and boilers addressing peak load.
- Operational adjustments for the site-specific factors such as available space, flow rate, and temperature requirements are critical for ensuring optimal performance in hybrid GAHP-boiler systems.

Project Recommendations: The Study Team offers the following recommendations based on the findings:

- Refine Summer Minimum Load Measurement: The best way to determine summer minimum DHW load is to measure it, but more research is needed to refine this method. Even if it is refined, installers may not want to measure it, so a tool should be created in the future.
- Generate GAHP COP as a Function of GAHP Run time: The Study Team and other GET Team members are gathering information that can generate this data.
- Develop a GAHP Site Screening Tool: More research is needed to screen sites for GAHP installation when the cost of natural gas, targeted GAHP COP, cost of the GAHP retrofit, and CO₂ emissions value are considered. Ultimately, a screening tool that takes these variables into account should be created to screen sites for GAHP implementation.

Introduction

This Gas Emerging Technology (GET) Project includes research into site screening criteria and sizing methods for gas absorption heat pump (GAHP) water heaters. GAHPs have been around for many years, but the application of this technology to domestic hot water (DHW) systems is novel and presents several challenges. Legacy DHW heaters are often sized for the maximum expected DHW load and can easily turn down output during lower demand. GAHPs, on the other hand, require a minimum DHW load to function optimally with a fixed baseline load and are recommended to be sized to 40–60% of the maximum DHW load. There is evidence that the DHW heater/boiler sizing methods currently in use overestimate DHW load, which becomes a problem when the GAHP requires a minimum load to function properly. Further complicating matters is the fact that many DHW retrofit projects in the multifamily segment are completed by contracting companies who do not have engineering staff to run DHW sizing calculations or come up with new designs for each retrofit project. Contractors generally rely on outside engineers or manufacturers to provide them with recommended DHW heater/boiler capacities and designs. Additionally, contractors need to have rough ideas of project costs up front to sell a project to a multifamily property. In order for the GAHP to be successful as an energy efficiency (EE) measure in the California multifamily market, the contractor community must be provided with appropriate tools to quickly screen sites for GAHP retrofits and determine the recommended size/quantity of GAHPs. This project seeks to bridge that gap by investigating current DHW sizing methods, researching what site information contractors can typically collect, and providing recommendations for site screening criteria and GAHP sizing and design.

Background

There is evidence that DHW systems in commercial and multifamily buildings are often oversized [1]. Consequently, the ASHRAE standards were updated in 1995 to introduce "Low/Medium/High" user classifications based on building demographics and different peak period hot water usage lengths. In addition, the Energy Policy Act has mandated flow rate limits for faucets and showerheads along with improvement in the water use efficiency of washing machines and dishwashers over the past three decades. These changes have resulted in a decrease in hot water consumption [2]. Although no recent studies have compared actual DHW loads to DHW sizing since the 1994 ACEEE study, the oversizing problem seems to persist. For example, the Department of Energy (DOE) proposed a rule for energy conservation standards for commercial water heating equipment for which there were comments that the manufacturing guidelines tend to oversize equipment. The DOE agreed that "manufacturing guidelines are likely to result in oversizing hot water equipment in many applications." An International Association of Plumbing and Mechanical Officials (IAPMO) Study for a Water Demand Calculator states that "the plumbing industry has long recognized that building potable water systems in today's buildings are oversized." This IAPMO study considered the size of both the pipes and the water heater [3]. Lastly, a study conducted in Poland that compared the forecasted and actual DHW demand in multifamily buildings, demonstrated oversizing of 7% to 45% depending on the sizing method used [4].

Oversizing a DHW boiler raises concerns for various reasons. It is particularly worrisome for new/emerging gas water heating technologies given that an oversized GAHP will not function as intended thereby reducing or eliminating the GAHP's energy savings potential. GAHPs use an absorption cycle that extracts heat from the air and transfers it to hot water resulting in greater than 1.0 coefficient of performance (COP) during the majority of the outdoor conditions. Although these systems are more expensive than traditional DHW boilers on a per unit of heat output basis and still not yet well-known, they are promising emerging EE technology. However, unlike incumbent DHW boilers, these systems only come in a few heat output sizes, with only some units having turn down capabilities, and in most cases require a minimum heating load. If that minimum load is not met, the unit may experience excessive cycling, which puts wear and tear on the machine and reduces its designed COP. Furthermore, an oversized GAHP increases the initial system cost, thereby negatively impacting project economics and hindering market adoption. This issue is similar to the challenges encountered with electric heat pump water heaters (EHPWHs), for which sizing and education tools have been developed. Like EHPWHs, GAHPs could also benefit from additional potable hot water storage to reduce cycling and lower the unit size. However, unlike EHPWHs, this approach has not yet been studied for GAHPs, as it remains a novel concept for these systems.

Additionally, the deemed savings measure package (SWWHO33) on California's electronic Technical Resource Manual (eTRM) for GAHPs targets multifamily building types, and two other GET projects seeking to expand the available field data to hotel/motel building types (ET23SWG0002 and ET24SWG0006). The contractors who work in these markets typically do not have in-house technical staff who can assist with site screening and DHW design. Contractors bridge this gap in the following ways:

- Perform like-for-like DHW heater/boiler replacements eliminating the need for new DHW sizing or design.
- Provide DHW boiler/heater manufacturers with site data and receive recommended DHW size from the manufacturer.
- For more complex DHW systems (e.g., solar thermal water heaters or EHPWHs), outside tools are used to determine DHW size and outside engineering services are procured for design. The design used is a boiler plate design that can be adjusted based on site conditions to save on design costs.

As contractors gain experience with DHW systems, their ability to screen, size, and design improves, and they develop an intuitive understanding of what constitutes a good site and the expected cost magnitude. However, since the GAHP systems are a novel application for DHW end-use, contractors do not currently have this intrinsic knowledge and there are currently no resources to support them or their contracted engineers. This lack of resources will likely limit adoption of GAHPs, so this project seeks to overcome gaps and provide the necessary resources.

Assessment Objectives

The goal of this study as listed below is to investigate existing methods of DHW system sizing; research what site information is typically available to installation contractors; and provide recommendations for site screening criteria and GAHP sizing and design.

- 1) Investigate the most-commonly used DHW sizing and design methods in multifamily and hotel buildings in California.
- 2) Evaluate if these methods can reliably calculate site specific minimum DHW loads from available data.
- 3) Analyze if these methods are applicable for sizing and designing GAHP DHW systems and provide recommendations if they are not suitable in their current form.
- 4) Provide recommendations for site screening, GAHP sizing calculation, and system design tailored for a contractor audience.

The expected project outcomes are listed below.

- 1) Identification of the most frequently used DHW system sizing methods in multifamily and hotel/motel buildings in California.
- 2) Comparison of the expected DHW loads using the most common sizing methods to actual natural gas billing data and actual DHW loads and identify gaps between sizing methods and actual site data.
- 3) Recommendations for site/operation data points needed to screen sites for GAHPs, size GAHPs, and design new GAHP systems.

DHW Sizing Methods

Common DHW Sizing Methods

The three most commonly used sources for DHW sizing tools are as follows:

- ASPE (American Society of Plumbing Engineers)
- ASHRAE Handbook HVAC Applications
- Manufacturer (MFG) sizing tools: (referred as MFG Tool 1, MFG Tool 2, and MFG Tool 3)

The Study Team also reviewed the following resources but did not use any of them as sizing methods, as they lacked relevant information for sizing DHW systems:

- California Plumbing Code (CPC) (Chapter 5 of Title 24) the basis of which is the IAPMO Uniform Plumbing Code (UPC)
- International Plumbing Code (IPC)
- International Energy Conservation Code (IECC)

This research included a comprehensive literature review and several meetings with a leading industry SME with expertise in hot water heating, who helped guide the study and reviewed its findings.

Preliminary Research for Water Heater Sizing Methods

This section summarizes the findings from the reviewed water heater handbooks, codes, and standards related to water heater sizing methods. The following sections will analyze the selected DHW sizing tool sources and explain why some sources were excluded from this study.

ASPE and ASHRAE [5], [6]

Both ASPE and ASHRAE have DHW sizing guidelines for different types of commercial buildings including schools, dormitories, nursing homes, motels, office buildings, and multifamily buildings. Both include different types of water heaters, source fuels, and sizes. Fuels include oil, gas, and electric and equipment types are tankless or instantaneous and storage. ASPE's sizing guidelines for multifamily buildings are in the "Plumbing Engineering and Design Handbook" in the section titled "Multifamily Buildings" [5]. ASHRAE's sizing guidelines are in "HVAC Applications Handbook" in Chapter 50.12 "Hot–Water Load and Equipment Sizing" [6]. Both methods use similar inputs, outputs, and calculation methodology. The basic inputs to <u>both</u> methods for a multifamily building are as follows:

- User demand profile: Total and average water demand depends upon the type of user. Both ASPE and ASHRAE split these consumption profiles into "Low," "Medium," and "High" categories based upon the occupant demographics.
- Peak period: The maximum water heater capacity [Btu/h] depends on the peak hot water demand duration. Both methods use peak periods ranging from 5 minutes to 180 minutes.

Figure 1 and 2 below show the Low, Medium, and High consumption profile occupant demographics as well as the hot water demands for each of these consumption profiles based on different peak periods. The consumption occupant demographics and hot water demands are the same for both ASPE and ASHRAE. The ASHRAE information is shown in Figure 3 and 4 below.

Some design considerations that ASHRAE tool provides under various steps are summarized below [6]:

Step 1: Choose high-performance equipment or processes that use less hot water or eliminate the need for it.

Step 2: Optimize plumbing layout for efficient hot water delivery, considering distributed generation or point-of-use heating for distant sinks.

Step 3: Select high-efficiency water heaters compatible with the system and fixtures.

Step 4: Explore pre-heating technologies (e.g., heat recovery or solar) before finalizing system design.

Step 5: Ensure proper system installation and consider monitoring equipment for commissioning and maintenance.

Step 6: Use hot-water recirculation loops sparingly to maintain hot pipes but be aware of potential energy use increases. Alternatively, employ multiple separate water heating systems to reduce or eliminate the need for recirculation loops.

Based on discussions with SMEs, we found that while recirculation and tank losses are typically accounted for, they were not a critical factor in this analysis. Since the sizing focuses on the system's performance during peak hours when losses are minimal compared to the user demand, they were acknowledged but not explicitly incorporated into the system design considerations. Figure 1: ASPE Hot Water Demands Based on Demographic LMH (Low, Medium, High) Factor [5]

Demographic Characteristics	LMH Factor
No occupants work (stay at home) Public assistance and low income (mix) Family and single-parent households (mix) High percentage of children Low income	High
Families Public assistance Singles Single-parent households	Medium
Couples High population density Middle income Seniors One person works. 1 stays home All occupants work	Low

Source: Goldner 1994, Energy use and DHW consumption research project.

Figure 2: ASPE Hot Water Demands (gallons) Based on Figure 1[5]

	Peak 5 Min, gal (L)/person	Peak 15 Min, gai (L)/person	Peak 30 Min, gal (Lyperson	Maximum H, gal (L)/person
Low	0.4 (1.5)	1.0 (4.0)	1.7 (6.5)	2.8 (10.5)
Medium	0.7 (2.6)	1.7 (6.4)	2.9 (11.0)	4.8 (18.0)
High	1.2 (4.5)	3.0 (11.5)	5.1(19.5)	8.5 (32.5)
	Maximum 2 H, gal (L)/person	Maximum 3 H, gal (L)/person	Maximum Day, gal (L)/person	Average Day, gal (L)/person
Low	4.5 (17.0)	6.1 (23.0)	20.0 (76.0)	14.0 (54.0)
Medium	8.0 (31.0)	11.0 (41.0)	49.0 (185.0)	30.0 (113.6)
High	14.5 (55.0)	19.0 (72.0)	90.0 (340.0)	54.0 (205.0)

Source: Goldner and Price 1994.


Note: These volumes are for DHW delivered to the tap at 120° F (49°C).

Figure 3: ASHRAE Hot Water Demands	(gallons)	[6]
------------------------------------	-----------	-----

	Peak Minutes					Maximum	Average	
Guideline	5	15	30	60	120	180	Daily	Daily
Low	0.4	1.0	1.7	2.8	4.5	6.1	20	14
Medium	0.7	1.7	2.9	4.8	8.0	11.0	49	30
High	1.2	3.0	5.1	8.5	14.5	19.0	90	54

(Gallons per Person at 120°F Delivered to Fixtures)

Figure 4: ASHRAE Hot Water Demand based on Demographics and Values from Figure 3 [6]



In the most basic form of this sizing method, the following equations are used.

Equation 1: Total Daily Hot Water Gallons Required Based on Consumption Profile, Peak Period, and Number of People

 $v_{pp} = v_{cp,pp} * ppl$ (In the most basic form of this sizing method, the following equations are used.

Equation 1)

Where:

 v_{pp} = total daily hot water gallons required based on consumption profile, peak period, and number of people.

 $v_{cp,pp}$ = the daily volume of hot water required *per person* based on consumption profile and peak period.

ppl = the total number of people in the building

Equation 2: Volumetric Hot Water Flowrate of Water Based on Consumption Profile and Peak Period

$$\dot{v}_{pp}\left[\frac{Gallons}{Minute}\right] = \frac{v_{pp}[Gallons]}{t_{pp}[Minute]}$$
 Equation 2)

Where:

 \dot{v}_{pp} = volumetric flowrate of hot water based on the consumption profile and peak period (gal/min)

 t_{pp} = the peak period time in minutes.

Equation 3: Heat Rate Formula:

$$\dot{Q} = (\dot{v}_{pp} * \rho * C_p * \Delta T * 60) / \eta$$
 Equation 3)

Where:

 \dot{Q} = Heat Rate (Btuh) ρ = density of water (lbm/gal) C_p = Specific heat of water (Btu / lbm- °F) ΔT =Temperature difference (°F) η = Water Heater/Boiler Efficiency

Equation 4: Storage Tank Volume Formula:

 $V = \frac{v_{pp}}{UC}$ Equation 4)

Where:

V= Storage Tank Volume UC= Usable Tank Capacity, on average 70% [6]

Example ASHRAE/ASPE Sizing Calculation

This is an example sizing calculation for 100 people in a middle-income apartment building. Assume that the incoming cold-water temperature is 40°F and the desired hot water temperature is 120°F. The efficiency of the water heater/boiler is planned to be 80%.

Based on Figure 1, the consumption profile is "Low."

Equation 1 gives the total daily volume of hot water based on the peak period, consumption profile and number of people. The total gallons per person at a 5-minute peak for a Low consumption profile user is 0.4 gallons/person-day. To get total daily hot water volume, use Equation 1

$$v_{pp} = 0.4 \left[\frac{Gallons}{person - day} \right] * 100 [People]$$
$$v_{pp} = 40 \left[\frac{gallons}{day} \right]$$

Using Equation 2, the volumetric flow rate is found at a peak period of 5 minutes.

$$\dot{v}_{pp} = \frac{40 \left[\frac{gallons}{day}\right]}{5 \left[Minutes\right]}$$
$$\dot{v}_{pp} = 8 \left[\frac{Gallons}{min}\right]$$

Using Equation 3, the heat rate (or water heater capacity is found)

$$\dot{Q} = \frac{\left(8\left[\frac{Gallons}{minute}\right] * 8.4\left[\frac{lbm}{gallon}\right] * 1\left[\frac{Btu}{lbm - {}^{\circ}\mathrm{F}}\right] * (120{}^{\circ}\mathrm{F} - 40{}^{\circ}\mathrm{F}) * 60\left[\frac{Minutes}{hr}\right]\right)}{80\%}$$
$$\dot{Q} = 6,720 \; Btu/hr$$

At a 5-minute peak period, the total required heating rate is 6,720 Btu/hour.

Equation 4 gives the total required storage tank volume at a 5-minute peak period.


$$V [gallons] = \frac{40 [gallons]}{70\%}$$
$$V = 57 Gallons$$

This same calculation is done at 15-minute, 30-minute, 60-minute, 120-minute, and 180minute time intervals. This gives a range of heat rates and storage tank capacities to satisfy the water heating load. Table 1 shows the outputs of Equations 1 - 4 at the other peak periods.

Table 1: Example Heat Rate and Storage Tank Volumes for a 100-person, Middle-Income Multifamily Building with an 80% Efficient Water Heater

Peak Min	5	15	30	60	120	180
Gal/Person/Day	0.4	1	1.7	2.8	4.5	6.1
Gal/Day	40	100	170	280	450	610
Gal/Min	8	7	6	5	4	3
Heat Rate [Btu/hr]	6,720	5,600	4,760	3,920	3,150	2,847
Storage Tank Vol [Gallons]	57	143	243	400	643	871

Figure 5: Example Heat Rate and Storage Tank Volumes for a 100-Person, Middle-Income Multifamily Building with an 80% Efficient Water Heater



ASHRAE and ASPE Differences

While ASHRAE and ASPE tools are quite similar, they utilize slightly different design considerations. This section discusses the *differences* between the two methods.

- The ASPE method does not consider the incoming water temperature, and instead assumes a set temperature rise in the boiler. Whereas ASHRAE requires users to input the design incoming water temperature and specify the desired hot water temperature which can range from 120°F to 140°F.
- The ASPE method takes the following additional nuances into consideration which are not part of the ASHRAE tool:
 - <u>Who pays for water:</u> When individuals pay for their hot water usage, it tends to reduce usage by 20–30%.
 - Peak demand may vary over different seasons and times of the day: Excess storage capacity required may vary depending upon the time of the day. Different peak times may show varying demand splits, so carefully analyze this data. It's advisable to use numbers from the winter season as it represents the true maximum demand for hot water.
 - <u>Laundry needs</u>: ASPE considers whether the DHW system will be providing hot water for clothes washers and adjusts for this additional water need.
 - <u>Kitchen needs</u>: ASPE considers how many fixtures are in the kitchen and whether there is a dishwasher and adjusts for the dishwasher water need.
 - <u>Laws about flow restrictions</u>: ASPE reminds the designer to pay attention to local and state regulations regarding fixture flow restrictions to refine volumetric flow rates.
- The method outlined in Equations 1–4 is the "Simplified" method in ASHRAE. It assumes that there is no existing hot water in the storage tank to satisfy the water heating needs. ASHRAE also has a "More Accurate Method" that accounts for the existing stored hot water available to satisfy the demand. This method uses the local slopes of the hot water use curve to calculate a more accurate heating rate.

IAPMO

IAPMO is an organization dedicated to ensuring the safety and efficiency of plumbing and mechanical systems. IAPMO's "2021 Uniform Plumbing Code" serves as a comprehensive reference detailing various aspects of plumbing design, installation, and maintenance, offering guidance on codes, standards, and best practices in the plumbing industry [7]. Guidelines on water system requirements are listed in Chapter 5, Appendix A and Appendix M in the 2021 Uniform Plumbing Code.

UPC Chapter 5: Water Heater Requirements

In this chapter, IAPMO outlines specific requirements for water heater installation, including heater location and safety requirements. While the provided information is valuable for water heater installation, it is not relevant to the sizing of water heater capacity and tank volume.

UPC Appendix A: Recommended Rules for Sizing the Water Supply System

Appendix A of the 2021 Uniform Plumbing Code provides a comprehensive set of rules for sizing the water supply system. It begins with preliminary information, such as minimum daily service pressure, water meter specifications, and pipe types. The document then delves into the concept of demand load, emphasizing the importance of understanding the supply needed in gallons per minute based on the number of fixtures in the building. It introduces the notion of permissible friction loss, which aims to maintain desirable minimum residual pressure at the highest fixture in the supply system, accounting for factors like elevation above street level.

The sizing of the building supply is a critical aspect discussed in this appendix. It involves determining the diameter of the pipe based on total demand and permissible friction loss. Special attention is given to copper and alloy piping, noting their potential impact on hydraulic pressure and considerations for hard water supply. Additionally, the document covers the sizing of principal branches and risers, outlining the required sizes to meet the demand load while considering permissible friction loss. In cases where branches to the building supply are sized for the same friction loss as branches and risers to the highest level in the building, measures such as size adjustments, throttling using valves, or increasing the size of the building supply are suggested.

Appendix M: Peak Water Demand Calculator

Appendix M covers how to calculate peak water demand for multifamily dwellings while accounting for water conserving plumbing fixtures, fixture fittings, and appliances. It accounts for different fixtures, flowrate, pipe sizing and probability of use. This gives important information on how to calculate the peak demand but does not explicitly state how to apply this to calculate water heater capacity or storage tank volume.

IAPMO Summary

IAPMO's 2021 Uniform Plumbing Code offers a comprehensive overview of regulations and requirements for water heater systems, but it lacks information on water heater capacity and storage tank sizing. IAPMO does provide hot water GPM output data but does not provide a method to use it to size the water heater capacity and/or storage tank. Therefore, IAPMO tool was not considered for further analysis in this study.

ICC: 2021 International Energy Conservation Code (IECC):

Section C4O4 Service Water Heating

The International Code Council (ICC) is an organization that develops building codes and standards for the construction industry. The 2021 International Energy Conservation Code (IECC) is one of the codes established by the ICC and focuses on energy efficiency in

building design and construction [8]. Section C4O4 of the IECC covers the following regarding service water heaters:

- Type of equipment: Instantaneous or Storage water heaters.
- Fuel Types: Oil, gas electric, or combination.
- Based on the type of equipment, there are options for input, rating condition storage tank, performance required and test procedure.
- Charts that provide information dependent on pipe sizes, volume, and material

The IECC offers valuable insights into sizing water heaters based on different equipment types and fuel options. However, it lacks methodology for translating this information into specific water heater capacity and storage tank volume for various occupational demands. Consequently, the section in the IECC that addresses water heater sizing was not included as one of the sizing methods considered in this study.

ICC: 2021 International Plumbing Code (IPC)

Chapter 5 Water Heaters

- The IPC stands for the International Plumbing Code. It is a set of plumbing codes and standards also developed by the ICC. The IPC provides regulations and guidelines for the design, installation, and inspection of plumbing systems in buildings, ensuring the safety and functionality of plumbing systems [9]. Chapter 5 of the IPC is on water heaters and includes the following: Regulations concerning the safety of water heating units and hot water storage tanks.
- Heated portable water needs and associated fixtures.
- Temperature and pressure controls for hot water storage tanks.
- Access requirements to water heaters and hot water storage tanks to allow for the maintenance and replacement of equipment.

Similar to the aforementioned IECC, the IPC has valuable insights concerning the regulation, use and maintenance of hot water heaters, but not any relevant information regarding system sizing. Therefore, the IPC was not included as one of the sizing methods in this study.

Manufacturers' Water Heater Sizing Tools

Three manufacturer-specific tools were examined in this section: MFG Tool 1, MFG Tool 2, and MFG TOOL 3¹. The inputs to the three manufacturer sizing tools are similar with some variations. The common inputs for the manufacturer sizing tool inputs are as follows:

- Fuel Type
- Number of apartment units
- No. of bedrooms/bathrooms
- Occupancy per unit
- Design incoming water temperature
- Desired hot water temperature
- Peak period

These inputs are very similar to the inputs to ASHRAE and ASPE tools. Some tools give the option to specify numerous different floor plans with flow rates for fixtures in bathrooms and kitchens for each floor plan. Examples of inputs and outputs for each tool with the same temperature and demand requirements are presented in the figures below.

	C RESET
	SYSTEM SETTINGS
To override a	default parameter, select from the drop down list
Installation Type	Temperature Units
Indoor	✓ Fahrenheit (°F) ✓
Fuel Type	Incoming Water Temperature (°F) 📁
Natural Gas	✓ 65
ASME Required	Stored Temperature (°F) 🛕
No	✓ 135
Low NOx Installation 🔞	Altitude (ft)
No	▼ 0 0

Figure 6: MFG Tool 1 Inputs 1

¹ Manufacturer/tool names were anonymized for this report

Figure 7: MFG Tool 1 Inputs 2

	Job Info	•
	APPLICATION	DATA
	Enter the requireme	nts below
Units with 1 Bath	Shower Heads	w/ In-suite Clothes Washer
0	2.5 GPM	w/ in-suite Clothes Washer
Units with 11/2 Bath	Shower Heads	
100	2.5 GPM	w/ In-suite Clothes Washer
Units with 2 Bath	Shower Heads	
0	2.5 GPM	w/ In-suite Clothes Washer
Units with 21/2 Bath	Shower Heads	
0	2.5 GPM	w/ In-suite Clothes Washer
Units with 3 Bath	Shower Heads	
0	2.5 GPM	w/ In-suite Clothes Washer
Units with 31/2 Bath	Shower Heads	
0	2.5 GPM	w/In-suite Clothes Washer
Shower Minutes Per Hour 💡		
7 -0		

Figure 8: MFG Tool 1 Outputs

VOLUME WATER H	IEATER RECOMMENDATIO #1	DN	
М			
Heaters Required	1	Heater Model No.	
			No Pump 500-2000 📑 Pump Mounted 500-2000 📑
Heater Capacity	0 USG	Input per Hour	500,000 BTU/HR
 Thermal Efficiency	85%	Venting	N/A
Storage Tanks	1 @ 340 USG	Tank Model	Custom (340 USG) Custom Tank Spec Sheet 🗎
Usable Storage	238 USG	Recovery	729 USGPH @ 70 °F Rise
Approx. 1st Hour Delivery	967 USG	Approx. 3 Hour Avg. Delivery	808 USG
Approx. Storage Recovery	28 MINUTES	% of Demand Satisfied	101%
		Se	lect

Figure 9: MFG Sizing Tool 2 Inputs 1

Application Sizing		and application sizing fields to have Pro-Size calculate the estimated hot "Continue" button to view the recommended A. O. Smith heaters for
Results Selection	System Settings	Switch to SI/Metric units.
Payback Calculator	Equipment:	Water Heaters Only (no external storage)
Product Literature		O Water Heaters with external storage if required
		 Commercial Tankless Heaters (no storage)
		O Boilers with external storage tank
	Fuel Type: Equipment Location:	Natural Gas
	Other Requirements:	Low NOx - Requirements of < 40 ng/J or 55 PPM
		 Ultra Low NOx - Requirements of < 14 ng/J or 20 PPM ASME Approved
	Display CDN Products:	
	# of Heaters:	Not Specified (Auto)
	Altitude:	Less than 2000 ft

Apartment Building Sizing

Figure 10: MFG Sizing Tool 2 Inputs 2

Application Data						
Temperatures						
Cold Water Temp:	65	°F				
Stored Water Temp:	135	۰F				
Load Profile						
Building Use:	Medium Pe	ak Demand	~	More Info.		
Peak Demand Period:	1	HOURS (C	Sustom?)		
Unit Application Loads						
Shower Head Flowrate:	2.5	USGPM				
Units with 1 Bath:	0	Persons pe	r unit:	1.5		🗌 w/ Clothes Washer
Units with 1-1/2 Baths:	0	Persons pe	r unit:	2		u/ Clothes Washer
Units with 2 Baths:	0	Persons pe	r unit:	2.5		🗌 w/ Clothes Washer
Units with 2-1/2 Baths:	0	Persons pe	r unit:	3		uv/ Clothes Washer
Laundry Room or Coin-Op La	undry					
Include Coin-Operated Lag	undry					
Model 1 - Quantity:	0	Capacity:	0	LE	в	
Model 2 - Quantity:	0	Capacity:	0	LE	в	
Additional Load and Intention	nal Oversize					
Additional Load:	0	USGPH ((stored	temp)		
Design Oversize	0%		~			
Load Summary						
Louis Summary						
Peak Demand:	0 USGPH	Tem	nperature	e Rise:		70 °F

Figure 11: MFG Sizing Tool 2 Outputs

	Search Res	sults									
Pro-Size Steps Application	To view detailed product information, select the recommended A. O. Smith heater that you feel best suits your application.										
Sizing Results	Load Summary	,									
Selection											
	Peak Demand:	571 USGPH	Tem	perature Rise: 70	٥F						
Payback Calculator											
Product Literature	Recommen	ded Products									
		BTH-400 Mxi Cyclone® Mxi Mod	lulating		Select						
	* 1	# Heaters: Heater Storage (ea): Input (ea):	1 119 USG 399,900 Btu/hr	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est, Storage Recovery:	657 USGPH @ 70 °F Rise 740 USGPH 685 USGPH 11 min						
	C.	New External Tanks: Total Usable Storage:	-	% Of Demand:	122% (2-hour peak)						
	1	BTH-150 Mxi Cyclone® Mxi Mod	lulating		Select						
	* ** *	# Heaters: Heater Storage (ea): Input (ea): New External Tanks:	150,000 Btu/hr	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	509 USGPH @ 70 °F Rise 649 USGPH 555 USGPH 24 min						
	. 6	Total Usable Storage:	-	% Of Demand:	101% (2-hour peak)						
		BTHL-400A Cyclone® LV (Larg	ge Volume)		• Select						
		# Heaters: Heater Storage (ea): Input (ea):	399,000 Btu/hr	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	644 USGPH @ 70 °F Rise 798 USGPH 696 USGPH 20 min						
		New External Tanks: Total Usable Storage:	-	% Of Demand:	126% (2-hour peak)						

Figure 12: MFG Tool 3 Inputs

Application Type	Apartment/Multi-family						
Unit Type	Water Heater						
Storage (gl)	N/A						
Fuel Type	Gas						
llation Zip Code	Amo	ount Au	io *				
Inlet (*F)	65 Outlet	(*F) 13	5		Elev. (ft)	0	
Load (auto 🗆)	Peak	(hr) 1			Rec. (hr)	1	
ASME	Low	NOx	1	U	Itra-Low NOx		
			J			\square	
dures			J				
ktures Click Here To Ar	dd Fixture *	Qty	Flow (GPH)	Flow (GPM)	Time (min)	Temp (°F)	Edit
	dd Fixture * Single Bath Units	Qty					Edit
		Qty 		(GPM)	(min)	("F)	Edit
	Single Bath Units			(GPM) 2.5	(min) 12	(°F) 105	Edit
	Single Bath Units 1 1/2 Bath Units			(GPM) 2.5 3	(min) 12 12	(°F) 105 105	


Figure 13: MFG Tool 3 Outputs

	Model		Quantity	1	
-	Input	270000 BTU	Delivery	4	92 US Gallons
	Size	100 US Gallons	Recovery	y 4	22 US GPH at 62 °F rise
i • •	Fuel Type	Gas	Storage	Tank N	I/A
4==1	Efficiency	80%			
ect Anoth					
			Qu	antity	1
	ry Match 🔹	270000 BTU		antity livery	1 492 US Gallons
	ry Match + Model	270000 BTU 100 US Gallons	De		

Summary of Sizing Methodology Inputs/Outputs

In summary, all water heater sizing methods investigated in this study use a similar set of system inputs to calculate water heater capacity and storage tank volume as shown in Figure 14 below. The methods used for sizing water heaters are ASPE, ASHRAE, and manufacturer sizing tools. The specific inputs and outputs for these tools are summarized below in Table 2, Table 3, and Figure 14.

Figure 14: Water Heater Capacity and Storage Tank Sizing Method



				Manufa	cturer Tools		Califo	ornia Codes *for refere	nce only. not used fo	r water heater sizing*		reference only, not used for eater sizing*	
Inputs	ASPE (American Society of Plumbing Engineers)	ASHRAE	LAAR! · · · · · · · · · · · · · · · · · · ·	MFG To	pol 1	MFG	vr MFG	Diumhine i Tool 2	Code (IAPMO UPC): /ater Distribution izing)	Plumbing Code (IAPMO UPC): Appendix A	Plumbing Code (IAPMO UPC): Appendix M	ICC: International Plumbing Code	IECC: 2021 International Energy Conservation Code
Installation Type (indoor/ outdoor)			X			x	х		Х	Х	Х	Х	
Fuel Type									Х	Х			X
Gallons per person	X	Х											
Season Changes to Gallons per person	х												
ASME required (Y/N)			X	[х	х		Х	Х			
Incoming water Temp		Х	X	[1	Х	Х				X	Х	
Stored Water Temp		Х			1	х	х		Х	Х		Х	
Building use (High, Med, Low) & Peak demand use time	X	Х			3	х	х		Х	х			
# of Units	X	Х	X		3	х	х		Х	х	х		
# of Units with 1/1.5/2/2.5 baths	X	х	X	(х	х		Х	Х	Х		
Number of Bathroom Fixtures (Bathtub, Bidet, Bath/shower													
combo, Faucet, Shower, water closet)			x						х	х		x	x
Shower head GPM			X				х			Х			
Shower Minutes Per Hour			X										
Bathroom Flow (GPM), time (min), and Temp (F)						x				х			
Persons per Unit		x					Х				x		
Heating Device Efficiency (%)		x											X
Peak Minutes	x	x				x	Х			х			~
Include Laundry? (Y/N)	~	x	×	,		x	X			~			
(If laundry) Quantity, Capacity, Temperature required	x	x	X			x	X						
Number of laundry fixtures (Washing machine, Faucet)	x	~	^			~	~		Х				
Include Food Service / Restaurant? (Y/N)	x	x	×	,		x			X				
(If Food Service) # of sinks and sizes & temperatures	x	x	x			x							
Number of Kitchen Fixtures (Dishwasher, Faucet/kitchen	^	^	^			^							
sink)	x								x		x	х	
Number/ type of other fixtures	^								x		x	X	
Laws about flow restrictions or temp	x								X		^	Λ	X
Flowrate of all fixtures	^								х				Λ
									X	V	× ×	×	X
Pipe Diameter								-		X	X	Х	X
Pipe Length										X	X		X
Pipe Material										Х	X		X
Pipe Insulation													
Pipe velocity											X		
Altitude			X			х	Х			Х		Х	
Low Nox (Y/N)			X			х	 Х						
Diversity Factor			X										
Additional Load (GPH)							Х						
Length of Service										Х			
Design oversize							Х						
Recirculation Loop			X										
Recirculation Tank temp			x				х			х			

Table 3: Outputs from Different Sizing Methods

Outputs	ASPE (American Society of Plumbing Engineers)	ASHRAE	LAARS, white (F MFG 1		va	de (IAPMO UPC): Tool 2 ater Distribution izing)	Plumbing Code (IAPMO UPC): Appendix A	Plumbing Code (IAPMO UPC): Appendix M	IPC: International Plumbing Code	IECC: 2021 International Energy Conservation Code
Gallons per person	х	х								
Gallons per minute	х									
Friction loss in piping										
Wahter heater Input		х	x	x	x					
Usable Storage Capacity	х	х	×		х					
Heater Storage Tank		х	×	×	x					
Heating Rate		х								
Heater Recovery					x					
1st hour delivery			×		x					
# of heaters			x	х	x					
Estimated storage recovery			×	×	x					
3 hour avg delivery			×		X					

Analysis of Methods

ASHRAE and ASPE

ASPE and ASHRAE provide clear assumptions and calculations that can be used to properly size a water heater. They share a similar approach to sizing a DHW system and use the same underlying data. Both consider Low, Medium, and High consumption profiles and different peak periods to calculate the heat rate and storage tank volume required to meet the hot water demand during specific peak periods. Both ASHRAE and ASPE provide water consumption profiles based on data collected approximately 30–40 years ago (1994), as illustrated in the captions from the ASPE Handbook shown in Figure 1 [5].

Since the ASHRAE and ASPE consumption profile data was collected over 30 years ago, the Study Team gathered hot water usage data from a more recent study by The Water Research Foundation, "Residential End Uses of Water, Version 2 Executive Report" [10] (REUW) and compared it to the ASHRAE and ASPE data. According to this source, the current per-person hot water consumption averages are lower compared to ASHRAE and ASPE. This is attributed to the increased use of water-efficient fixtures and appliances since the ASHRAE/ASPE data was gathered. The actual gallons per household per day (GHPD) hot water consumption in the REUW report is split into different categories shown in Table 4 and includes the impacts of leaks.

Shower39.1%17.8 gphdFaucet33.8%15.4 gphdClothes washer9.7%4.4 gphdBath5.7%2.6 gphdDishwasher4.8%2.2 gphdLeak4.6%2.1 gphdOther2.0%0.9 gphdToilet0%0.0 gphd			
Clothes washer9.7%4.4 gphdBath5.7%2.6 gphdDishwasher4.8%2.2 gphdLeak4.6%2.1 gphdOther2.0%0.9 gphdToilet0%0.0 gphd	Shower	39.1%	17.8 gphd
Bath5.7%2.6 gphdDishwasher4.8%2.2 gphdLeak4.6%2.1 gphdOther2.0%0.9 gphdToilet0%0.0 gphd	Faucet	33.8%	15.4 gphd
Dishwasher4.8%2.2 gphdLeak4.6%2.1 gphdOther2.0%0.9 gphdToilet0%0.0 gphd	Clothes washer	9.7%	4.4 gphd
Leak4.6%2.1 gphdOther2.0%0.9 gphdToilet0%0.0 gphd	Bath	5.7%	2.6 gphd
Other2.0%0.9 gphdToilet0%0.0 gphd	Dishwasher	4.8%	2.2 gphd
Toilet0%0.0 gphd	Leak	4.6%	2.1 gphd
	Other	2.0%	0.9 gphd
Total 45.5 gphd	Toilet	0%	0.0 gphd
	Total		45.5 gphd

Table 4: Average Daily Hot Water use per Household REUW [10]

The Study Team determined that leaks should not be included in calculating the total daily hot water use per household, making the total *43.4 gallons per household per day*. Assuming the number of people per household to be 2.6², the calculated daily average per capita hot water use is about 16.6 gallons [10]. This average is lower than the "Low" consumption profile provided by ASPE/ASHRAE. Since an average can include values below/above the average number, actual water usage in some residences can be even lower than 16.6 gallons/person-day. After consulting with an industry SME, a "Very Low" consumption value of 10 gallons per person per day was used to compare to the ASPE/ASHRAE values. This consumption would correspond to the same occupant demographics of ASHRAE/ASPE's "Low" consumption profile [5]. The ratio of the ASHRAE/ASPE and "Very Low" consumption value was used to determine the "Very Low" consumption per person per day at different peaks, as shown in Table 5.

Table 5 also shows that ASHRAE/ASPE methods is oversizing water heater heat consumption and storage tank volume because the more recent water consumption data is significantly less than the data in the "Low" consumption profile. This is consistent with anecdotal evidence of oversized water heaters in California.

Consumption	Peak Minutes (gallons/person)						Max Daily
Profile	5	15	30	60	120	180	(gallons/day)
Very Low	0.2	0.6	1.0	1.6	2.5	3.4	10
Low [5]	0.4	1	1.7	2.8	4.5	6.1	20
Medium [5]	0.7	1.7	2.9	4.8	8	11	49
High [5]	1.2	3	5.1	8.5	14.5	19	90

Table 5: Hot water demand as a function of consumption profile and peak minutes (gallons per person per day)

Figure 15 shows graphical representation of the "Very Low" consumption profile.

² This value from the REUW Report




Figure 15: Updated ASHRAE Hot Water Demand Profile

The next section in the report includes a comparative analysis between actual site DHW usage data with ASHRAE/ASPE and REUW data.

Analysis of ASHRAE/ASPE vs. Manufacturer tools:

The Study Team compared the manufacturer sizing tool outputs to the ASHRAE/ASPE outputs using the same set of inputs. The inputs to the manufacturer tools and ASHRAE/ASPE are shown in Table 6 below. If the manufacturer tool had additional inputs, the default values were used. Multiple iterations of manufacturer tool and ASHRAE/ASPE calculations are conducted starting with the assumption of 100 apartment units and increasing by 20-unit increments up to 240 units. This was done to understand how sizing changes with increasing hot water demand. Each of the manufacturer's tool allowed modification of the inputs listed in Table 6. The tools also contained some default settings, such as flow rate, temperature at fixture, which were not modified.

Input	Value
Units	100-240
Type of unit	1 bed/ 1.5 bath
People per unit	2.6 [10]
Temperature in	65°F
Temperature Out	135°F
Peak Time	60 minutes

Table 6: Key Assumption used in manufacturing tools to size water heater

The ASHRAE/ASPE method was used to calculate heat rate and storage tank volume for each peak period. MFG Tool 2 and MFG Tool 3 have an option to input the peak period while the MFG Tool 1 does not. After several iterations of the MFG Tool 1, it was determined that these tools most likely use a 60-minute peak period. Therefore, a 60-minute peak period was used in all tools for consistency.

Error! Reference source not found. shows the ASHRAE heat rate for different consumption profiles as the number of dwellings (and therefore the number of people) increases. Figure 17–19 illustrates that peak hot water demand has a greater impact on the recommended water heater capacity in manufacturer tools relative to the ASHRAE approach. This underscores the need to accurately predict the hot water demand when sizing water heaters.





Figure 16: ASHRAE/ASPE Calculated Heat Rate Based at Different Consumption Profiles

ASHRAE vs MFG Tool 1:

Below is the predicted water heater heat rate and storage tank volume using the MFG Tool 1 sizing tool as a function of apartment units. Each heating unit has an efficiency of 85%.

Figure 17: ASHRAE vs MFG Tool 1 Recommended Water Heater Sizes as a function of Units in a Multifamily Building



The ASHRAE method shows a steady increase in both the capacity and the storage volume as the number of apartments increases from 100–240. The capacity values at 100 and 240 apartments are similar for both Manufacturer #1 and ASHRAE. Between the two endpoints, ASHRAE capacities rise steadily. Capacity recommendations from Manufacturer #1 do not follow a straight line because the manufacturer does not produce "made-to-order" equipment, and the tool recommends actual manufacturer-produced units. ASHRAE's recommended storage tank volume increases steadily with increased demand, but


the recommendations from Manufacturer #1 are much, much lower. Comparing heat rate output with the ASHRAE method, it was concluded that the MFG Tool 1 is likely assuming a water use profile that is similar to ASHRAE's "Low".

There was less correlation between storage tank volumes, as the ASHRAE tool showed a steeper increase in tank size with increasing demand compared to the MFG Tool 1 which barely increases as the number of apartments goes up.

ASHRAE vs MFG Tool 2:

Below, in Figure 18, is the predicted water heater heat rate and storage tank volume using the MFG Tool 2 as a function of apartment units. Each heating unit has an efficiency of 96%.

Figure 18: ASHRAE vs MFG Tool 2 Recommended Water Heater Sizes as a function of Units in a Multifamily Building




Similar to the comparison with MFG Tool 1, the heat rates increase as the number of apartments goes up. MFG Tool 2 offers the flexibility to select a consumption profile, and in this case, "Medium" was chosen. However, the consumption profile seems to fall in between ASHRAE's "Medium" and "High" consumption profiles.

Again, the heat rate appears to be increasing as a function of demand, whereas storage tank volume does n

ASHRAE vs MFG Tool 3:

The final manufacturer tool under consideration was MFG 3's sizing tool. See the comparison between MFG Tool 3 and ASHRAE in Figure 19 below.





As with the two previous tools, it was observed that as demand increases, the required heat rate also increases. In this case, MFG Tool 3 uses a consumption profile which is higher than ASHRAE's "High" consumption profile. Again, the actual storage tanks recommended by MFG Tool 3 are considerably smaller than ASHRAE.

Sizing Method Findings

The Study Team conducted a comprehensive analysis of various water heating system sizing methods/tools. Below are the significant findings from this research:

- Energy and plumbing codes do not offer helpful information for sizing water heaters. While IAPMO provides hot water design flow data, it lacks guidance on how to use it for sizing. Similarly, IECC provides information on different fuel types and pipe sizing information but lacks information on how to calculate heat rate and storage tank volume. The IPC provides regulations and guidelines for plumbing system design, installation, and inspection, including safety measures for water heaters, but it does not offer information on water heater sizing, making it irrelevant for this study.
- ASHRAE and ASPE provide equations for and clear guidance for sizing water heaters and storage tanks in multifamily properties.
- The underlying data used to determine water consumption profile in ASHRAE/ASPE is dated and has high consumption values compared to the more recent data from the Residential End Uses of Water report.
- It's likely that manufacturer tools use the same basic methodology as ASHRAE and ASPE for heat rate calculations. The heat output rates in manufacturer tools matched closely with ASHRAE/ASPE values. However, manufacturer tools recommend much smaller storage tanks than ASHRAE/ASPE. This may be due to additional code requirements for larger storage tanks.
- A key difference was identified in the approach between ASHRAE and the manufacturer tools: ASHRAE seemed to offer a choice between a storage tank capable of providing hot water for peak periods or larger water heaters, while manufacturers calculated a water heater size that balances both heat rate and storage volume. ASHRAE lacked a method to combine these two factors into one equation, unlike the manufacturer tools.
- If manufacturer tools are using the same underlying data and method as ASHRAE/ASPE, it is possible that all methods oversize water heaters and storage tanks. This possibility is further investigated in later sections using actual site data and comparing against ASHRAE/ASPE and manufacturer tool recommendations.

Subject Matter Expert Interviews

The findings of the previous section determined that there are various resources used in the industry to size DHW systems. The resources are usually similar but have distinct differences leading to a lack of uniformity within the industry. The major DHW sizing resources considered were:

- American Society of Heating, Refrigerating and Air-Conditioning Engineers Handbook
- American Society of Plumbing Engineers Plumbing Engineering Design Handbook
- Manufacturer tools
- International/Uniform Plumbing Codes
- Electric Heat Pump Water Heater Tool

Therefore, SMEs in water heating for multifamily buildings were surveyed to understand:

- Issues associated with DHW sizing
- Key components considered when sizing DHW systems
- Most utilized sizing resources
- Key components considered when selecting DHW systems
- Approaches for anticipating future demand changes

Survey Participants

SMEs were recruited from various stakeholders. These included water heating manufacturers (MFG), technical experts (TE), and Contractors (C) involved in the gas-fired domestic water heating industry.

Survey Questionnaire

The survey questionnaire consisted of two sections: one with open-ended questions focused on DHW sizing and replacement, and another featuring multiple choices to be ranked. The questions were designed to collect insights from various stakeholders, i.e., technical expert, manufacturer, or contractor. The survey questionnaire is presented below.

Section 1: Open ended questions:

- Question 1: Why do you replace a water heater? (failure, age, capacity, technology)
- Question 2: Do you see any issues with how water heating system sizing is happening currently?

Section 2: Ranking Questions:

Table 7: SME Survey Question 3

Question 3	Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.									
		L/M/H (Low, Medium, High)	Rank	Explanation						
А	Number of occupants									
В	Number of apartments									
С	Demographics of the occupancy (senior, affordable, families, etc.)									
D	Number of bathrooms									
E	Type of fixtures									
F	Age of the plumbing fixtures									
G	Number of washing machines									
Н	Location of washing machines (in apartments, shared)									
I	Time of day the peak uses occur									
J	Duration of the peak periods									
К	Gallons per person per day									
L	Type of temperature maintenance system (do you prefer circulation, heat trace, etc.)									
М	If circulation, the method of balancing the riser									
N	Hot water piping material									
0	Length of the hot water piping									
Р	Diameter and volume of the hot water distribution network									
Q	Configuration of the hot water distribution network									
R	Insulation on the hot water piping									
S	Effectiveness of the pipe insulation installation									

Table 8: SME Survey Question 4

Question 4	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.										
	LMH (Low, Medium, High) Rank E:										
А	ASHRAE										
В	ASPE										
С	IPC (International Plumbing Code)										
D	IAPMO/ UPC (Uniform Plumbing Code)										
E	Manufacturer's method										
F	EHPWH Tool										
G	Measured data from the site or from a similar occupancy										
	Other method										
	Other method										
	Other method										

Table 9: SME Survey Question 5

Question 5	Here are some features that may be u Are there any other features that are important. Please ran			lain your rankings
		LMH (Low, Medium, High)	Rank	Explanation
A	Water heater efficiency			
В	Cost			
С	Location where the water heater will be installed			
D	Incoming cold-water temperature			
E	Hot water temperature			
F	Master mixing valve temperature			
G	First hour rating			
Н	Recovery efficiency			
I	Heat rate (capacity)			
J	Location where the storage tank(s) will be installed			
К	Volume of storage (one large tank or a number of smaller ones. ASME tanks?)			
L	Size of storage tanks (volume, dimensions, ASME tanks?)			
М	Heat losses of the circulation loop			
N	Brand			
0	Is water heater sizing adjusted based on the presence of preheat sources (Solar, etc.)			
Р	Gallons per hour (recovery rate)			
	Other			

Table 10: SME Survey Question 6

Question 6	Here are some ways to account for future increases in demand when selecting a water heater. Are there any others that you use? Please rank order the top five. Please explain your rankings.								
		Rank	Explanation						
А	Provide space for additional water heaters								
В	Provide space for additional storage tanks								
С	Install larger storage as part of initial design								
D	Install additional storage tanks as part of initial design								
E	Install heater with larger heating capacity as part of initial design								
F	Provide additional capacity in the gas line or in the electrical panel								
	Others								
	Others								

SME Responses

The surveys were conducted through 1-hour recorded video calls with each SME. First, open-ended questions were asked to identify patterns within SME responses. In the second section, experts were asked to assign importance levels (Low, Medium, High) to each sizing element. The responses initially assigned as "High" were further ranked from 1-5 to provide quantifiable answers for statistical analysis. The scaling system is based on the importance of the specific element being questioned, where 1 is the rank given to the most important element, 2 as the second most important, and so on. An example of a response to question 3 is shown in Table 11 to show the "Low," "Medium," and "High" categories and scores associated with the sizing elements that ranked "High". All SME responses are presented in Appendix 1. The survey questions were standardized across all experts to ensure consistency, and the ranking process aimed to quantify the results. To quantify the importance of each element in the ranking questions, each ranking was assigned a score. The most important ranking of "1" was given a score of 5, "2" was given a score of 4, and so on. Components that were not categorized as "High" automatically received a score of 0. This was done to ensure that the most important sizing element received the highest score. Table 12-Table 19 summarize the responses from all SMEs interviewed with values of the scores quantified based on their rankings. Figure 20-Figure 23 present the results in pie charts to show which elements had the highest score and were ranked of highest importance.

Table 11: SME #12 Question 3 Responses

Question 3	Here are some key components needed for the si components? Please rank order t		• •	
		LMH (Low, Medium, High)	Rank	Explanation
А	Number of occupants	Н	2	Establishes demand
В	Number of apartments	L		
С	Demographics of the occupancy (senior, affordable, families, etc.)	н	3	Correlated with how much usage per person
D	Number of bathrooms	L		
E	Type of fixtures	н	4	Fixture efficiency/ capability affects demand
F	Age of the plumbing fixtures	Н	5	Fixture efficiency/ capability affects demand
G	Number of washing machines	М		
н	Location of washing machines (in apartments, shared)	М		
1	Time of day the peak uses occur	L		
J	Duration of the peak periods	L		
К	Gallons per person per day	Н	1	Derivate the other 4 Highs
L	Type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	L		
М	If circulation, the method of balancing the riser	L		
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
Р	Diameter and volume of the hot water distribution network	L		
Q	Configuration of the hot water distribution network	L		
R	Insulation on the hot water piping	L		
S	Effectiveness of the pipe insulation installation	L		

DHW System Sizing Issues and Causes for Replacement

During the interviews, each SME was asked about the primary reason for replacing a water heater. Around 85% of the interviewed SMEs highlighted that the most common cause for DHW system replacement is failure. Less frequent reasons included replacements due to age, incentives, newer technologies, or capacity. Contractors, tasked with replacements after DHW failure, operate with a swift turnaround time, given the substantial impact of a failed water heater on residents. When a water heater has failed, contractors often opt for a 'like-for-like' replacement, essentially upgrading to a newer version of the same-sized system. However, when sizing new DHW systems or replacements not due to failure, contractors often defer to manufacturers to recommend DHW systems which are sized based on manufacturer tools. According to SME #8 and SME #29, who are contractors, it is advantageous to use manufacturer tools to size DHW systems in these cases because manufacturers provide a guarantee that their sizing predictions will be sufficient. If their calculations are insufficient, the manufacturers commit to supplying all additional equipment at no additional cost. Technical experts, usually contacted early in the designing of a building, are tasked with sizing a DHW system based on certain design considerations and demand requirements without the presence of an existing system. Since there are different end goals and time constraints regarding DHW system sizing for each type of SME, there is often a divergence in sizing approaches between technical experts, manufacturers and contractors. When replacing failed systems, contractors and building managers typically choose the same size already in place, leading to different sizing methodologies for new constructions, non-failure replacements, and failure replacements.

When asked about the main issue with DHW system sizing, 72% of SMEs agreed that systems were often oversized, citing a lack of uniformity in sizing tools. Less discussed issues included the use of outdated data in DHW sizing resources, which no longer aligns with modern, energy-efficient fixtures. Furthermore, the presence of uncertainty in realworld data underscores the need for improved modeling techniques. While many SMEs agree oversizing is an issue, SME #9 emphasized that 'oversizing is not a dirty word.' Instead, it can be viewed as a positive design approach aimed at mitigating the likelihood that users will run out of hot water, thereby reducing the maintenance calls. In traditional gas boiler water heaters, the initial cost per Btuh is small so oversizing generally has a minimal impact on upfront capital cost. However, it's essential to recognize that the industry is moving towards heat pump water heaters due to their energy efficiency, environmental benefits, and growing consumer preference. These systems do come with a higher upfront cost per Btuh, which underscores the importance of right sizing to reduce costs and improve market adoption. Additionally, as the industry transitions to heat pumps, there are not yet as many readily available resources on sizing heat pump water heaters, which is causing a gap in proper sizing practices.

Key Parameters for DHW System Sizing

In Question 3, each SME was presented with several parameters affecting DHW sizing and was asked to categorize each as "High", "Medium" or "Low" importance and then number rank the "High" importance parameters. Then a score was assigned to each parameter based on its rank with higher scores being more important variables. The most important DHW sizing component was found to be "Number of Occupants" with a total score of 108 as shown in Figure 20. According to the interviewees, having an accurate count of occupants in a multifamily building is crucial in establishing the hot water demand. The components that received the next highest scores were "Gallons per Person per Day" with a score of 52, and "Demographics of the occupancy" with a score of 35. These five (5) highest scorings components are all used in ASHRAE sizing tool. This indicates agreement between ASHRAE's sizing methodologies and the survey findings. Table 7Table 10 and Figure 20Figure 23 show the scored responses by the SMEs.

Q3	DHW System Sizing Component	Total Score	Mean	Standard Deviation	cv
А	number of occupants	108	3.72	1.98	0.53
В	number of apartments	62	2.14	2.06	0.97
С	demographics of the occupancy	35	1.21	1.54	1.28
D	number of bathrooms	28	0.97	1.77	1.83
E	type of fixtures	21	0.72	1.51	2.08
F	age of the plumbing fixtures	1	0.03	O.18	5.29
G	number of washing machines	14	0.48	0.97	2.01
Н	location of washing machines (in apartments, shared)	8	O.28	0.64	2.31
I	time of day the peak uses occur	13	0.45	0.97	2.16
J	duration of the peak periods	52	1.79	1.67	0.93
К	gallons per person per day	73	2.52	1.94	0.77
L	type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	21	0.72	1.17	1.62
М	If circulation, the method of balancing the riser	5	O.17	0.59	3.43
N	length of the hot water piping	2	0.07	0.36	5.29
0	diameter and volume of the hot water distribution network	5	O.17	0.46	2.67
Р	configuration of the hot water distribution network	5	O.17	0.53	3.07

Table 12: Key Components for DHW System Sizing SME Responses Summary

Table 13: Key Components for DHW System Sizing SME Responses Part 1

	А	В	С	D	Е	F	G	Н
Q3	number of occupants	number of apartments	demographics of the occupancy	number of bathrooms	type of fixtures	age of the plumbin g fixtures	number of washing machines	location of washing machines (in apartments, shared)
Total Score	108	62	35	28	21	1	14	8
Mean	3.72	2.14	1.21	0.97	0.72	0.03	0.48	0.28
Standard Deviation	1.98	2.06	1.54	1.77	1.51	0.18	0.97	0.64
Coefficient of Variation	0.53	0.97	1.28	1.83	2.08	5.29	2.01	2.31
SME 1	0	2	0	4	5	0	3	0
SME 2	4	1	0	0	0	0	0	0
SME 3	5	3	0	0	0	0	0	0
SME 4	3	5	1	0	0	0	0	0
SME 5	5	3	0	0	0	0	2	0
SME 6	4	0	2	0	0	0	0	0
SME 7	5	5	0	2	1	0	0	0
SME 8	5	0	0	4	0	0	0	0
SME 9	0	0	0	0	0	0	0	0
SME 10	0	5	4	0	0	0	0	1
SME 11	4	0	3	0	2	1	0	0
SME 12	5	2	4	0	0	0	0	0
SME 13	5	0	4	0	0	0	0	0
SME 14	5	0	4	0	0	0	0	0
SME 15	5	5	3	0	0	0	0	0


	А	В	С	D	E	F	G	н
Q3	number of occupants	number of apartments	demographics of the occupancy	number of bathrooms	type of fixtures	age of the plumbin g fixtures	number of washing machines	location of washing machines (in apartments, shared)
SME 16	0	0	0	0	0	0	0	0
SME 17	5	5	1	0	0	0	0	0
SME 18	5	5	1	0	0	0	0	0
SME 19	5	0	0	0	0	0	0	0
SME 20	5	1	0	0	0	0	0	2
SME 21	5	1	0	0	0	0	0	2
SME 22	5	4	3	0	5	0	0	0
SME 23	5	0	0	0	0	0	0	0
SME 24	5	5	0	4	0	0	2	0
SME 25	5	2	2	0	1	0	0	0
SME 26	3	0	0	0	4	0	0	0
SME 27	0	4	3	5	0	0	2	1
SME 28	5	0	0	4	3	0	2	0
SME 29	0	4	0	5	0	0	3	2

Table 14: Key Components for Water Heater Sizing SME Responses Part 2

	I	J	К	L	М	Ν	0	Р
Q3	time of day the peak uses occur	duration of the peak periods	gallons per person per day	type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	lf circulation, the method of balancing the riser	length of the hot water piping	diameter and volume of the hot water distributio n network	configuration of the hot water distribution network
Total	13	52	73	21	5	2	5	5
Mean	0.45	1.79	2.52	0.72	0.17	0.07	0.17	0.17
Standard Deviation	0.97	1.67	1.94	1.17	0.59	0.36	0.46	0.53
Coefficient of Variation	2.16	0.93	0.77	1.62	3.43	5.29	2.67	3.07
SME 1	0	1	0	0	0	0	0	0
SME 2	3	2	5	0	0	0	0	0
SME 3	0	4	0	0	0	0	0	0
SME 4	0	2	0	0	0	0	0	0
SME 5	0	1	4	0	0	0	0	0
SME 6	0	5	3	2	0	2	2	2
SME 7	0	3	4	0	0	0	0	0
SME 8	0	2	3	0	1	0	0	0
SME 9	0	0	0	0	0	0	0	0
SME 10	2	3	0	0	0	0	0	0
SME 11	0	0	5	0	0	0	0	0
SME 12	1	1	4	3	0	0	0	0

	I	J	К	L	М	Ν	0	Р
Q3	time of day the peak uses occur	duration of the peak periods	gallons per person per day	type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	lf circulation, the method of balancing the riser	length of the hot water piping	diameter and volume of the hot water distributio n network	configuration of the hot water distribution network
SME 13	0	0	3	2	0	0	1	0
SME 14	0	3	0	0	0	0	0	0
SME 15	3	3	4	1	0	0	1	1
SME 16	0	0	5	4	0	0	0	0
SME 17	0	4	3	2	0	0	0	0
SME 18	0	4	3	2	0	0	0	0
SME 19	1	1	4	3	3	0	0	0
SME 20	0	4	3	0	0	0	0	0
SME 21	0	4	3	0	0	0	0	0
SME 22	0	0	0	0	0	0	0	0
SME 23	0	0	4	2	0	0	1	0
SME 24	0	1	3	0	0	0	0	0
SME 25	3	4	5	0	0	0	0	0
SME 26	0	0	5	0	0	0	0	2
SME 27	0	0	0	0	0	0	0	0
SME 28	0	0	0	0	1	0	0	0
SME 29	0	0	0	0	0	0	0	0

Figure 20: Key Components for DHW System Sizing SME Responses Summary



System Sizing Resources


The subject matter experts were presented with a variety of sizing resources and asked to categorize and rank their preferred resources. ASHRAE's handbook emerged as the most preferred resource with a score of 85. The second most preferred resource is the EHPWH Tool with a score of 60, which incorporates calculations often derived from the ASHRAE Handbook. SME #19, who specializes in non-failure DHW system replacement projects, mentioned that they prefer using the EHPWH Tool as their sizing resource because it is regularly updated with current data. Measured data from the site or sites with similar occupancy characteristics was the third preferred resource with a score of 55. The top scoring resource, ASHRAE's handbook, requires time consuming calculations. So, even though it is the most preferred resource, it is often not used in the case of failure because it is not always feasible to conduct exhaustive sizing calculations under such time constraints. As discussed before, replacement due to failure is usually done by 'like-for-like' replacement. However, 'like-for-like' replacement is not a sizing resource and was not included in this section of the survey. Therefore, in these cases, experts resort to readily available measured data from similar occupancy profiles or easily accessible manufacturer tools. SME #11, who prioritized measured data from similar occupancy profiles as their top choice, emphasized that this data holds a significant advantage. It is favored because it provides insight into an already functioning system, offering a practical reference point for sizing DHW systems. Table 15 and Figure 21 below show a summary of the SME responses.

	А	В	С	D	E	F	G
Q4	ASHRAE	ASPE	IPC (International Plumbing Code)	IAPMO/ UPC (Uniform Plumbing Code)	Manufacturer's method	EHPWH Tool	Measured data from the site or from a similar occupancy
Total Score	85	44	13	27	49	60	55
Mean	2.93	1.52	0.45	0.93	1.69	2.07	1.90
Standard Deviation	1.89	1.89	1.07	1.51	2.07	2.21	1.97
Coefficient of Variation	0.65	1.24	2.39	1.62	1.22	1.07	1.04
SME 1	3	4	2	5	0	0	0
SME 2	4	2	0	0	0	5	3
SME 3	5	0	3	2	4	0	0
SME 4	0	0	0	0	0	3	4
SME 5	5	4	0	0	3	0	0
SME 6	2	1	0	3	0	4	5
SME 7	5	2	3	4	0	0	0
SME 8	4	3	1	2	5	0	0
SME 9	5	0	0	0	0	0	0
SME 10	5	5	0	0	3	4	2
SME 11	3	0	0	2	0	4	5
SME 12	2	2	0	0	3	5	4
SME 13	0	0	0	0	0	0	0
SME 14	5	4	0	0	0	0	0

Table 15: Water Heater Sizing Resources SME Responses

	А	В	С	D	E	F	G
Q4	ASHRAE	ASPE	IPC (International Plumbing Code)	IAPMO/ UPC (Uniform Plumbing Code)	Manufacturer's method	EHPWH Tool	Measured data from the site or from a similar occupancy
SME 15	2	0	0	0	1	5	3
SME 16	0	0	0	0	0	0	0
SME 17	4	5	0	0	0	3	0
SME 18	4	5	0	0	0	3	0
SME 19	4	0	0	2	0	5	3
SME 20	3	0	0	0	5	0	4
SME 21	3	0	0	0	5	0	4
SME 22	5	0	4	3	0	0	0
SME 23	3	0	0	0	0	4	5
SME 24	0	0	0	0	0	0	0
SME 25	4	3	0	0	5	5	5
SME 26	5	4	0	0	2	5	3
SME 27	0	0	0	4	5	0	3
SME 28	0	0	0	0	3	5	2
SME 29	0	0	0	0	5	0	0

Figure 21: Water Heater Sizing Resources SME Responses Summary



Key Parameters for DHW System Selection

In the process of selecting DHW systems, SMEs often face the task of choosing between multiple manufacturers, brand makes, and models of DHW Heaters/Boilers after completing the sizing process. The SMEs were asked which components are considered when selecting their preferred water heater. The most highly ranked component for system selection, with a score of 93, was "Heat Rate (Capacity)" followed by "Size of Storage Tanks" with a score of 58. These findings align with those from the previous section, which affirm that these are the most crucial features when selecting DHW systems. Many readily available sizing tools often output the capacity of the water heater in Btuh, and the size of the water heater tanks in gallons when recommending DHW systems. The SMEs' responses to this question are presented in Table 16 and Figure 22. According to SME #13, the key determinant when selecting a DHW system is its capacity, as it often determines the system's ability to fulfill demand.

The parameters that shared the third rank, with a score of 57, were "Cost" and "Gallons per hour (recovery rate). Many SMEs highlighted that cost plays a significant role in determining whether the customer can afford the system. "Recovery Rate" emerged as a top consideration due to its ability to ensure a consistent supply of hot water during peak periods. Although not a high-scoring parameter, many contractors emphasized the importance of the "Brand" in their selection criteria, citing brand loyalty and a preference for recommending products with positive past experiences. This section sheds light on the considerations involved in the selection of DHW systems, ranging from technical specifications to cost and brand reputation.

Table 16: Key Components for DHW System Selection SME Responses Summary

Q5	DHW System Selection Component	Total	Mean	Standard Deviation	cv
А	Water heater efficiency	48	1.66	1.58	0.96
В	Cost	57	1.97	1.87	0.95
С	Location where the water heater will be installed	35	1.21	1.54	1.28
D	Incoming cold water temperature	5	0.17	0.59	3.43
E	Hot water temperature	13	0.45	1.16	2.59
F	Master mixing valve temperature	6	0.21	0.92	4.47
G	First hour rating	43	1.48	2.09	1.41
Н	Recovery efficiency	27	0.93	1.51	1.62
1	Heat rate (capacity)	93	3.21	1.88	0.59
J	Location where the storage tank(s) will be installed	4	0.14	0.57	4.14
К	Volume of storage (one large tank or a number of smaller ones. ASME tanks?)	21	0.72	1.53	2.11
L	Size of storage tanks (volume, dimensions, ASME tanks?)	58	2.00	2.05	1.03
М	Heat losses of the circulation loop	2	0.07	0.36	5.29
Ν	Brand	21	0.72	1.46	2.02
0	Is water heater sizing adjusted based on the presence of preheat sources (Solar, etc.)	6	0.21	0.66	3.21
Р	Gallons per hour (recovery rate)	57	1.97	2.19	1.11

Table 17: Features in Selecting Water Heaters SME Responses Part 1

	А	В	С	D	E	F	G	н	l I
Q5	Water heater efficiency	Cost	Location where the water heater will be installed	Incoming cold-water temperature	Hot water temperature	Master mixing valve temperature	First hour rating	Recovery efficiency	Heat rate (capacity)
Total	48	57	35	5	13	6	43	27	93
Mean	1.66	1.97	1.21	0.17	0.45	0.21	1.48	0.93	3.21
Standard Deviation	1.58	1.87	1.54	0.59	1.16	0.92	2.09	1.51	1.88
Coefficient of Variation	0.96	0.95	1.28	3.43	2.59	4.47	1.41	1.62	0.59
SME 1	0	0	0	0	4	5	0	0	2
SME 2	0	2	3	0	0	1	5	4	0
SME 3	0	5	0	0	0	0	4	0	1
SME 4	5	3	2	0	4	0	0	0	0
SME 5	3	2	0	0	0	0	0	0	5
SME 6	5	0	0	0	0	0	3	2	1
SME 7	1	0	0	0	Ο	0	5	0	2
SME 8	2	1	0	0	0	0	5	0	3
SME 9	1	2	0	0	0	0	4	0	3
SME 10	0	2	0	0	0	0	5	4	3
SME 11	0	5	0	0	0	0	0	0	4
SME 12	3	4	2	0	0	0	5	0	5
SME 13	3	1	0	0	0	0	0	0	5
SME 14	3	4	0	0	0	0	0	0	5


	Α	В	С	D	E	F	G	н	l I
Q5	Water heater efficiency	Cost	Location where the water heater will be installed	Incoming cold-water temperature	Hot water temperature	Master mixing valve temperature	First hour rating	Recovery efficiency	Heat rate (capacity)
SME 15	1	5	2	3	0	0	0	0	4
SME 16	3	0	0	0	0	0	0	5	4
SME 17	0	0	2	0	0	0	0	3	5
SME 18	0	0	2	0	0	0	0	3	5
SME 19	2	0	4	0	0	0	0	0	5
SME 20	3	4	1	0	0	0	0	2	5
SME 21	3	4	1	0	0	0	0	2	5
SME 22	0	0	1	0	0	0	4	2	3
SME 23	2	0	0	0	3	0	0	0	5
SME 24	2	3	5	0	0	0	0	0	4
SME 25	4	3	0	1	2	0	0	0	0
SME 26	2	3	5	0	0	0	0	0	4
SME 27	0	4	2	1	0	0	0	0	0
SME 28	0	2	3	0	0	0	0	0	5
SME 29	0	5	0	0	0	0	3	0	0

Table 18: Features in Selecting Water Heaters SME Responses Part 2

	J	К	L	М	N	0	Р
Q5	Location where the storage tank(s) will be installed	Volume of storage (one large tank or several smaller ones. ASME tanks?)	Size of storage tanks (volume, dimensions , ASME tanks?)	Heat losses of the circulation loop	Brand	Is water heater sizing adjusted based on the presence of preheat sources (Solar, etc.	Gallons per hour (recovery rate)
Total	4	21	58	2	21	6	57
Mean	0.14	0.72	2.00	0.07	0.72	0.21	1.97
Standard Deviation	0.57	1.53	2.05	0.36	1.46	0.66	2.19
Coefficient of Variation	4.14	2.11	1.03	5.29	2.02	3.21	1.11
SME 1	0	3	1	0	0	0	0
SME 2	0	0	0	0	0	0	0
SME 3	0	0	3	0	2	0	0
SME 4	0	0	0	0	1	0	0
SME 5	0	0	4	0	0	0	0
SME 6	0	4	0	0	0	0	0
SME 7	0	4	3	0	0	0	0
SME 8	0	0	0	0	4	0	0
SME 9	0	0	0	0	0	0	5
SME 10	0	0	0	0	0	0	0
SME 11	3	0	0	0	0	0	4
SME 12	0	0	0	0	1	0	5

	J	К	L	М	Ν	0	Р
Q5	Location where the storage tank(s) will be installed	Volume of storage (one large tank or several smaller ones. ASME tanks?)	Size of storage tanks (volume, dimensions , ASME tanks?)	Heat losses of the circulation loop	Brand	Is water heater sizing adjusted based on the presence of preheat sources (Solar, etc.	Gallons per hour (recovery rate)
SME 13	0	4	0	0	0	2	0
SME 14	0	0	2	0	0	0	2
SME 15	0	0	0	0	0	3	0
SME 16	0	0	1	2	0	0	5
SME 17	0	0	4	0	0	0	5
SME 18	0	0	4	0	0	0	5
SME 19	0	0	5	0	0	0	0
SME 20	0	0	5	0	5	0	5
SME 21	0	0	5	0	5	0	5
SME 22	0	0	0	0	0	0	5
SME 23	0	0	4	0	1	0	0
SME 24	0	5	5	0	0	1	4
SME 25	0	0	5	0	0	0	5
SME 26	0	1	0	0	0	0	0
SME 27	0	0	3	0	0	0	5
SME 28	1	0	4	0	0	0	0
SME 29	0	0	0	0	2	0	4

Figure 22: Key Components for DHW System Selection SME Responses Summary



Accounting for Demand Increase in DHW System Sizing

When sizing DHW systems, SMEs were prompted to consider the factors necessary to accommodate future increases in demand. According to survey results, the highest ranked way to plan for increased demand, with a score of 83, is to provide space for additional storage tanks during the initial sizing of the system and mechanical room/mechanical enclosure. SME #22 indicated that storage tanks are not only more economical but also easier to install as demand grows compared to additional water heaters or the initial oversizing of the system. Respondents tend to assert that allocating additional storage tank space is the most convenient approach for accommodating future demand. The summarized SME responses are presented in Table 19 and Figure 23.


The second-highest ranking method of addressing demand increase, with a score of 66, is the need to provide additional capacity in the gas line or electrical panel. This is important as it addresses the crucial issue of ensuring that gas lines or electrical panels are appropriately sized in advance to accommodate increased demand. The difficulty and cost of resizing the power system after the fact underscores the significance of this approach.

	А	В	С	D	E	F
Q6	Provide space for additional water heaters	Provide space for additional storage tanks	Install larger storage as part of initial design	Install additional storage tanks as part of initial design	Install heater with larger heating capacity as part of initial design	Provide additional capacity in the gas line or in the electrical panel
Total	62	83	46	28	52	66
Mean	2.14	2.86	1.59	0.97	1.79	2.28
Standard Deviation	1.81	1.96	1.92	1.59	2.14	2.13
Coefficient of Variation	0.85	0.68	1.21	1.64	1.19	0.94
SME 1	5	0	0	0	4	3
SME 2	3	4	0	0	0	5
SME 3	0	0	4	3	5	0
SME 4	0	0	4	3	0	0
SME 5	0	0	0	0	0	0
SME 6	3	2	0	0	0	5
SME 7	4	4	5	2	3	0
SME 8	2	5	3	4	0	1
SME 9	0	0	0	0	0	0
SME 10	0	0	3	2	5	4
SME 11	4	3	0	0	0	5
SME 12	4	4	0	0	0	5
SME 13	0	5	0	0	0	4

Table 19 : Ways to Account for Demand Increase in Water Heater Sizing SME Responses

	А	В	С	D	E	F
Q6	Provide space for additional water heaters	Provide space for additional storage tanks	Install larger storage as part of initial design	Install additional storage tanks as part of initial design	Install heater with larger heating capacity as part of initial design	Provide additional capacity in the gas line or in the electrical panel
SME 14	0	4	0	0	5	0
SME 15	3	4	1	1	3	2
SME 16	0	0	3	0	4	5
SME 17	4	5	0	0	0	3
SME 18	4	5	0	0	0	3
SME 19	4	4	2	0	0	5
SME 20	3	4	0	0	5	0
SME 21	3	4	0	0	4	0
SME 22	0	5	0	0	0	0
SME 23	4	5	0	0	0	3
SME 24	0	0	4	0	5	3
SME 25	3	4	5	5	0	5
SME 26	1	2	5	4	3	0
SME 27	0	5	4	4	0	0
SME 28	4	3	0	0	1	5
SME 29	4	2	3	0	5	0

Figure 23: Ways to Account for Demand Increase in Water Heater Sizing SME Responses Summary



Survey Response Variation

The variation in responses is measured by the coefficient of variation (CV), calculated for questions 3–6 on the survey. These were the only questions where CV was applied since they were the only ones with quantifiable results. The lowest CV value indicates the highest level of agreement among surveyors. In question 3, where SMEs were asked about the key components needed to size DHW systems, the lowest CV of 0.53 and the highest score of 108 revealed that "Number of occupants" was the most agreed-upon factor. Moving on to question 4, regarding DHW sizing resources, the SMEs predominantly agreed that ASHRAE was the most preferred sizing resource with the highest score of 85 and the lowest CV of 0.65. For question 5, addressing the selection of DHW systems, the SMEs were aligned in considering "Heat Rate (Capacity)" with a score of 93, as the top factor which was underscored by the lowest CV value of 0.59. Lastly, in question 6, which asked SMEs to suggest adjustments to DHW systems to account for increased demand, there was a majority agreement that the optimal way, with the lowest CV of 0.68 and highest score of 83, is by providing space for additional water heaters.

SME Findings

This section identified inconsistencies in central DHW system sizing resources and methodologies for multifamily buildings. A total of (29) Subject Matter Experts were interviewed to gain more insight into the inconsistencies, preferred sizing methods, important sizing factors and gaps. Below are the main conclusions from these interviews:

- The primary reason for water heater replacement is often due to failure.
- Oversizing of water heaters is identified as a common issue.
- The findings also bring to light disparities in DHW system sizing between new construction, replacements due to failure, and replacements not due to failure.
- There are variations among contractors, technical experts, and manufacturers in their recommended sizing practices.
- The most important component for sizing DHW systems is the "Number of Occupants".
- There is a strong preference among SMEs for traditional sizing tools like ASHRAE's handbook, making it the most used resource.
- Newer tools like the EHPWH Tool and the practical use of measured data from similar sites are also favored because they are regularly updated with current data.
- "Heat Rate (Capacity)" is identified as the most important factor when selecting DHW equipment.

- The selection of DHW equipment involves considering various manufacturers and models after sizing calculations. Among contractors, brand loyalty is an important factor when selecting DHW equipment.
- SMEs find that providing space for additional storage tanks during initial sizing is the most cost-effective and convenient approach for addressing future demand increases.
- Another important design consideration is ensuring that gas lines and electrical panels have enough capacity for demand increase.

The previous section highlighted a lack of consistency in manufacturer sizing tools, potentially attributed to different sizing methodologies, although confirmation is hindered by intellectual property constraints. Unfortunately, this research was not able to add any additional insights regarding the inconsistencies between various sizing methodologies. Furthermore, as the industry transitions to heat pumps, a notable knowledge gap in proper sizing practices is observed.

In summary, this section provided insight into the preferred sizing resources, key factors considered and highlighted the divergence in sizing approaches between technical experts, manufacturers, and contractors. This study was essential in understanding the perspectives of SMEs in the DHW system sizing industry and lays the foundation for further investigation in the next section, where sizing methodologies will be compared to real-site data.

Compare Sizing Methods with Actual Site Data

The findings from the previous sections discussed various resources used to size DHW systems as well as how SMEs ranked the different sizing resources. In this section, different sizing methods are compared with actual site data. This comparison aimed to identify gaps in the commonly utilized sizing methods and provide recommendations to bridge these gaps. The DHW loads at six (6) sites were determined using hourly gas bill data or hourly monitored DHW system data and compared with the recommended DHW capacities and storage tank volumes from the following commonly used sizing methods:

- ASHRAE/ASPE
- EHPWH Tool
- Manufacturer Tools (MFG Tool 1, MFG Tool 3, MFG Tool 2)

Site Data

Site data for six multifamily sites were collected and are shown in Table 20 below. The occupant demographics for each site are shown in Table 21. For each site, the occupant demographics constitute an ASHRAE "Medium" consumption profile as explained in **Figure 1**.

Inputs	Incoming cold water temp (F)	Supply hot water temp (F)	Units	Existing DHW system input capacity (Btuh)	Existing storage tank volume (gal)	Nominal Efficiency of existing DHW system
Site 1	65	130	(72) 2 bed/ 1 bath	System 1: 750,000 Btuh System 2: 650,000 Btuh Total: 1,400,000 Btuh	System 1: 119 gal System 2: 119 gal Total: 238 gal	82%
Site 2	58	120	(18) Total: (12) 1 bed/ 1 bath, (6) studio	System 1: 263,000 Btuh	Total: 119 gal	80%
Site 3	65	135	(16) 2 bed/2 bath	System 1: 200,000 Btuh System 2: 199,999 Btuh Total: 399,999 Btuh	System 1: 99 gal System 2: 100 gal Total: 199 gal	80%
Site 4	65	140	(62) Studios	System 1: 500,000 Btuh	System 1: 115 gal	84%
Site 5	65	140	(49) Total: (12) 3 bed/ 2bath , (36) 2 bed/2 bath, (1) studio	System 1: 399,000 Btuh System 2: 399,000 Btuh Total: 798,000 Btuh	System 1: 400 gal System 2: 400 gal Total: 800 gal	82%
Site 6	66	130	(101) Total (1) 2 bed/ 1bath, (100) 1 bed/ 1 bath	System 1: 1.: 270,000 Btuh 2., 199,999 Btuh	System 1: 1. 100 gal 2. 100 gal	82%

Table 20: Site Data

Inputs	Incoming cold water temp (F)	Supply hot water temp (F)	Units	Existing DHW system input capacity (Btuh)	Existing storage tank volume (gal)	Nominal Efficiency of existing DHW system
				System 2:	System 2:	
				1. 270,000 Btuh	1. 100 gal	
				2. 199,000	2. 100 gal	
				System 3:	System 3:	
				1. 270,000 Btuh	1. 100 gal	
				2. 270,000 Btuh	2. 100 gal	
				System 4:	System 4:	
				1. 199,000 Btuh	1. 100 gal	
				2. 199,900 Btuh	2. 100 gal	
				Total: 1,876,999 Btuh	Total: 800 gal	

Site	Occupant Demographics
Site #1	Mostly working age families No housing assistance
Site #2	Working age people
Site #3	Luxury apartments for working singles, couples and families
Site #4	50% on housing assistance 50% working-age and senior adults
Site #5	Families and working age adults 20% on housing assistance
Site #6	Working age adults 30% on housing assistance

Table 21: Site Occupant Demographics

Sizing Analysis

Winter Projected Load

Property management from Sites 1, 3, 4, 5, and 6 shared hourly gas bill data for a 5-year period. The Study Team used monitored DHW data from another project (ET23SWG0001) for Site 2. The monthly gas bill data was categorized into two seasons: 'Summer' and 'Winter'. For this study, the summer months are assumed to be June, July, and August and all other months are considered winter months. According to the 2019 Residential Appliance Saturation Study (RASS) study, domestic hot water consumption emerges as the most significant gas consumption end-use during the summer months [8]. In contrast, winter months include additional gas end-uses such as space heating, contributing to variations in overall gas usage. Due to the absence of end-use level gas consumption data for sites 3-6, the study team relied on the summer gas bill data to isolate DHW consumption. This data was then scaled to predict the winter DHW load. Since site 1 provided gas bill data exclusively for DHW load, the study team utilized site 1's summer-to-winter DHW load as a reference to verify the proposed "Summer to Winter Scale Factor" for sites 4-6. Occupancy was unknown but assumed to be relatively high.

The DEER water heater calculator (DWHC) version 5.1 [11] was used to project the DHW load during the winter months and also used to determine the summer to winter scale factor. The DHWC provides hourly hot water load in Btuh for all 12 months. The inputs used in the "TechCalc" sheet of the DWHC are presented in Figure 24 below. Once the major inputs, "Building Type" and "Climate Zone," are entered, the tool has a "Calculate All Results" button which outputs the projected hourly DHW load for a full year.


Stor_EF-Gas-07	75gal-0.53E	F	-	Technology Para	neters			HPWH Technolo	gy parameters	
				Туре	Stor			HPminT	0	F
Multifamily Hor	ne	•		UEF/EF	0.53			HPmaxT	0	F
				Fuel	Gas	1000		HPmaxGal	0.0	gallons
CZ09 🔻				Volume	75	gallons		COP		
_				Сар	70.00	kW or kBtu/h		Frac Resist	0.10	
Input Spec	Index			RE/TE	0.76	TE for Com. W	Hs	RE of ER backup	0.98	
TechIndex	95	FALSE	FALSE	Draw Pattern	N/A					
BldgType	27	MFm		Tank UA	11.69	Btu/hr-F				
CZindex	9	CZ09		Aux W	0.00	watts				
				Vent W	0.00	watts		Annual Results		
		Aux Btu	350.00	Btu/hr		TechIndex	TechID	Bldg		
Calculate All Results			Aux Eff	0.67			95	Stor EF-Gas-075gal-	MF	

Figure 24: DEER water heater calculator v5.1 inputs part 1

Figure 25: DEER water heater calculator v5.1 inputs part 2

ers		Capacity Sizing Parameters			Volume Sizing Parameters		
MFm	5	Sizing Factor	1.2		Sizing Factor	1.2	
135	F	reqd capacity for peak volume	34,271	Btu/hr	reqd volume for peak volume	42	gallons
8.2	Btu/gal-F	reqd capacity * Sizing Factor	41,125	Btu/hr	reqd volume * Sizing Factor	50	gallons
Res	900	equiv capacity of one unit	91,168	Btu/hr	equiv volume of one unit:	125	gallons
41,125	Btu/hr	number of units needed:	0.45		number of units needed:	0.4	
FALSE							
27		number of units used:	1.00				
37968	Btu/hr						
	135 8.2 Res 41,125 FALSE 27	MFm 5 135 F 8.2 Btu/gal-F Res 900 41,125 Btu/hr FALSE 27	MFm 5 Sizing Factor 135 F reqd capacity for peak volume 8.2 Btu/gal-F reqd capacity * Sizing Factor Res 900 equiv capacity of one unit 41,125 Btu/hr number of units needed: FALSE 27 number of units used:	MFm5Sizing Factor1.2135Freqd capacity for peak volume34,2718.2Btu/gal-Freqd capacity * Sizing Factor41,125Res900equiv capacity of one unit91,16841,125Btu/hrnumber of units needed:0.45FALSE27number of units used:1.00	MFm5Sizing Factor1.2135Freqd capacity for peak volume34,271Btu/hr8.2Btu/gal-Freqd capacity * Sizing Factor41,125Btu/hrRes900equiv capacity of one unit91,168Btu/hr41,125Btu/hrnumber of units needed:0.45645FALSEImage: State of the state of t	MFm5Sizing Factor1.2Sizing Factor135Freqd capacity for peak volume34,271Btu/hrreqd volume for peak volume8.2Btu/gal-Freqd capacity * Sizing Factor41,125Btu/hrreqd volume * Sizing FactorRes900equiv capacity of one unit91,168Btu/hrequiv volume of one unit:41,125Btu/hrnumber of units needed:0.45number of units needed:FALSE1001.001.001.00	MFm5Sizing Factor1.2Sizing Factor1.2135Freqd capacity for peak volume34,271Btu/hrreqd volume for peak volume428.2Btu/gal-Freqd capacity * Sizing Factor41,125Btu/hrreqd volume * Sizing Factor50Res900equiv capacity of one unit91,168Btu/hrequiv volume of one unit:12541,125Btu/hrnumber of units needed:0.45number of units needed:0.4527Image: state of the s

After the tool was run, the maximum hot water load for each hour during the summer months and winter months were compiled. The maximum hourly values for each season were then plotted in Figure 26 below.





The summer to winter scale factor is 1.39 and was calculated using equation 5 below:

Equation 5: DHW Summer to Winter Scale Factor

 $DHW_{Winter:Summer} = \frac{Max Hot Water Load_{Winter}}{Max Hot Water Load_{summer}} (5)$

Max Hot Water Load_{Winter} = 24,799 BTUh Max Hot Water Load_{Summer} = 17,781 BTUh

 $DHW_{Summer:Winter} = 1.39$

The scaling methodology was validated using data from site 1 because it had gas bill data that solely reflected DHW load during both summer and winter periods. Figure 27 below illustrates the comparison between the actual winter hot water load and the winter projected load using the summer to winter scale factor of 1.39 at site 1.




Figure 27: Summer to Winter DHW load projection vs actual comparison

The data showed an average 10% difference between the 'Winter Actual' and the 'Winter Projected' data, indicating a good approximation. Table 22 below breaks down gas enduses for each site. In cases where the data was not solely DHW load, the team calculated the winter projected load based on the summer data using the winter to summer scaling factor from Equation 5.

Site	Gas Bill Data End-Uses
Site 1	DHW only
Site 2	DHW only
Site 3	DHW only
Site 4	DHW Space Heating Other miscellaneous end-uses
Site 5	DHW Space Heating Other miscellaneous end-uses
Site 6	DHW Space Heating Other miscellaneous end-uses

Table 22: Site-Specific Gas bill end-uses

Recirculation Loads

Recirculation loads can vary widely. ASHRAE does not provide a concrete way to size DHW capacity for recirculation loads. The EHPWH sizing tool does account for recirculation, and there is no way to know if the manufacturer tools account for recirculation loads or not. The DHW loads from the gas bills include recirculation. The recommended water heaters for all sizing methods must provide heating for recirculation, so the Study Team did not try to disaggregate recirculation loads from the maximum loads.

Comparisons of Sizing Tools to Site Data

The Study Team input the information from Table 20 into ASHRAE sizing tool, the manufacturer sizing tools, and the EHPWH sizing tool. The tools provide recommended DHW heating capacity and storage tank volume. The Study Team combined the DHW heating capacity and the energy in the stored hot water to develop a metric called the "Equivalent Peak Capacity". Equivalent peak capacity is found by adding the available capacity from the water heater with the available capacity from the stored hot water. Available capacity from the water heater is simply the heat rate of the burner multiplied times the efficiency. The stored hot water capacity is the tank size multiplied by 70% [6], the density of water

(8.33 lbm/gal) and the temperature difference (delta-T) between make-up and supply water temperature shown in Table 20. All values in Figures 28 through 33 and Tables 33-28 were **normalized by the total number of apartments** so the values could be easily compared between sites. Comparisons are difficult between sites without normalization because the DHW loads at the sites range widely because of the varying number of apartments at each site.

The Study Team compared the equivalent peak capacities recommended by each tool to the 75th percentile of DHW demand and to the 100Th percentile. The 100th percentile is the maximum DHW demand at the site, and if tools do not size for this demand, they risk recommending a system that could run out of hot water. However, the 75th percentile is shown and compared to because the DHW systems operate at this demand many more hours of the year.

In Figures 24 through 33

- The "AOS" bar stands for "Available on Site" and represents the Equivalent Peak Capacity (Btuh) of all DHW systems present at the site. Total capacity and storage tank volume for each site can be found in Table 20.
- The bars labeled "MFG # 1," "MFG # 2," and "MFG # 3" represent the recommended Equivalent Peak Capacity (Btuh) corresponding to each manufacturer's tool. For specific manufacturer recommendations pertaining to Site 1, refer to Appendix 2.
- The "ASHRAE" bar represents the Equivalent Peak Capacity (Btuh) calculated using the ASHRAE sizing method utilizing the inputs from Table 20.
- The "EHPWH Tool" bar illustrates the EHPWH Tool's recommended Equivalent Peak Capacity (Btuh) based on the inputs from Table 20, which are building type, incoming and outgoing water temperature, and demographic.
- The four percentile lines were created using the gas billing data. These were used to see how the DHW sizing tools compare to the DHW gas consumption at each site. Since the sizing methods do not explain if they are aiming for a 99th percentile design (as is common for space heating systems) or for a 100th percentile design, the Study Team used the gas bill data to calculate both metrics and display them. The lines for the 75th and 50th percentiles from the gas bills are also included to assess how hot water usage looks outside of the limited peak periods.

Site 1

Figure 28 illustrates the DHW capacity estimated by each sizing method in comparison to the DHW loads recorded in Site 1's gas bills during the peak winter season. Table 23 shows the sizing tool outputs, equivalent peak capacity, and comparison of outputs to actual DHW loads.






Table 23: Site 1 DHW Comparison (Per Apartment Unit)

Tool	Actual/ Recommended Capacity (Btuh)	Efficiency	Available Capacity (Btuh)	Actual/ Recommended Storge Tank Size (gal)	Stored Hot Water Capacity (Btuh)	Equivalent Peak Capacity (Btuh)	% Difference of Equivalent Peak Capacity (Btuh) to 75 th Percentile	% Difference of Equivalent Peak Capacity (Btuh) to 100 th percentile (Maximum DHW Load)
Available on Site ³	19,444	82%	15,847	3.3	1,253	17,100	392%	52%
ASHRAE	,566	82%	5,351	14.1	5,350	10,701	208%	-5%
MFG Tool 1	3,958	95%	3,760	1.1	421	4,182	20%	-63%
MFG Tool 2	6,943	95%	6,596	1.7	626	7,222	108%	-36%
MFG Tool 3	15,278	80%	12,222	2.5	948	13,170	279%	17%
EHPWH Tool	4,065	100%	4,065	33.2	12,576	16,641	64%	48%

³ From Table 20

Site 1 Conclusions and comparisons

At Site 1, the onsite DHW system is oversized compared to the 75th and 100th percentile DHW demand. The onsite unit is 392% oversized compared to the 75th percentile and 57% oversized compared to the 100th percentile.

All manufacturer tools oversized compared to the 75th percentile and only one oversized compared to the 100th percentile. MFG Tool 3 oversized by 17% compared to the 100th percentile while MFG Tool 1 undersized by 63% and MFG Tool 2 undersized by 36%. MFG Tool 2 only under sizes compared to the 100th percentile at Site 1 and Site 6.

The recommended equivalent peak capacity using the ASHRAE method was oversized by 208% compared to the 75th percentile and was under sized by 5% compared to the 100th percentile. ASHRAE only under sizes the DHW system compared to the 100th percentile at this site and Site 4. The EHPWH Tool recommended an equivalent peak capacity that was oversized by 64% compared to the 75th percentile and by 49% compared to the 100th percentile.

The manufacturer tools recommend the smallest storage tank volume, followed by ASHRAE, followed by the EHPWH Tool.

MFG Tool 3 is the closest to the actual 100th percentile without under sizing.

Site 2

Figure 29 illustrates the DHW capacity estimated by each sizing method in comparison to the projected DHW loads during the peak winter season. Site #2 used monitored DHW data from another project (ET23SWG0001) and the data came from the summer months. Table 24 shows the sizing tool outputs, equivalent peak capacity, and comparison of outputs to actual DHW loads.




Figure 29: Site 2 DHW Comparison (Per Apartment Unit)

Table 24: Site 2 DHW Comparison (Per Apartment Unit)

Tool	Actual/ Recommended Capacity (Btuh)	Efficiency	Available Capacity (Btuh)	Actual/ Recommended Storge Tank Size (gal)	Stored Hot Water Capacity (Btuh)	Equivalent Peak Capacity (Btuh)	% Difference of Equivalent Peak Capacity (Btuh) to 75 th Percentile	% Difference of Equivalent Peak Capacity (Btuh) to 100 th percentile (Maximum DHW Load)
Available on Site	14,611	80%	11,689	7	2,390	14,079	441%	81%
ASHRAE	6,381	80%	5,104	14	5,103	10,207	292%	31%
MFG Tool 1	6,944	96%	6,667	3	1,205	7,872	203%	1%
MFG Tool 2	8,556	80%	6,844	5	1,627	8,471	226%	9%
MFG Tool 3	15,000	80%	12,000	6	2,008	14,008	439%	80%
EHPWH Tool	2,394	100%	2,394	20	7,391	9,786	276%	26%

Site 2 Conclusions and comparisons

At Site 12 the onsite DHW system is oversized compared to the 75th and 100th percentile DHW demand. The onsite unit is 441% oversized compared to the 75th percentile and 81% oversized compared to the 100th percentile.

All manufacturer tools oversized compared to the 75th percentile and the 100th percentile. MFG Tool 3 oversized by 80% compared to the 100th percentile, MFG Tool 2 oversized by 9% and MFG Tool 1 undersized by only 1%. This is the only site where MFG Tool 1 meets the 100th percentile. MFG Tool 1 could be meeting the 100th percentile here because this site has only 18 apartments. Even the smallest units built by MGF 2 may be sufficient for the maximum DHW load for 18 apartments.

The recommended equivalent peak capacity using the ASHRAE method was oversized by 292% compared to the 75th percentile and by 31% compared to the 100th percentile. The EHPWH Tool recommended an equivalent peak capacity that was oversized by 276% compared to the 75th percentile and by 26% compared to the 100th percentile.

The manufacturer tools recommend the smallest storage tank volume, followed by ASHRAE, followed by the EHPWH Tool.

MFG Tool 2 was the closest to the actual 100th percentile without under sizing. At this site, all of the tool recommendations were able to meet the 75th percentile and the 100th percentile DHW demands. ASHRAE might over predict the maximum DHW load at this site because 2.6 people per apartment was used for all sites, but there are six and (12) 1 bedroom/1 bathroom units so a better approximation of people per unit would be 1.5.

Site 3

Figure 30 illustrates the DHW capacity estimated by each sizing method in comparison to the DHW loads recorded in Site 3's gas bills during the peak winter season. Table 25 shows the sizing tool outputs, equivalent peak capacity, and comparison of outputs to actual DHW loads. The inputs utilized for each of the sizing tools to recommend DHW units for site 3 are in Table 20. For EHPWH Tool and manufacturer tool recommendations specific to Site 3 refer to Appendix 2.






Table 25: Site 3 DHW Comparison (Per Apartment Unit)

Tool	Actual/ Recommended Capacity (Btuh)	Efficiency	Available Capacity (Btuh)	Actual/ Recommended Storge Tank Size (gal)	Stored Hot Water Capacity (Btuh)	Equivalent Peak Capacity (Btuh)	% Difference of Equivalent Peak Capacity (Btuh) to 75 th Percentile	% Difference of Equivalent Peak Capacity (Btuh) to 100 th percentile (Maximum DHW Load)
Available on Site	25,000	81.0%	20,250	12	5,077	23,327	1026%	160%
ASHRAE	7,115	81.0%	5,763	14	5,761	11,524	412%	18%
MFG Tool 1	7,813	96.0%	7,500	4	1,531	9,031	301%	-7%
MFG Tool 2	12,438	97.0%	12,064	6	2,551	14,615	550%	50%
MFG Tool 3	40,000	80.0%	32,000	6	2,296	34,296	1424%	252%
EHPWH Tool	4,394	100.0%	4,394	33	13,597	17,991	700%	85%

Site 3 Conclusions and comparisons

The onsite DHW system is oversized compared to the 75th and 100th percentile DHW demand. The onsite unit is 1,026% oversized compared to the 75th percentile and 160% oversized compared to the 100th percentile.

All manufacturer tools oversized compared to the 75th percentile, two tools oversized compared to the 100th percentile, and one tool under sized. MFG Tool 3 was oversized by 252% and MFG Tool 1 was oversized by 50% compared to the 100th percentile. However, MFG Tool 3 was undersized by 7%.

The recommended equivalent peak capacity using ASHRAE's methodology was oversized by 412% compared to the 75th percentile by and was oversized by 18% compared to the 100th percentile. The EHPWH Tool recommended a DHW system that was oversized by 700% compared to the 75th percentile and by 85% compared to the 100th percentile.

The manufacturer tools recommend the smallest storage tank volume, followed by ASHRAE, followed by the EHPWH Tool.

ASHRAE is the closest to the actual 100th percentile without under sizing.

Site 4

Figure 31 illustrates the DHW capacity estimated by each sizing method in comparison to the DHW loads recorded in Site 4's gas bills during the peak winter season. Table 26 shows the sizing tool outputs, equivalent peak capacity, and comparison of outputs to actual DHW loads. The inputs utilized for each of the sizing tools to recommend DHW units for site 4 are in Table 20. For EHPWH Tool and manufacturer tool recommendations specific to Site 3 refer to Appendix 2.




Figure 31: Site 4 DHW Comparison (Per Apartment Unit)

Tool	Actual/ Recommended Capacity (Btuh)	Efficiency	Available Capacity (Btuh)	Actual/ Recommended Storge Tank Size (gal)	Stored Hot Water Capacity (Btuh)	Equivalent Peak Capacity (Btuh)	% Difference of Equivalent Peak Capacity (Btuh) to 75 th Percentile	% Difference of Equivalent Peak Capacity (Btuh) to 100 th percentile (Maximum DHW Load)
Available on Site	8,065	84%	6,774	2	811	7,585	238%	17%
ASHRAE	7,351	84%	6,175	14	6,173	12,347	451%	90%
MFG Tool 1	6,450	85%	5,483	1	564	6,047	170%	-7%
MFG Tool 2	8,063	95%	7,660	2	839	8,499	279%	31%
MFG Tool 3	12,871	95%	12,227	3	1,411	13,638	508%	110%
EHPWH Tool	2,466	100%	2,466	17	7,498	9,964	344%	53%

Table 26: Site 4 DHW Comparison (Per Apartment Unit)

Site 4 Conclusions and comparisons

At Site 4 the onsite DHW system was oversized compared to 75th and 100th percentile DHW demands. The onsite unit is 238% oversized compared to the 75th percentile, but it was only 17% oversized compared to the 100th percentile. At all other sites, the onsite system is at least 52% oversized (Site 1).

The manufacturer tools recommended units that were oversized compared to the 75th percentile, but only MFG Tool 2 and MFG Tool 3 were oversized compared to the 100th percentile. MFG Tool 2 was oversized by 31% and MFG Tool 3 was oversized by 110% compared to the 100th percentile. MFG Tool 1 was undersized by 36% compared to the 100th percentile.

The recommended equivalent peak capacity using the ASHRAE method was oversized by 451% compared to the 75th percentile and by 90% compared to the 100th percentile. The EHPWH Tool recommended a DHW system that was oversized by 53% compared to the absolute maximum load but was oversized by 344% compared to the 75th percentile.

The manufacturer tools recommend the smallest storage tank volume, followed by ASHRAE, followed by the EHPWH Tool.

At site 4, the onsite unit was the closest to the 100th percentile without under sizing (17% oversized) and MFG 2 was the next closest at 31% oversized. ASHRAE might over predict the maximum DHW load at this site because 2.6 people per apartment was used for all sites, but all the apartments in site 4 are studios so a better approximation of people per unit would be 1.5. Since ASHRAE was predicting the demand for more people, it makes sense that it overshot the 100th percentile prediction more than in other sites.

Site 5

Figure 32 illustrates the DHW capacity estimated by each sizing method in comparison to the DHW loads recorded in Site 1's gas bills during the peak winter season. Table 27 shows the sizing tool outputs, equivalent peak capacity, and comparison of outputs to actual DHW loads.




Figure 32: Site 5 DHW Comparison (Per Apartment Unit)

Tool	Actual/ Recommended Capacity (Btuh)	Efficiency	Available Capacity (Btuh)	Actual/ Recommended Storge Tank Size (gal)	Stored Hot Water Capacity (Btuh)	Equivalent Peak Capacity (Btuh)	% Difference of Equivalent Peak Capacity (Btuh) to 75 th Percentile	% Difference of Equivalent Peak Capacity (Btuh) to 100 th percentile (Maximum DHW Load)
Available on Site	16,286	82%	13,354	16	6,188	19,542	474%	91%
ASHRAE	6,526	82%	5,351	14	5,350	10,701	214%	5%
MFG Tool 1	8,161	85%	6,937	2	619	7,556	122%	-26%
MFG Tool 2	12,245	96%	11,755	5	1,841	13,596	299%	33%
MFG Tool 3	29,184	80%	23,347	4	1,392	24,739	627%	142%
EHPWH Tool	4,243	100%	4,243	35	13,119	17,361	474%	91%

Table 27: Site 5 DHW Comparison (Per Apartment Unit)

Site 5 Conclusions and comparisons

The onsite unit at Site 5 is oversized compared to the 75th percentile and 100th percentile demand. It is 474% oversized compared to the 75th percentile and 91% oversized compared to the 100th percentile.

The manufacturer tools recommended units that were oversized compared to the 75th percentile, but only MFG Tool 2 and MFG Tool 3 were oversized compared to the 100th percentile. MFG Tool 2 was oversized by 33% and MFG Tool 3 was oversized by 142% compared to the 100th percentile. MFG Tool 1 was undersized by 26% compared to the 100th percentile.

The recommended equivalent peak capacity using the ASHRAE method was oversized by 214 % compared to the 75th percentile and by only 5% compared to the 100th percentile. The EHPWH Tool recommended an equivalent peak capacity that was oversized by 410% compared to the 75th percentile and by 70% compared to the 100th percentile.

The manufacturer tools recommend the smallest storage tank volume, followed by ASHRAE, followed by the EHPWH Tool.

At Site 5, the ASHRAE method recommended an equivalent peak capacity that was the closest to the 100th percentile without under sizing.

Site 6

Figure 33 illustrates the DHW capacity estimated by each sizing method in comparison to the DHW loads recorded in Site 6's gas bills during the peak winter season. Table 28 shows the sizing tool outputs, equivalent peak capacity, and comparison of outputs to actual DHW loads.




Figure 33: Site 6 DHW Comparison (Per Apartment Unit)

Tool	Actual/ Recommended Capacity (Btuh)	Efficiency	Available Capacity (Btuh)	Actual/ Recommended Storge Tank Size (gal)	Stored Hot Water Capacity (Btuh)	Equivalent Peak Capacity (Btuh)	% Difference of Equivalent Peak Capacity (Btuh) to 75 th Percentile	% Difference of Equivalent Peak Capacity (Btuh) to 100 th percentile (Maximum DHW Load)
Available on Site	18,584	81%	15,053	8	2,956	18,009	336%	87%
ASHRAE	6,426	82%	5,269	14	5,269	10,538	155%	9%
MFG Tool 1	3,950	97%	3,820	1	296	4,116	0%	-57%
MFG Tool 2	5,941	96%	5,703	2	879	6,582	59%	-32%
MFG Tool 3	14,158	80%	11,327	2	665	11,992	190%	24%
EHPWH Tool	2,685	100%	2,685	22	8,243	10,928	165%	13%

Table 28: Site 6 DHW Comparison (Per Apartment Unit)

Site 6 Conclusions and comparisons

At Site 6 onsite unit is oversized compared to the 75th and 100th percentile DHW demand. The onsite unit is 336% oversized compared to the 75th percentile and 87% oversized compared to the 100th percentile.

At Site 6, two manufacturer tools oversized compared to the 75th percentile and only one oversized compared to the 100th percentile. MFG Tool 3 oversized by 24% compared to the 100th percentile while MFG Tool 1 undersized by 57% and MFG Tool 2 undersized by 32%. This is the only site where MFG Tool 2 undersizes compared to the 100th percentile.

The recommended equivalent peak capacity using the ASHRAE method was oversized by 336% compared to the 75th percentile and by only 9% compared to the 100th percentile. The EHPWH Tool recommended an equivalent peak capacity that was oversized by 190% compared to the 75th percentile and by only 13% compared to the 100th percentile.

The manufacturer tools recommend the smallest storage tank volume, followed by ASHRAE, followed by the EHPWH Tool.

At Site 6, the ASHRAE method recommended an equivalent peak capacity that was the closest to the 100th percentile without under sizing followed closely by the EHPWH Tool.

Summary & Findings

In this section, the Study Team compared sizing recommendations from various tools with the site data. Below is the summary and important findings from this analysis. Table 29 shows a comparison of the over/under sizing for all of the tools at all of the sites. The bolded value in Table 29 indicates which tool (not including what was available on site) was the closest to the actual 100th percentile without under sizing.

Site	%Difference: Available on site	%Difference: ASHRAE	%Difference: MFG Tool 1	%Difference: MFG Tool 2	%Difference: MFG Tool 3	%Difference: EHPWH Tool
Site 1	52%	-5%	-63%	-36%	17%	48%
Site 2	81%	31%	1%	9%	80%	26%
Site 3	160%	18%	-7%	50%	252%	85%
Site 4	17%	90%	-7%	31%	110%	53%
Site 5	91%	5%	-26%	33%	142%	91%
Site 6	87%	9%	-57%	-32%	24%	13%

Table 29: Percent Difference: 100th percentile vs Sizing Tools

- In the section titled "Analysis of Methods" the manufacturer tools were presumed to use the ASHRAE methodology for estimating DHW loads. MFG Tool 1 was presumed to use a consumption profile similar to ASHRAE's "low," MFG Tool 2 was presumed to use a consumption profile in between ASHRAE's "Medium" and "High," and MFG Tool 3 was presumed to use a consumption profile greater than ASHRAE's "High." At all sites MFG Tool 1 had the lowest equivalent peak capacity followed by MFG Tool 2 and MFG Tool 3. MFG Tool 3 is the only one that recommended an equivalent peak capacity that always met the 100th percentile of DHW demand.
- The manufacturer tools recommend the smallest storage tank volume, followed by ASHRAE, followed by the EHPWH Tool. The manufacturer tools appear to make up for smaller storage tank volumes with higher capacities while the EHPWH Tool makes up for smaller capacities with larger storage tank volumes. ASHRAE's storage tank volumes and capacities fall in between the EHPWH Tool and the manufacturer tools.
- MFG Tool 1 recommends tools which are usually undersized. The study team believes this is because it is using estimates of hot water use similar to ASHRAE's low profile.
- MFG Tool 2 oversizes at four sites and undersizes at two sites compared to the 100th percentile.
- MFG Tool 3 overshoots the 100th percentile by a modest amount on sites #1 and #6 and by a lot on sites #2, #3, #4, and #5. Sites #3 and #5 (where MFG Tool 3 is oversized by 252% and 142%, respectively) are the only sites with 2-bathroom units. It appears that the number of bathrooms influences the sizing recommendations for MFG Tool 3 quite a lot. Sites #2 and #3 have been discussed earlier. The Study Team thinks that the reason MFG Tool 3 is oversizing by such a large margin (110%) at Site #4 is because that site only has studio apartments, and the tool is assuming a larger hot water usage per bathroom than it should for a studio.
- The equivalent peak capacity is oversized with respect to the 100th percentile at all sites. A like-for-like replacement would result in oversizing because a smaller DHW heater would suffice. The exception is Site #4 where the AOS is much closer to the maximum load.
- The 100th and 99th percentile can be as much as 47% different (at site #1).
- ASHRAE gets the closest to the actual 100th percentile on half of the sites and it is right more than the other tools. The Study Team doesn't know why ASHRAE under sizes with respect to the 100th percentile at Site #1. The Study Team thinks ASHRAE greatly oversizes at Site #4 and #5 (by 90% and 31%, respectively) because the calculations use 2.6 people per apartment which is probably too high for the studio apartments at Sites #4 and #5.
- Even though the EHPWH tool was set to use the ASHRAE Medium profile, it only matches the ASHRAE estimates well at Sites #2 and #6. At site #4 (all studios), the EHPWH tool used 1.37 people/studio apartment, and ASHRAE used 2.6

people/apartment. Since 1.37 is less than 2.6, that explains why the EHPWH peak load is less than ASHRAE. At Site #5, the EHPWH tool uses a weighted average of 2.67 people/apartment, so it is unclear why it is so much higher than ASHRAE. Similarly, at Site #1 and #3 the EHPWH uses 2.57 people/2-bedroom apartment, so it is unclear why it predicts higher peak load than ASHRAE.

 The EHPWH tool overshoots the 100th percentile all of the time, but it gets closer to the actual peak load on Sites #2 and #6.

Overall, the DHW tools are very inconsistent in predicting the peak DHW loads. ASHRAE seems to be the most consistent of all the methods considered.

Site Screening, Sizing, and Design Criteria for GAHPs

GAHP Background

The Gas Absorption Heat Pump (GAHP) units perform best when supporting systems requiring continuous heating loads, making them ideal for replacing DHW systems typically served by conventional boilers [12]. GAHPs can be more affordable, reliable, and sustainable than DHW systems with only conventional boilers if installed at sites that meet the sizing and design criteria [12]. GAHPs are preferred to be used in hybrid configurations with traditional gas boilers. In this setup, GAHPs are sized to meet the base hot water load, while the auxiliary boilers provide auxiliary heating to meet the load during periods of high demand. GAHPs are manufactured by a handful of manufacturers, but this study evaluated two systems; GAHP 1, which has a rated fixed capacity of 123,500 Btuh, and GAHP 2 which has a rated variable capacity of up to 78,000 Btuh. Manufacturer/model names are removed to anonymize the report.

Site Screening Criteria

To assess whether a site is a suitable candidate for replacing its conventional boiler DHW system with a preheat GAHP and auxiliary boiler system, the following screening criteria must be considered:

- System design
- GAHP capacity and minimum flowrate
- Temperature limitations
- GAHP run time and cycle time requirements
- Indirect storage tank and buffer tank volume (if applicable)

Each of these criteria is further detailed in the sections below.

System Design

This part of the study considers a hybrid configuration combining a preheat GAHP with a traditional gas boiler DHW system. Successful integration of these systems involves several key factors. Figure 34 and

Figure 35 illustrate two different configurations. A preheat GAHP and auxiliary boiler system often requires an Indirect Storage Tank (IST). Some specific manufacturer units also require an additional buffer tank in addition to existing storage water tanks.

Based on discussions with the manufacturers of the GAHP units and web research, the following key factors must be considered for the system feasibility. First, adequate outdoor

space is required for the GAHP unit, with the GAHP 1 unit requiring a minimum footprint of 5'10" by 9', and the GAHP 2 unit requiring 4' by 2.8'. Shared clearances can reduce space needs when installing multiple units. The installation area must be well-ventilated to ensure proper exhaust and to prevent evaporator coil air recirculation. Ground-level installations are preferred for ease of installation, although rooftop installations are possible, often resulting in higher project costs. GAHPs typically produce more noise than traditional boilers, so it is important to comply with applicable local municipal noise ordinances to ensure successful installation and community acceptance [12].

In the mechanical room, space is needed for a heat exchanger (or Indirect Storage Tank) and, for GAHP 1, a buffer tank to integrate the system with existing infrastructure. GAHP units should ideally be located within 20 feet of electrical and plumbing connections to minimize costs. Additionally, the building's occupancy should be considered; one manufacturer recommends a minimum of 30 to 50 apartments to ensure a sufficient DHW load. However, additional research conducted by the study team indicates that more than 50 units may be necessary.




Figure 34: Preheat configuration of GAHP and boiler system: GAHP 1




Figure 35: Preheat configuration of GAHP and boiler system: GAHP 2

GAHP Capacity and Minimum Flowrate

Minimum DHW Loads

The comparison of DHW sizing tools to actual site data showed that traditional sizing tools are aiming for the 100th percentile. This is because their systems have to meet the maximum DHW load without running out of hot water. The GAHP, on the other hand, does not need to meet the maximum 100th percentile load because it usually operates with a boiler that can meet that load. However, the GAHP is most efficient when it is running for long periods and its efficiency will degrade if run time is too low. The run time of a GAHP unit is dependent upon the minimum DHW load. That minimum DHW load takes place in the summer night-time or early morning hours. This is a new way of thinking about sizing DHW systems, so there is no DHW tool that can predict this.

If the DHW load is less than the GAHP capacity, the GAHP may not run continuously. This is shown using data from Site #1 in Figure 36 and Site #5 in Figure 37. At Site #1, the red line for the GAHP capacity is above the summer minimum DHW load, but it falls below the average hourly load (the green line) most hours of the day. So, although it is more than the summer minimum, a GAHP might be a good candidate for Site #1. However, at Site #5, the GAHP capacity is more than the summer minimum and it is less than the average hourly load most hours of the day. This means it will rarely run a full hour and will probably run 30-45 minutes on average because the summer minimum is about half of the GAHP capacity. GAHP from manufacturer #1 would not be a good candidate for Site #5.




Figure 36: Comparison of GAHP Capacity and Site #1 Summer DHW Loads




Figure 37: Comparison of GAHP Capacity and Site #5 Summer DHW Loads

Since there is no tool that can predict summer minimum DHW load at the time of this writing, the best practice is to measure the DHW load. This can be done using a combination of an ultrasonic flow meter and clamp-on temperature probes. The Study Team is testing out this method of determining summer minimum load on upcoming Gas Emerging Technology field studies for GAHP products. Ultrasonic metering is being used to screen sites before a project is initiated. There are many outstanding questions using this method that will be answered as field studies progress. These questions include:

- How many days is sufficient to accurately predict the summer minimum load?
- How can the summer minimum load be predicted if the ultrasonic measurement was done during fall, winter, or spring?
- Do both the recirculation load and make up water need to be measured to pick a suitable site for a GAHP?
- How much time does it take to install and uninstall the ultrasonic meter and analyze the data?
- How much does an ultrasonic meter cost?
- Will contractors be willing to purchase an ultrasonic meter to screen sites for GAHP installation?
- Can a sizing tool be created that predicts the summer minimum load?

The Study Team is working to answer these questions in future GAHP field work through the GET program.

Minimum Flowrate Calculation

It is recommended that each site has an average hot water demand that matches or exceeds the capacity of the GAHP system being considered. Discussions with GAHP manufacturers have highlighted the importance of accounting for the minimum flow rate for each GAHP unit to assess its viability for replacing traditional DHW systems or acting as a preheater. The following equation 6 is used to calculate the minimum flow rate based on the rated capacity of the GAHP unit and the difference between the incoming and exiting water temperature:

Equation 6: Minimum Flow Rate

$$Min \ Flow \ Rate \ \left[\frac{Gal}{hr}\right] = \frac{GAHP \ Capacity \left[\frac{Btu}{hr}\right]}{\rho\left[\frac{lbm}{gal}\right]c_p\left[\frac{Btu}{lbm^{-\circ}F}\right]\Delta T \ [^{\circ}F]}$$
(6)

where,

 $GAHP \ Capacity =$ Rated Capacity of the GAHP Unit $\left[\frac{Btu}{hr}\right]$: 123,500 Btuh for GAHP and 78,000 Btuh for GAHP 2 $\rho = \text{density} \left[\frac{lbm}{gal}\right]$: 8.33

$$c_p = \text{Specific heat } \left[\frac{Btu}{lbm - ^\circ F}\right]: 1$$

 $\Delta T = T_{delivery} - T_{incoming} [^{\circ}F]$

The minimum flow rate allows for continuous operation of the unit. If the minimum flow rate were consistently maintained, the GAHP could function as a preheat unit without requiring additional IST. However, DHW demand varies, and during low demand periods, the flow rate may drop below the minimum required for continuous operation. These variations in flowrate can affect the unit's cycle and run times, potentially necessitating the use of an IST. The impact of GAHP run and cycle times on the required flow rate is explained in the following section.

GAHP run time and Cycle time requirements

GAHP units perform at optimal efficiency when supporting systems with continuous heating loads. However, since continuous load is uncommon in DHW systems, there must be a minimum load that allows the unit to cycle on and off without short cycling. Short cycling can reduce efficiency and strain the equipment.

Equation 7: Tank Volume

$$Tank Vol [Gal] = \frac{GAHP \ Capacity \ [Btuh] * GAHP \ run \ time \ [hr]}{\rho \left[\frac{lbm}{gal}\right] c_p \left[\frac{Btu}{c_{F-lbm}}\right] \Delta T \ [^{\circ}F]}$$
(7)

Where

 $\begin{array}{l} GAHP\ Capacity = {\rm Rated\ Capacity\ of\ the\ GAHP\ Unit\ \left[\frac{Btu}{hr}\right]}: 123,500\ {\rm Btuh\ for\ GAHP\ 1\ and\ 78,000}\\ {\rm Btuh\ for\ GAHP\ 2}\\ \rho = {\rm density\ \left[\frac{lbm}{gal}\right]}: 8.33\\ c_p = {\rm Specific\ heat\ \left[\frac{Btu}{lbm^{-\circ}{\rm F}}\right]}: 1\\ \Delta T = T_{delivery}\ -\ T_{incoming\ }\ [^{\circ}{\rm F}]\\ GAHP\ run\ time\ [min]:\ {\rm Site\ specific\ optimal\ time\ for\ GAHP\ unit} \end{array}$

The cycle time as defined by equation 8, is the sum of GAHP run time, and the time required to fill the IST.

Equation 8: Tank Charge Time

$$Tank charge time [min] = Cycle Time [min] - GAHP run time [min]$$
(8)

where,

Tank charge Time [min]: Site specific time required to fill indirect storage tank (if needed)

Cycle Time [min]: Site specific optimal cycle time determined by minimum desired cycles per day.

According to discussions with the GAHP manufacturers, each unit has a minimum run time and a specified maximum number of cycles per day to optimize its performance. Representatives for the GAHP 1 unit indicated that it does not reach a steady-state Coefficient of Performance (COP) until it has been running for at least 10 minutes. However, the minimum run time in Equation 7 and 8 will vary depending on the targeted average GAHP COP, which considers the COP during the startup phase before the unit reaches steady state. There is not currently enough data to provide the GAHP COP as a function of the GAHP run time. The Study Team recommends research be put out to provide this data for IST sizing.

Before sizing a unit, every user must determine the number of cycles per day and run time required to reach the breakeven point. Theoretically, the GAHP could run for 2 hours if the IST were sized for that, but if the minimum flow rate was low enough, it might only run 2 hours/day and take the other 22 hours to fill the tank. In other words, the GAHP run time would be 2 hours but the tank fill time would be be 22 hours making the cycle time 24 hours

(1 cycle per day). The ideal GAHP run time and number of cycles per day will vary by site, based on the GAHP installation cost, natural gas prices, and if there are any CO₂ emissions reduction goals. There is currently no tool to take these considerations as inputs and give recommendations for GAHP run times and number of cycles per day. Therefore, it is recommended to develop a tool that incorporates these variables to recommend GAHP run times, number of cycles per day and calculate system payback period and other benefits.

Example Cycle Time and Cycles/Day Calculation

M&V data from Site 1⁴ from the above section was used to calculate the minimum GAHP run time. The GAHP run time is determined when the targeted weighted average GAHP COP is the same as a condensing boiler. At Site 1, it takes approximately 45 minutes for the GAHP's weighted average efficiency to reach 94%, which is the minimum efficiency for an Energy Star[®] condensing boiler [13].

The number of cycles per day for a GAHP system is influenced by the customer's specific needs. For this example, it is assumed that the GAHP would need to run a maximum of 12 cycles per day to be a cost-effective investment. Equation 9 and 10 calculates the minimum flow rate of incoming city water needed to determine if the site is a candidate for a preheat configuration of GAHP and an auxiliary boiler system.

Equation 9: Minimum Flow Rate

$$Min \ Flow \ Rate \ \left[\frac{gal}{min}\right] = \frac{Tank \ vol \ [gal]}{Tank \ charge \ time \ [min]} \tag{9}$$

Equation 10: Min Flowrate for 12 cycles per day

$$Min \ Flow \ Rate \ for \ 12 \ cycles \ per \ day \left[\frac{gal}{min}\right] = \frac{GAHP \ Capacity \ [Btuh]*GAHP \ Run \ Time \ [hr]}{\rho\left[\frac{lbm}{gal}\right]c_p\left[\frac{Btu}{\circ F-lbm}\right]\Delta T \ [\circ F]} (Tank \ Charge \ Time \ [min]} (10)$$

Where *GAHP run time* [*min*] = 45 *min Cycle Time for* 12 *cycles per day* [*min*] = 120 *min*

$$GAHP \ Capacity = \text{Rated Capacity of the GAHP1 Unit } \left[\frac{Btu}{hr}\right] : 123,500 \text{ Btuh}$$

$$\rho = \text{density } \left[\frac{lbm}{gal}\right] : 8.33$$

$$c_p = \text{Specific heat } \left[\frac{Btu}{lbm^{-\circ}F}\right] : 1$$

⁴ This data comes from GAHP Field Site #1

$\Delta T = T_{delivery} - T_{incoming} [^{\circ}F] = 120 - 65 = 55$

The minimum flowrate calculated is 2.68 gal/min or 3,866 gal/ day to ensure the GAHP would be able to run for 45 minutes per cycle with 12 cycles per day. In the case of other sites, the calculated minimum flow rate should be feasible for it to be a viable candidate for GAHP installation.

Indirect Storage Tank

Figure 38 and Figure 39 illustrate that to replace traditional DHW systems with a preheat GAHP and auxiliary boiler, it is advisable to include an Indirect Storage Tank (IST). Additionally, for GAHP 1, a buffer tank is also recommended. The IST tank functions as a thermal storage, which allows the tank to discharge hot water when the GAHP unit is not in operation, ensuring steady flow and efficient operation. Figure 38 below shows a screenshot from one manufacturer of ISTs and includes the high output heat exchanger near the bottom of the tank [14].



Figure 38: Commercial Indirect Storage Tank with Heat Exchanger [14]

Indirect Storage Tank Stratification

The ISTs considered in this study would likely be "stratified", similar to those used in solar thermal DHW systems. Stratification refers to the layering effect within the IST, where hot, less dense water accumulates at the top, while colder, denser water settles at the bottom. Figure 39 shows a fully stratified storage tank, with red symbolizing hot water and blue symbolizing cold water [15].

Figure 39 Stratified Solar Thermal Storage Tank [15]



Tank stratification is advantageous for preheat GAHP systems. In a stratified tank, the hottest water resides at the top, allowing it to be delivered to the existing storage tanks. Meanwhile, the GAHP heat exchange coils can be positioned at the bottom, where the cooler water is located, ensuring that the coldest water is heated by the GAHP.

See Figure 40 for the visual representation:

- #4 indicates the hottest water being delivered to the storage tank.
- #3 indicates the water exiting the GAHP at the maximum output temperature.
- #2 shows the water entering the GAHP.
- #1 is the incoming city water.

By placing the heat exchange coils at the bottom of the IST, the temperature of the water entering the GAHP is lowered, which enhances the GAHP's COP and run time. Both of these factors contribute to optimized performance and improved overall system efficiency.




Figure 40: Preheat GAHP 2 and stratified IST with Heat Exchanger

As seen in Figure 40 above, the water/glycol temperature entering the GAHP unit (#2) should not exceed 140°F to prevent the unit from cycling off. It may be necessary to use inlet temperature control, such as a variable frequency drive (VFD) on a recirculation pump or a flow control valve, to allow flow control and thereby regulate/lower the inlet temperatures of the GAHP unit. This is applicable when the recirculation water is mixing with the makeup city water as seen in Figure 41, where #5 is the recirculation line mixing with the city make-up water. During periods of minimal DHW usage, such as at night when there is little to no cold city make-up water, the inlet temperatures to the GAHP unit can rise above the unit's operational limit. This causes the GAHP unit to shut down, requiring the hot water load to be fully handled by existing auxiliary boiler. The water/glycol temperature exiting the GAHP 1 unit, flow line 3 in Figure 42, typically ranges between 130°F and 140°F. Based on typical heat exchanger characteristics, this temperature range translates to a maximum DHW delivery temperature of 120°F to 130°F. To meet peak loads, an auxiliary boiler may be required as shown in

Figure 35.




Figure 41: Preheat GAHP 2 and stratified IST with Recirculation Line

Temperature Limitations

GAHP units tend to have specific temperature requirements that should be met prior to replacing traditional DHW systems with a preheat GAHP and auxiliary boiler system. It is recommended that the controls be configured so that the storage tank can cycle between the GAHP maximum output temperature and the incoming city water temperature, providing sufficient thermal inertia in the IST for the GAHP unit to run efficiently. The temperature difference between incoming city water and maximum GAHP output temperature may range from 50°F to 70°F. This delta allows cold water to accumulate in the IST, enabling the GAHP unit to operate longer. However, the temperature delta is site–specific because incoming city water temperature depends on the site climate zone and the maximum GAHP output temperature depends on the specific GAHP unit. The temperature delta is also season–specific because the incoming city water temperature also depends on the season.

The GAHP 1 unit has an assumed maximum GAHP output temperature of 122°F when connected to an IST. The unit shuts off when the temperature of the return flow going into the GAHP 1 unit from the IST reaches 122°F. The maximum output temperature of GAHP 1 is closer to 140°F, but as the IST heats up to 122°F, the return temperature to GAHP 1 will trend

toward 122°F and shut the unit off. In contrast, the GAHP 2 unit has a maximum GAHP output temperature range of 130°F to 140°F.




Figure 42: Preheat GAHP 1 and Stratified IST with Heat Exchanger

IST Temperature Sensor Placement

The study team also considered the placement of temperature sensors in the IST during the design and installation phases of the GAHP systems to ensure optimal performance. Proper sensor placement allows the GAHP to respond efficiently. The GAHP 2 controls use an Aquastat, a controller that turns the GAHP off or on to maintain temperature control. This means that when the temperature sensor reads 140°F, the system will turn off. Based on conversations with the manufacturer, the system will not turn back on until the temperature drops to 125°F, as there is a 15°F default deadband.

Figure 43 depicts the GAHP, IST, and possible temperature sensor placements. In

Figure 43, the sensor's location within the IST will affect the GAHP run time and there are pros and cons for each. If the Sensor is placed at top point T1, the system can respond quickly when the water reaches the desired temperature, preventing overheating. However, it might shut off too soon, leaving the lower parts of the tank cooler, leading to uneven heating and frequent on-off cycling. If the sensor is placed at mid-point T2, it may accurately reflect the overall temperature of the tank and reduce the chances of frequent

cycling. However, the sensor might not detect when the top of the tank is fully heated, leading to a delayed shutdown of the heating system, which could slightly overheat the top layer. Finally, if the sensor is placed at low point T3, it can ensure that the entire tank reaches the desired temperature before the system shuts off, providing more consistent hot water availability. However, it might take longer to turn off, leading to potential overheating at the top and slower system response, which could waste energy. The location of the temperature sensor may impact system performance and efficiency and needs to be studied with further testing.

In Figure 42, the sensor placement is less critical since the temperature entering GAHP 1 unit(#2) is assumed to match the temperature exiting the IST (#5). Note that #5 could be higher than #2, but the Study Team has no data to determine how much higher it could be because there is no field data to show GAHP performance with an IST.




Figure 43: GAHP 2 and Indirect Storage Tank diagram

IST and Buffer Tank Volume

According to discussions with one manufacturer, the size of the IST is determined by the GAHP manufacturing team and sold in conjunction with the GAHP unit. However, with other GAHP manufacturers, the responsibility for determining the size of the IST is left to the customer or contractor at the installation site. One manufacturer of ISTs suggested a sizing methodology based not on formulas, but rather on the first-hour rating and gallons per minute (GPM) of the system [14]. Since the study team did not have access to first-hour ratings and accurate GPM data, they recommend an alternative approach for sizing the indirect storage tank, which considers the specific type of GAHP, as outlined in equation 7.

This study includes a very simplified calculation with the assumption that the temperature in the whole IST is the same. This is not often the case as discussed in an earlier section.

The thermal storage capacity of the indirect storage tank is determined by the temperature difference between the maximum GAHP outlet temperature, which varies by unit, and the incoming city water temperature, which is influenced by the local climate zone. **Error! Not a valid bookmark self-reference.**,

Figure 45, and Figure 46 illustrate how the volume of the indirect storage tank changes considering a 45-minute GAHP run time as the average incoming water temperature varies across different climate zones. The recommended tank volume is based on average temperatures, but an important consideration is that the GAHP run time will be shorter in the summer when the incoming water temperature is higher than average. Although these calculations use average water temperatures, it is important that the GAHP controls are not set to activate the unit only when the tank temperature equals the average city water temperature, as this would cause the unit to rarely operate in the summer. For example, if the average makeup temperature is 65°F, but the summer temperature rises to 70°F, the GAHP would never turn on.

Figure 44: GAHP 1 (max delivery temp of 120 F) Indirect Storage Tank volume vs Incoming temperature for a 45-minute GAHP run time




Figure 45: GAHP 2 (max delivery temp of 130F) Indirect Storage Tank volume vs Incoming temperature for a 45-minute GAHP run time





Figure 46: GAHP 2 (max delivery temp of 140F) Indirect Storage Tank volume vs Incoming temperature for a 45-minute GAHP run time



As shown in

Figure 35, the GAHP 1 unit requires a buffer tank, while the GAHP 2 does not. The purpose of a buffer tank is to provide thermal inertia, which stabilizes the system during periods of low demand. This helps to reduce the frequency of the heat generators, such as boilers or heat pumps, short cycling, which potentially improves the overall efficiency of the system. This helps maintain the desired temperature range and protects the system from potential damage caused by rapid temperature changes. Buffer tanks are a simple and cost-effective way to enhance the overall operating efficiency and lifespan of a heating system by reducing unnecessary equipment short cycling. The recommended volume for a buffer tank is determined using equation 11 below:

Equation 11: Buffer Tank Volume

$$Buffer Tank Vol [Gal] = \frac{GAHP Run Time [min]*(GAHP Capacity [Btuh] - Q_{min heat load} [Btuh])}{\Delta T [°F]*500^{5}} (11)$$

Where

 $\begin{array}{l} GAHP\ run\ time\ [min] = Site\ specific\ optimal\ time\ for\ GAHP\ unit\\ GAHP\ Capacity = {\sf Rated\ Capacity\ of\ the\ GAHP\ Unit\ \left[\frac{Btu}{hr}\right]}: 123,500\ {\sf Btuh\ for\ GAHP\ 1\ and\ 78,000}\\ {\sf Btuh\ for\ GAHP\ 2}\\ Q_{\min\ heat\ load} = Heat\ output\ to\ site\ specific\ minimum\ load\\ \Delta T = T_{delivery} -\ T_{incoming}\ [^{\circ}{\sf F}] \end{array}$

Similar to the IST, the size of a buffer tank depends on factors such as the type and size of the GAHP, the manufacturer, the site-specific temperature difference, and the heating load of the site. To determine if a site will be a good candidate for replacing the DHW system with a combined GAHP 1 and auxiliary boiler system, it is crucial to ensure that an appropriately sized buffer tank is available. The study team's recommendations are preliminary estimates, and further optimization, modeling, and fieldwork are necessary to accurately determine the appropriate tank types, size, temperature settings, and cycling frequency. These are important design considerations for sizing the combined GAHP and boiler DHW system, which currently has limited guidance.

⁵ A constant used for standard water properties where density 8.33 $\frac{lbm}{gal} * 60 \frac{gal}{min}$

Screening, Sizing, and Design Criteria for GAHPs Findings

The purpose of this part of the study was to provide recommendations for screening sites and assess viability for replacing the existing traditional gas boiler system with a GAHP preheater and auxiliary boiler system. The findings are summarized below:

- **Pre-Heat Configuration**: GAHP units are well-suited for pre-heat configuration with traditional gas boilers. In this setup, the GAHP handles the base hot water load, and the gas boilers provide supplemental heating to meet peak demand.
- Site Requirements: Sites for integrating GAHP units with traditional gas boiler DHW systems require sufficient outdoor space, proper ventilation, proximity to electrical and plumbing connections, noise mitigation, and ensuring an adequate flowrate to maintain efficient operation.
- Hot Water Demand: Each site must have sufficient hot water demand that allows for the minimum required flow rate for the GAHP system, which is calculated based on the unit's rated capacity and difference between the makeup city water and the GAHP exit temperature. Consistent flow rates are crucial for continuous operation, and variations can impact the GAHP's effectiveness and necessitate additional ISTs.
- Operational Efficiency: GAHP units perform optimally with continuous heating load. If continuous operation is not feasible, a minimum flow rate must be maintained to prevent short cycling. Each unit has a specific run time to reach optimal performance, so calculating minimum flow rates and cycle times is essential to determine a site's suitability for a hybrid GAHP system.
- Temperature Requirements: Optimal efficiency for GAHP units depends on specific temperature differentials across the unit. For example, the GAHP 1 unit supplies water at a maximum temperature of 120°F when it is connected to an IST, while the GAHP 2 unit can supply higher temperatures between 130–140°F when connected to ISTs. During periods of low demand or peak demand, auxiliary boilers may be used.
- Storage Tank Requirements: When replacing traditional DHW systems with a GAHP and boiler system, it is recommended to include an indirect storage tank, and for GAHP 1 systems, a buffer tank. The indirect storage tank helps maintain system efficiency by ensuring steady flow and sufficient run time for the GAHP. The buffer tank, required for the GAHP 1 but not GAHP 2, offers thermal inertia to stabilize the system during low demand, reduces equipment short cycling, and improves overall efficiency. The tank sizes are determined by the GAHP's capacity, run time, and temperature differentials.

When evaluating GAHP units, contractors often depend on external engineers or manufacturers for recommendations on domestic hot water heaters and boiler capacities and designs. For GAHPs to be effectively implemented and be successful as an energy efficiency measure in California, it is crucial for contractors to have guidelines for screening sites and sizing GAHP systems. This study addresses that need by leveraging existing DHW sizing research to provide recommendations for GAHP system design and site criteria. Current sizing tools are meant to size to the 100th percentile of DHW demand, so the Study Team suggests further research to investigate how to screen sites for summer minimum DHW loads, and how to calculate a return on investment for a GAHP unit when the summer minimum DHW load is not enough for the GAHP to run continuously.

Conclusions

This report examined the sizing methodologies and performance of DHW systems across multiple sites, revealing significant issues with DHW sizing in general and as it relates to GAHP site screening. The study gathered insights from SME interviews, sizing methodologies from ASHRAE, ASPE, and manufacturers in order to identify differences in system sizing. These sizing methods were then compared to actual site data. Finally, the report discusses the transition to EHPWH and GAHPs which introduced new challenges, and the findings underscored the need for refined sizing methodologies and screening tools for GAHPs that can calculate economic viability. The conclusions are outlined below:

- Inconsistencies in Sizing Methodologies and Oversizing:
 - Existing DHW systems across six sites were found to be oversized by 17% to 160% compared to the maximum DHW load (the 100th percentile of the hourly DHW load).
 - While ASHRAE, manufacturer tools, and an EHPWH tool provide valuable sizing outputs (heat rate and storage tank volume), their predictions of maximum DHW load is inconsistent. The tools examined in this study sized DHW systems anywhere from -57% (under sized) to 252% (oversized) of the actual maximum DHW load depending on the tool and site.
 - In most cases, DHW tools oversize with respect to the actual maximum DHW load
- Insights from Subject Matter Expert Interviews:
 - DHW Oversizing: Oversizing is a common issue, especially when replacing failed systems.
 - **Sizing Factor**: The number of occupants was consistently identified as the most important factor when sizing DHW systems.
 - Preferred Sizing Tools: ASHRAE's handbook remains the most preferred sizing tool, though newer tools like the EHPWH tool are valued for their use of updated, site-specific data.
 - Heat Rate: Heat rate (capacity) is the most crucial factor in equipment selection.
 - Brand Loyalty: Contractors tend to show brand loyalty when selecting DHW equipment, even if the right-size equipment is not available with the preferred brand.
- Variations in Manufacturer Tools:
 - Manufacturer tools often yielded different recommended sizes due to variations in the background assumptions.
 - The three manufacturer tools evaluated and the EHPWH are very inconsistent at predicting the peak loads. On the other hand, the ASHRAE method using the

medium consumption profile was usually the least oversized compared to the 100th percentile. The Study Team thinks this is because ASHRAE predicts the load using the number of people rather than the number of bathrooms or bedrooms.

- None of the existing DHW sizing methods are suitable for sizing GAHP systems because they cannot predict summer minimum loads.
- Methodological Similarities:
 - Manufacturer tools and ASHRAE/ASPE equations follow similar sizing methods, particularly for calculating heat output rates. However, manufacturer tools often recommend smaller storage tanks. The Study Team believes this is due to additional costs for tanks because of code requirements when they are more than 119 gallons.
- Sizing Challenges with Electric Heat Pumps:
 - As the industry transitions towards gas and electric HPWH systems, a knowledge/resource gap in proper sizing has emerged. These systems require different considerations than traditional gas systems, particularly regarding storage tank size and peak demand management.
 - GAHPs do not have the exact same sizing issues electric HPWHs, but they share some gaps in common like their smaller capacities and need for additional storage to maximize run time.
- Application of pre-heat GAHP and Auxiliary Boiler Systems:
 - Pre-Heat Configuration: GAHP units work effectively in a pre-heat configuration with auxiliary gas boilers. GAHP systems handle the base load, while auxiliary boilers manage peak demand during high-usage periods.
 - Site Requirements: Sites need adequate outdoor space, proper ventilation, access to electrical and plumbing connections, and minimal noise impact to support a GAHP-boiler hybrid system.
 - Operational Efficiency: GAHP systems perform best with continuous heating loads. Maintaining a minimum flow rate is crucial to prevent system short cycling and ensure operational efficiency.
 - Temperature and Storage Requirements: GAHP systems require specific temperature difference for optimal performance. An indirect storage tank is recommended to maintain steady flow, with a buffer tank necessary for certain GAHP models to prevent short cycling and improve efficiency.
- Recommendations for GAHP Implementation:
 - Contractors and site engineers often rely on external recommendations from manufacturers for final DHW system sizing and design.

- Contractors need clear guidelines for screening sites and properly sizing GAHP systems to ensure their successful adoption as an energy efficiency measure in California.
- Designers and installers implementing GAHPs should calculate the minimum flow rate. If the minimum flow rate is not enough to keep the GAHP running continuously, an IST should be used. The size of the IST depends on the desired GAHP COP which is influenced by the GAHP run time.
- There is currently not enough data to provide the GAHP COP as a function of the GAHP run time. This was identified as a research need.
- The GAHP run time, number of cycles per day, cost of natural gas and potential value of CO₂ emissions reductions all affect the viability of a GAHP project. There is currently no tool to take these things and provide recommendations on GAHP run time, number of cycles per day and calculate payback period and other nonenergy benefits. This was identified as a research need.
- There is currently no tool to predict summer minimum DHW load, the best way to get this is to measure the actual DHW load. This can be accomplished using an ultrasonic flow meter and a clamp on temperature probe. The Study Team is doing this in several upcoming field studies but does not have enough information to present conclusive recommendations at this time.
- GAHPs need a tool to predict the summer minimum load as a way of screening a site for a cost-effective installation. The gas bills provide a start, but the gas bills do not distinguish between how much is hot water use and how much is recirculation. To create a more useful screening tool, we need make-up water flow rates and delta T between incoming and supply water temperatures. A good site is one where the summer hot water use load is greater than the capacity of the GAHP being proposed.
- We recommend that data be gathered on the summer DHW use, exclusive of the recirculation loads. That data could be used to create a GAHP screening tool for contractors to use that would not require measurement at every site.
- Further Research Needed:
 - The study calls out the following additional research needs for GAHPs
 - Need for accurate predictions of summer minimum DHW loads. The Study Team is testing out the use of an ultrasonic flow meter combined with clampon temperature probes. The research questions that need to be answered using this method are the following:
 - How many days is sufficient to accurately predict the summer minimum load?
 - How can the summer minimum load be predicted if the ultrasonic measurement was done during fall, winter, or spring?

- Do both the recirculation and make up water need to be measured to pick a suitable site for a GAHP?
- How much time does it take to install and uninstall the ultrasonic meter and analyze the data?
- How much does an ultrasonic meter cost?
- Will contractors be willing to purchase an ultrasonic meter to screen sites for GAHP installation?
- Can a sizing tool be created that predicts the summer minimum load?
- **Need for GAHP COP as a function of run time.** The Study Team along with other GET researchers are gathering data which can be used to generate this.
- **Need for GAHP Screening Tool.** There is a need for a tool where the GAHP run time, number of cycles per day, cost of natural gas, cost of the GAHP retrofit, and CO2 emissions benefits are all taken into consideration with outputs that tell a customer if the GAHP project will be economically viable.

References

- [1] J. L. S. Max H. Sherman, "Proceedings of the ACEEE 1994 Summer Study on Energy Efficiency in Buildings," 1994.
- [2] U. Congress, *Energy Policy Act of 1992*, U.S. Government Publishing Office, 1992.
- [3] I. A. o. P. a. M. O. (IAPMO), "Study finds using IAPMO Water Demand Calculator can lead to energy, carbon, and water savings in single and multifamily residences.," [Online]. Available: https://www.phcppros.com/articles/17687-study-finds-usingiapmo-water-demand-calculator-can-lead-to-energy-carbon-and-water-savingsin-single-and-multifamily-residences.
- [4] I. R. P. H. Wojciech Rzeźnik, "Comparison of Real and Forecasted Domestic Hot Water Consumption and Demand for Heat Power in Multifamily Buildings, in Poland," *Energies*, vol. 15, no. 19, 2022.
- [5] Ammerican Society of Plumbing Engineers, Domestic Water Heating Design Manual, ASPE Press, 2020.
- [6] American Society of Heating, Refrigeration, and Air–Conditioning Engineers, ASHRAE Handbook – HVAC Applications, 2023.
- [7] International Association of Plumbing and Mechanical Officials, "2021 Uniform Plumbing Code," 2021. [Online].
- [8] C. E. Comission, "2019 Resident Appliance Saturation Study," 2019. [Online].
- [9] I. C. Council, "International Plumbing Code," ICC, 2021.
- [10] W. R. Foundation, "Residential End Uses of Water, version 2: Executive Report," Water Research Foundation, 2020.
- [11] C. E. D. a. R. System, *DEER Water Heater Calculator v5,* 2020.
- [12] CLEAResult, "Gas Absorption Heat Pumps Best Practices Guide," FORTISBC, 2023.
- [13] U. S. E. P. Agency, "Commercial Boilers: Optimize Efficiency with Condensing Boilers and Low Return Water Temps," 2020.
- [14] HTProducts, "Stainless Steel Indirects and Storage Tanks," [Online].
- [15] Lochinvar, "Stratified Solar Tank," Lochinvar, LLC, [Online]. Available: https://www.lochinvar.com/lit/TSU-01.pdf.
- [16] I. C. Council, "International Energy Conservation Code," ICC, 2021.
- [17] LAARS, "RightSpec Sizing Guide," LAARS, [Online]. Available: https://laarsrightpspec.com/Commercial/ApplicationData/Apartments.aspx. [Accessed October 2023].
- [18] Rheem, "RapidSpec," Rapid Spec, [Online]. Available: https://rapidspec.com/.

- [19] A. Smith, "Pro-size water heater sizing," A.O. Smith, [Online]. Available: http://www.hotwatersizing.com.
- [20] ANESI, "Gas Heat Pump ANESI HP80," January 2024. [Online]. Available: https://stonemountaintechnologies.com/wpcontent/uploads/2024/01/Anesi_80K_Datasheet_24-01_HP80.pdf?trk=public_post_commenttext#:~:text=Length%20in%2Fcm%2048%2F121.9,Width%20in%2Fcm%2034%2F86.4.
- [21] Frontier Energy, "Steam Table Technology Assessment and Gas Energy Savings Demonstration," Southern California Gas and San Diego Gas & Electric, 2020.
- [22] Robur, "GAHP Line A Series," June 2024. [Online]. Available: https://www.robur.com/hubfs/doc/ROBUR_GAHP-A_commercial-leaflet-jun24.pdf.
- [23] CEDARS, "California Energy Data and Reporting Systems," [Online]. Available: https://cedars.sound-data.com/deer-resources/tools/waterheaters/file/2919/download.. [Accessed April 2024].

Appendices

Appendix 1: Raw SME Responses:

SME 1

Here are some key components needed for the sizing of a water heating system. Are there				
any additional components? Please rank order the top five. Please explain your rankings.				

		LMH (Low,		
		Medium, High)	Rank	Explanation
Α	Number of occupants	L		
В	Number of apartments	Н	4	usage
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	М		
D	Number of bathrooms	Н	2	peak load is in bathrooms
Е	Type of fixtures	Н	1	this is for gpm
F	Age of the plumbing fixtures	М		
				gpm (higher load), next
G	Number of washing machines	Н	3	biggest consumer
	Location of washing machines (in			
Н	apartments, shared)	L		
Ι	Time of day the peak uses occur	М		
				total demand for how
J	Duration of the peak periods	Н	5	much to generate
Κ	Gallons per person per day	М		
	Type of temperature			
	maintenance system (do you			
L	prefer circulation, heat trace, etc.)	Н		temp and movement
				find out what is a dead
	If circulation, the method of			leg, how many branches.
Μ	balancing the riser	Н		Method is not important
Ν	Hot water piping material	L		
0	Length of the hot water piping	М		
	Diameter and volume of the hot			
Ρ	water distribution network	М		
	Configuration of the hot water			discovery of dead points
Q	distribution network	Н		in system
R	Insulation on the hot water piping	М		
	Effectiveness of the pipe			
S	insulation installation	М		
	Additional components			
	Additional components			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
		LMH (Low,			
		Medium, High)	Rank	Explanation	
А	ASHRAE	Н	3		
В	ASPE	Н	2		
С	IPC	Н	4		
D	IAPMO/ UPC (Uniform Plumbing	Н	1		
	Code)				
Е	Manufacturer's method	L			
F	EHPWH Tool	L			
G	Measured data from the site or	м			
G	from a similar occupancy	141			
	Other method				
	Other method				

	e are some features that may be used to se			
fea	tures that are important. Please rank order th		e explain y	our rankings.
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Water heater efficiency	M		
В	Cost	М		
	Location where the water heater will be			
С	installed	L		
D	Incoming cold water temperature	М		
Е	Hot water temperature	Н	2	
F	Master mixing valve temperature	Н	1	
G	First hour rating	L		
Н	Recovery efficiency	М		
Ι	Heat rate	Н	4	
	Location where the storage tank(s) will be			
J	installed	М		
	Volume of storage (one large tank or a			
К	number of smaller ones. ASME tanks?)	Н	3	
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	Н	5	
М	Heat losses of the circulation loop	М		
Ν	Brand	М		
	Is water heater sizing adjusted based on			
	the presence of preheat sources (Solar,			
0	etc.	М		
	Other features			
	Other features			

Here are some ways to account for future increases in demand when selecting a water heater. Are there any others that you use? Please rank order the top five. Please explain your rankings.

	<u> </u>	LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	Н	1	
	Provide space for additional storage			
В	tanks	М		
	Install larger storage as part of initial			
С	design	М		
	Install additional storage tanks as			
D	part of initial design	М		
	Install heater with larger heating			
Е	capacity as part of initial design	Н	2	
	Provide additional capacity in the			
F	gas line or in the electrical panel	Н	3	
	Others			
	Others			

SME 2

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

	KIIIgs.	LMH (Low,		
		Medium, High)	Rank	Explanation
А	Number of occupants	Н	2	
В	Number of apartments	Н	5	
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	М		
D	Number of bathrooms	М		
Е	Type of fixtures	М		
F	Age of the plumbing fixtures	М		
G	Number of washing machines	М		
	Location of washing machines (in			
Н	apartments, shared)	L		
	Time of day the peak uses occur	Н	3	
J	Duration of the peak periods	Н	4	
Κ	Gallons per person per day	Н	1	
	Type of temperature maintenance			
	system (do you prefer circulation, heat			
L	trace, etc.)	М		
	If circulation, the method of balancing			
М	the riser	Н		
Ν	Hot water piping material	L		
0	Length of the hot water piping	М		
	Diameter and volume of the hot water			
Ρ	distribution network	М		
	Configuration of the hot water			
Q	distribution network	М		
R	Insulation on the hot water piping	М		
	Effectiveness of the pipe insulation			
S	installation	М		
	Additional components			
	Additional components			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
103		LMH (Low,			
		Medium, High)	Rank	Explanation	
А	ASHRAE	Н	2	great for multifamily loads	
В	ASPE	Н	4	pipe sizing is crucial peak flow sizing	
С	IPC	L			
D	IAPMO/ UPC (Uniform Plumbing Code)	L			
Е	Manufacturer's method	L			
F	EHPWH Tool	Н	1	updated/efficient, custom loads from ASHRAE	
G	Measured data from the site or				
G	from a similar occupancy	Н	3	good for retrofit sizing	
	Other method				
	Other method				

	re are some features that may be used			-
tea	tures that are important. Please rank or	LMH (Low,	lease e	xpiain your rankings.
		Medium, High)	Rank	Explanation
А	Water heater efficiency	H		
В	Cost	Н	4	
	Location where the water heater will			
С	be installed	н	3	
D	Incoming cold water temperature	L		
Е	Hot water temperature	М		
F	Master mixing valve temperature	Н	5	
				primary plant,
G	First hour rating	н	1	capacity question,
н	First hour rating Recovery efficiency	H H	2	primary criteria
	Heat rate	M	2	
1	Location where the storage tank(s)	1*1		
J	will be installed	н		
•	Volume of storage (one large tank or			getting into the door
	a number of smaller ones. ASME			(sizing
К	tanks?)	М		consideration)
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	М		
М	Heat losses of the circulation loop	Н		
Ν	Brand	L		
	Is water heater sizing adjusted based			
	on the presence of preheat sources			
0	(Solar, etc.)	L		
	Experience with a product	М		
	other features			

Here are some ways to account for future increases in demand when selecting a water heater. Are there any others that you use? Please rank order the top five. Please explain your rankings.

	<u> </u>	LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	Н	1	
	Provide space for additional storage			
В	tanks	М		
	Install larger storage as part of initial			
С	design	М		
	Install additional storage tanks as part			
D	of initial design	М		
	Install heater with larger heating			
Е	capacity as part of initial design	Н	2	
	Provide additional capacity in the gas			
F	line or in the electrical panel	Н	3	
	Others			
	Others			

SME 3

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

	ikings.	LMH (Low,		
		Medium, High)	Rank	Explanation
А	Number of occupants	н	1	gallons of usage can be calculated based on this (demand)
В	Number of apartments	H	3	demand
С	Demographics of the occupancy (senior, affordable, families, etc.)	L		size to current demographic, could be changed
D	Number of bathrooms	М		
Е	Type of fixtures	М		
F	Age of the plumbing fixtures	L		
G	Number of washing machines	М		
Н	Location of washing machines (in apartments, shared)	L		
	Time of day the peak uses occur	L		
J	Duration of the peak periods	н	2	How long water is being used is necessary for sizing
K	Gallons per person per day	M	2	
L	Type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	L		
М	If circulation, the method of balancing the riser	L		
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
Ρ	Diameter and volume of the hot water distribution network	L		
Q	Configuration of the hot water distribution network	L		
R	Insulation on the hot water piping	М		
S	Effectiveness of the pipe insulation installation	м		
	Additional components			
	Additional components			

Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	ASHRAE	Н	1	
В	ASPE	L		
С	IPC	Н	3	
	IAPMO/ UPC (Uniform Plumbing			
D	Code)	Н	4	
E	Manufacturer's method	Н	2	
F	EHPWH Tool	L		
G	Measured data from the site or			
G	from a similar occupancy	L		
	Other method			
	Other method			

He	Here are some features that may be used to select a water heater. Are there any other			
fea	atures that are important. Please rank o	order the top five.	Please e	xplain your rankings.
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Water heater efficiency	М		
В	Cost	Н	1	
	Location where the water heater will			
С	be installed	М		
D	Incoming cold water temperature	Н		
Е	Hot water temperature	L		
F	Master mixing valve temperature	М		
G	First hour rating	Н	2	
Н	Recovery efficiency	М		
Ι	Heat rate	Н	5	
	Location where the storage tank(s)			
J	will be installed	М		
	Volume of storage (one large tank or			
	a number of smaller ones. ASME			
Κ	tanks?)	М		
	Size of storage tanks (volume,			relate to water
L	dimensions, ASME tanks?)	Н	3	storage
М	Heat losses of the circulation loop	M		
				plumber preference,
Ν	Brand	Н	4	loyalty
	Is water heater sizing adjusted			
	based on the presence of preheat			
0	sources (Solar, etc.)	L		
	Experience with a product			
	other features			

Here are some ways to account for future increases in demand when selecting a water heater. Are there any others that you use? Please rank order the top five. Please explain your rankings.

, 0 01				
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	М		
	Provide space for additional			
В	storage tanks	L		
	Install larger storage as part of			
С	initial design	Н	2	
	Install additional storage tanks			
D	as part of initial design	Н	3	
	Install heater with larger			larger heating capacity
	heating capacity as part of			is necessary as you
Е	initial design	Н	1	scale up.
	Provide additional capacity in			
	the gas line or in the electrical			
F	panel	L		
	Others			
	Others			

SME 4

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

	kiiigs.	LMH (Low,		
		Medium, High)	Rank	Explanation
Α	Number of occupants	Н	3	
В	Number of apartments	Н	1	
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	М	5	
D	Number of bathrooms	М		
Е	Type of fixtures	L		
F	Age of the plumbing fixtures	L		
G	Number of washing machines	L		
	Location of washing machines (in			
Н	apartments, shared)	L		
I	Time of day the peak uses occur	М		
J	Duration of the peak periods	Н	4	
Κ	Gallons per person per day	М		
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	М		
	If circulation, the method of			
М	balancing the riser	L		
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
	Diameter and volume of the hot			
Ρ	water distribution network	М		
	Configuration of the hot water			
Q	distribution network	L		
R	Insulation on the hot water piping	М		
	Installation considerations (Building			
S	Height, space outdoors)	М		
				location of GHPWH,
				non-traditional
	Additional components	Н	2	locations
	Additional components			

Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	ASHRAE	М		
В	ASPE	М		
С	IPC	М		
	IAPMO/ UPC (Uniform Plumbing			
D	Code)	М		
Е	Manufacturer's method	М		
F	EHPWH Tool	Н	3	
G	Measured data from the site or			
G	from a similar occupancy	Н	2	
	Other method	Н	1	
	Other method			

	re are some features that may tures that are important. Pleas			-
Tea	tures that are important. Fleas	LMH (Low,		
		Medium, High)	Rank	Explanation
				lower emissions, upgrade to
А	Water heater efficiency	Н	1	higher eff
В	Cost	Н	3	
				outside which is out the
	Location where the water			norm, closer to mech room,
С	heater will be installed	Н	4	less piping, lower cost
	Incoming cold water			
D	temperature	М		
_				limit 140, if higher needs to
Е	Hot water temperature	Н	2	be considered
_	Master mixing valve			
F	temperature	L		
G	First hour rating	L	_	
H	Recovery efficiency	L		
I	Heat rate	L		
	Location where the storage	м		
J	tank(s) will be installed	IMI		
	Volume of storage (one large tank or a number of			
К	smaller ones. ASME tanks?)	м		
IX.	Size of storage tanks			
	(volume, dimensions, ASME			
L	tanks?)	м		
	Heat losses of the			
М	circulation loop	М		
	•			manufacturer to brand, know
Ν	Brand	Н	5	it works
	Is water heater sizing			
	adjusted based on the			
	presence of preheat			
0	sources (Solar, etc.)	L		
	Experience with a product			
	other features			

-		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	L		
	Provide space for additional storage			
В	tanks	L		
	Install larger storage as part of initial			
С	design	М	2	
	Install additional storage tanks as part			
D	of initial design	М	3	
	Install heater with larger heating			
Е	capacity as part of initial design	L		
	Provide additional capacity in the gas			
F	line or in the electrical panel	N/A		
	Others	Н	1	
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

	kings.	LMH (Low,		
		Medium, High)	Rank	Explanation
				demand is based on the number of
А	Number of occupants	Н	1	people
В	Number of apartments	Н	3	
С	Demographics of the occupancy (senior, affordable, families, etc.)	м		
D	Number of bathrooms	М		
Е	Type of fixtures	L		
F	Age of the plumbing fixtures	М		
G	Number of washing machines	Н	4	demand focused
Н	Location of washing machines (in apartments, shared)	L		
Ι	Time of day the peak uses occur	L		
J	Duration of the peak periods	Н	5	demand
Κ	Gallons per person per day	Н	2	
	Type of temperature maintenance system (do you prefer circulation,			
L	heat trace, etc.)	L		
М	If circulation, the method of balancing the riser	М		
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
Ρ	Diameter and volume of the hot water distribution network	L		
Q	Configuration of the hot water distribution network	L		
R	Insulation on the hot water piping	М		
S	Installation considerations (Building Height, space outdoors)	м		
	Additional components Additional components			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.			
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	ASHRAE	Н	1	
В	ASPE	Н	2	
С	IPC	L		
D	IAPMO/ UPC (Uniform Plumbing			
	Code)	L		
Е	Manufacturer's method	Н	3	
F	EHPWH Tool	М		
G	Measured data from the site or			
G	from a similar occupancy	L		
	Other method			
	Other method			

	e are some features that may be used to se			-
feat	ures that are important. Please rank order t		e expla	in your rankings.
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Water heater efficiency	Н	3	
В	Cost	Н	4	
	Location where the water heater will be			
С	installed	L		
D	Incoming cold water temperature	L		
Е	Hot water temperature	L		
F	Master mixing valve temperature	L		
G	First hour rating	L		
Н	Recovery efficiency	L		
I	Heat rate	Н	1	
	Location where the storage tank(s) will			
J	be installed	L		
	Volume of storage (one large tank or a			
К	number of smaller ones. ASME tanks?)	L		
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	Н	2	
М	Heat losses of the circulation loop	L		
Ν	Brand	L		
	Is water heater sizing adjusted based on			
	the presence of preheat sources (Solar,			
0	etc.)	L		
	Experience with a product			
	other features			

		LMH (Low, Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters			
	Provide space for additional storage			
В	tanks			
	Install larger storage as part of initial			
С	design	Н		
	Install additional storage tanks as			
D	part of initial design	Н		
	Install heater with larger heating			
Е	capacity as part of initial design			
	Provide additional capacity in the			
F	gas line or in the electrical panel	Н		
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

Tan	kings.	LMH (Low,		
		Medium, High)	Rank	Explanation
Α	Number of occupants	Н	2	establishing demand
В	Number of apartments	М		0
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	Н	4	
D	Number of bathrooms	М		
Е	Type of fixtures	М		
F	Age of the plumbing fixtures	Н		
G	Number of washing machines	М		
	Location of washing machines (in			
Н	apartments, shared)	М		
I	Time of day the peak uses occur	М		
J	Duration of the peak periods	Н	1	establishing demand
Κ	Gallons per person per day	Н	3	
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	Н	4	
	If circulation, the method of			
М	balancing the riser	L		
Ν	Hot water piping material	М		
0	Length of the hot water piping	Н	4	
	Diameter and volume of the hot			
Ρ	water distribution network	Н	4	
	Configuration of the hot water			
Q	distribution network	Н	4	
R	Insulation on the hot water piping	Н	4	
	Installation considerations (Building			
S	Height, space outdoors)	М		
	Additional components			
	Additional components	Н	2	establishing demand

Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	ASHRAE	М	4	
В	ASPE	М	5	
С	IPC	L		
	IAPMO/ UPC (Uniform Plumbing			
D	Code)	М	3	
Е	Manufacturer's method	L		
F	EHPWH Tool	М	2	
0	Measured data from the site or			
G	from a similar occupancy	Н	1	
	Other method	L		
	Other method			

	e are some features that may be used to se			•
feat	ures that are important. Please rank order t		e explair	your rankings.
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Water heater efficiency	Н	1	
В	Cost	M		
	Location where the water heater will be			
С	installed	Н		
D	Incoming cold water temperature	М		
Е	Hot water temperature	М		
F	Master mixing valve temperature	L		
G	First hour rating	Н	3	
Н	Recovery efficiency	Н	4	
Ι	Heat rate	Н	5	
	Location where the storage tank(s) will			
J	be installed	L		
	Volume of storage (one large tank or a			
К	number of smaller ones. ASME tanks?)	Н	2	
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	L		
М	Heat losses of the circulation loop	Н		
Ν	Brand	М		
	Is water heater sizing adjusted based on			
	the presence of preheat sources (Solar,			
0	etc.)	Н		
	Experience with a product			
	other features			

,	0	LMH (Low,		
		• •		
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	М	3	
	Provide space for additional			
В	storage tanks	М	4	
	Install larger storage as part of			
С	initial design	L		
	Install additional storage tanks as			
D	part of initial design	L		
	Install heater with larger heating			
Е	capacity as part of initial design	L		
	Provide additional capacity in the			
F	gas line or in the electrical panel	Н	1	
	Plumbing options to make options			
	to additional equipment	Н	2	
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

	kiiigs.	LMH (Low,		
		Medium, High)	Rank	Explanation
А	Number of occupants	Н	1	establishing demand
В	Number of apartments	Н	1	
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	L		
D	Number of bathrooms	Н	4	
Е	Type of fixtures	Н	5	demand related
F	Age of the plumbing fixtures	L		
G	Number of washing machines	М		
	Location of washing machines (in			
Н	apartments, shared)	М		
Ι	Time of day the peak uses occur	L		
J	Duration of the peak periods	Н	3	
К	Gallons per person per day	Н	2	
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	М		
	If circulation, the method of			
М	balancing the riser	L		
Ν	Hot water piping material	L		
0	Length of the hot water piping	М		
	Diameter and volume of the hot			
Р	water distribution network	М		
	Configuration of the hot water			
Q	distribution network	L		
R	Insulation on the hot water piping	L		
	Installation considerations			
S	(Building Height, space outdoors)	L		
	Additional components			
	Additional components			

Her	Here are some resources used to size water heating systems. Are there any other			
reso	resources that you use? Please rank order the top five. Please explain your rankings.			
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	ASHRAE			ASHRAE is familiar,
А	ASHRAE	Н	1	industry standard
В	ASPE	М	4	
С	IPC	М	3	
	IAPMO/ UPC (Uniform Plumbing			UPC is familiarity
D	Code)	Н	2	standard
Е	Manufacturer's method	L		
F	EHPWH Tool	L		
G	Measured data from the site or			
G	from a similar occupancy	L		
	Other method			
	Other method			

Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.				
		LMH (Low,		
		Medium, High)	Rank	Explanation
				ideal is high but not a
				determinant of the need
А	Water heater efficiency	н	5	to satisfy the job
В	Cost	М		
	Location where the water heater			
С	will be installed	н		
D	Incoming cold water temperature	М		
Е	Hot water temperature	М		
F	Master mixing valve temperature	М		
				determine if peak
G	First hour rating	Н	1	demand can be met
Н	Recovery efficiency	М		
I	Heat rate	Н	4	
	Location where the storage			
J	tank(s) will be installed	М		
	Volume of storage (one large			critical question for
	tank or a number of smaller ones.			space and redundancy
К	ASME tanks?)	Н	2	efficiency
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	Н	3	
	Heat losses of the circulation			
М	Іоор	L		
Ν	Brand	L		
	Is water heater sizing adjusted			
	based on the presence of			
0	preheat sources (Solar, etc.)	L		
	Experience with a product			
	other features			

,00					
		LMH (Low,			
		Medium, High)	Rank	Explanation	
	Provide space for additional			no space no	
А	water heaters	Н	2	product	
	Provide space for additional				
В	storage tanks	Н	2		
				expecting increase	
	Install larger storage as part of			demand, quick and	
С	initial design	Н	1	easy	
	Install additional storage tanks				
D	as part of initial design	М	4		
	Install heater with larger heating				
Е	capacity as part of initial design	М	3		
	Provide additional capacity in				
	the gas line or in the electrical				
F	panel	L			
	Tankless units into storage				
	tanks	М			
	Others				

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

Tarik	ings.	LMH (Low,		
		Medium, High)	Rank	Explanation
Α	Number of occupants	H	1	
В	Number of apartments	Н		
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	М		
D	Number of bathrooms	Н	2	
Е	Type of fixtures	Н		
F	Age of the plumbing fixtures	М		
G	Number of washing machines	Н		
	Location of washing machines (in			
Н	apartments, shared)	Н		
1	Time of day the peak uses occur	L		
J	Duration of the peak periods	Н	4	
Κ	Gallons per person per day	Н	3	
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	М		
	If circulation, the method of			
М	balancing the riser	Н	5	
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
	Diameter and volume of the hot			
Р	water distribution network	M		
	Configuration of the hot water			
Q	distribution network	Н		
R	Insulation on the hot water piping	Н		
	Installation considerations			
S	(Building Height, space outdoors)	Н		
	Additional components			
	Additional components			

Hei	Here are some resources used to size water heating systems. Are there any other						
res	resources that you use? Please rank order the top five. Please explain your rankings.						
		LMH (Low,					
		Medium, High)	Rank	Explanation			
				most established pluming and			
А	ASHRAE			HVAC systems, most industry			
		Н	2	respect			
				most established pluming and			
В	ASPE			HVAC systems, most industry			
		Н	3	respect			
С	IPC	М	5				
D	IAPMO/ UPC (Uniform						
D	Plumbing Code)	М	4				
				contractor standpoint, so many			
E	Manufacturer's			diff types as a contractor we want			
	method			to take out as much liability as we			
		Н	1	can			
F	EHPWH Tool	М					
	Measured data from						
G	the site or from a						
	similar occupancy	L					
	Other method						
	Other method						

	e are some features that may be used cures that are important. Please rank o			
Teat		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Water heater efficiency	H	4	
В	Cost	Н	5	
	Location where the water heater			
С	will be installed	M		
D	Incoming cold water temperature	L		
Е	Hot water temperature	L		
F	Master mixing valve temperature	L		
				how much capacity
G	First hour rating	Н	1	during peal
Н	Recovery efficiency	Н		
I	Heat rate	Н	3	
	Location where the storage tank(s)			
J	will be installed	М		
	Volume of storage (one large tank			
	or a number of smaller ones. ASME			
Κ	tanks?)	M		
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	M		
М	Heat losses of the circulation loop	Н		
				reputable
Ν	Brand	H	2	manufacturer
	Is water heater sizing adjusted			
	based on the presence of preheat			
0	sources (Solar, etc.)	L		
	Electrical Capacity	Н		
	other features	Н	4	

		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	М	4	
	Provide space for additional			
В	storage tanks	Н	1	
	Install larger storage as part of			
С	initial design	Н	3	
	Install additional storage tanks as			
D	part of initial design	Н	2	
	Install heater with larger heating			
Е	capacity as part of initial design	М		
	Provide additional capacity in the			electrical
F	gas line or in the electrical panel	М	5	capacity
	More space in boiler room			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

	kings.	LMH (Low,		
		Medium, High)	Rank	Explanation
А	Number of occupants			
В	Number of apartments	Н		
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	L		
D	Number of bathrooms			
Е	Type of fixtures			
F	Age of the plumbing fixtures			
G	Number of washing machines			
	Location of washing machines (in			
Н	apartments, shared)			
Ι	Time of day the peak uses occur			
J	Duration of the peak periods	Н		
К	Gallons per person per day			
	Type of temperature maintenance			
	system (do you prefer circulation,			so many other
L	heat trace, etc.)	L		factors, insignificant
	If circulation, the method of			
М	balancing the riser	L		
Ν	Hot water piping material			
0	Length of the hot water piping			
	Diameter and volume of the hot			
Ρ	water distribution network			
	Configuration of the hot water			
Q	distribution network	Н		
R	Insulation on the hot water piping	L		code requirements
	Installation considerations (Building			
S	Height, space outdoors)	L		
	Additional components			
	Additional components			

Hei	Here are some resources used to size water heating systems. Are there any other						
res	resources that you use? Please rank order the top five. Please explain your rankings.						
		LMH (Low,					
		Medium, High)	Rank	Explanation			
А	ASHRAE			ASHRAE has become too			
A	ASHKAE	Н	1	complicated in time			
В	ASPE	L					
С	IPC	L					
D	IAPMO/ UPC (Uniform						
	Plumbing Code)	L					
Е	Manufacturer's method	L					
F	EHPWH Tool	L					
	Measured data from						
G	the site or from a						
	similar occupancy	L					
	Other method						
	Other method						

Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.				
100				
А	Water heater efficiency	Medium, High)	Rank	Explanation
В	Cost	Н	4	
	Location where the water			
С	heater will be installed	L		
	Incoming cold water			
D	temperature	L		
Е	Hot water temperature	L		
	Master mixing valve			
F	temperature	L		
G	First hour rating	Н	2	
Н	Recovery efficiency	L		
Ι	Heat rate	Н	3	
	Location where the storage			
J	tank(s) will be installed	L		
	Volume of storage (one large			
	tank or a number of smaller			
Κ	ones. ASME tanks?)	Н		
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	М		
	Heat losses of the circulation			
М	loop	L		
Ν	Brand	L		
	Is water heater sizing adjusted			
	based on the presence of			
0	preheat sources (Solar, etc.)	L		rare to see
	Availability	Н	1	existing buildings
	other features			

		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	L		
	Provide space for additional			
В	storage tanks	L		
	Install larger storage as part of initial			
С	design	Н		
	Install additional storage tanks as			
D	part of initial design	L		
	Install heater with larger heating			
Е	capacity as part of initial design	Н		
	Provide additional capacity in the			
F	gas line or in the electrical panel	L		
	More space in boiler room			
	Others			

	e are some key components needed for additional components? Please rank c	-		- · ·
		LMH (Low, Medium, High)	Rank	Explanation
A	Number of occupants	Medium, riigh) M	Nalik	
B	Number of apartments	M H	1	establish demand
D	Demographics of the occupancy		1	
0		н	2	largest driver for demand
С	(senior, affordable, families, etc.) Number of bathrooms	<u> </u>	2	largest driver for demand
D				
E	Type of fixtures	L		
F	Age of the plumbing fixtures	M		
G	Number of washing machines	М		
				central laundry sees
				heavier usage, whereas in
	Location of washing machines (in		_	apartment more spread
Н	apartments, shared)	Н	5	out
				helps understand
				recovery rates necessary,
Ι	Time of day the peak uses occur	Н	4	storage
J	Duration of the peak periods	Н	3	used to define storage
Κ	Gallons per person per day	L		
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	L		
	If circulation, the method of			
М	balancing the riser	L		automatic balancing
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
	Diameter and volume of the hot			
Р	water distribution network	M		
	Configuration of the hot water			
Q	distribution network	M		
R	Insulation on the hot water piping	L		
	Installation considerations (Building			
S	Height, space outdoors)	L		
	Type of water heating Systems			
	(steam, gas, electric, instantaneous,			more applicable to new
	storage)	н		construction
	Additional components			

Question 4					
	Here	are	some	resources	
			11		

used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings. LMH (Low, Medium, High) Rank Explanation Industry standard documents ASHRAE Н 1 А shared data between AHRAE and В ASPE ASPE. Н 1 IPC С L IAPMO/ UPC (Uniform D Plumbing Code) L Manufacturer's Е method М 3 becoming an industry standard, F EHPWH Tool especially in PNW. Generates useful data 2 М Measured data from G the site or from a 4 similar occupancy М most used in this case *based on Other method Μ 5 ASHRAE/ASPE Other method

©ICF 2024

Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.				
ica		LMH (Low,		
		Medium, High)	Rank	Explanation
			-	code required, not
А	Water heater efficiency	L		a lot to consider
В	Cost	Н	4	
	Location where the water heater will			
С	be installed	М		
D	Incoming cold-water temperature	L		standard
Е	Hot water temperature	L		standard- 140
F	Master mixing valve temperature	L		
				important in MF
				because only 1
G	First hour rating	Н	1	peak
				direct correlation
Н	Recovery efficiency	Н	2	to system design
				direct correlation
Ι	Heat rate	Н	3	to system design
	Location where the storage tank(s)			
J	will be installed	M		
	Volume of storage (one large tank or a			
Κ	number of smaller ones. ASME tanks?)	M		
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	M		
М	Heat losses of the circulation loop	L		
Ν	Brand	L		
	Is water heater sizing adjusted based			
	on the presence of preheat sources			
0	(Solar, etc.)	М		
	Availability			
	other features			

	-	T	1
	Medium, High)	Rank	Explanation
Provide space for additional water			
heaters	М		
Provide space for additional			
storage tanks	М		
			storage tanks are
Install larger storage as part of			cheaper to
initial design	Н	3	oversize
			storage tanks are
Install additional storage tanks as			cheaper to
part of initial design	Н	4	oversize
Install heater with larger heating			directly correlated
capacity as part of initial design	Н	1	to cost
			could be
Provide additional capacity in the			impossible/difficul
gas line or in the electrical panel	Н	2	t in the future
Construction/build limitations			
Others			
	Provide space for additional water heaters Provide space for additional storage tanks Install larger storage as part of initial design Install additional storage tanks as part of initial design Install heater with larger heating capacity as part of initial design Provide additional capacity in the gas line or in the electrical panel Construction/build limitations	LMH (Low, Medium, High)Provide space for additional water heatersMProvide space for additional storage tanksMInstall larger storage as part of initial designHInstall additional storage tanks as part of initial designHInstall heater with larger heating capacity as part of initial designHProvide additional capacity in the gas line or in the electrical panelH	LMH (Low, Medium, High)RankProvide space for additional water heatersMProvide space for additional storage tanksMInstall larger storage as part of initial designMInstall additional storage tanks as part of initial designH13Install additional storage tanks as part of initial designH11Provide additional capacity in the gas line or in the electrical panelH2Construction/build limitations

	e are some key components needed additional components? Please rank			
any		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Number of occupants	H	2	establishes demand,
В	Number of apartments	L		
				correlated with how
	Demographics of the occupancy			much usage per
С	(senior, affordable, families, etc.)	Н	3	person
D	Number of bathrooms	L		
_	T		4	fixture efficiency/ capability affects
Е	Type of fixtures	Н	4	demand
_			_	fixture efficiency/ capability affects
F	Age of the plumbing fixtures	H	5	demand
G	Number of washing machines	M		
	Location of washing machines (in			
Н	apartments, shared)	M		
	Time of day the peak uses occur	L		
J	Duration of the peak periods	L		
К	Gallons per person per day	Н	1	derivate the other 4 Highs
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	L		
	If circulation, the method of			
М	balancing the riser	L		
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
	Diameter and volume of the hot			
Ρ	water distribution network	L		
	Configuration of the hot water			
Q	distribution network	L		
R	Insulation on the hot water piping	L		
	Installation considerations			
S	(Building Height, space outdoors)	L		
	Additional components			
	Additional components			

	Here are some resources used to size water heating systems. Are there any other					
res	resources that you use? Please rank order the top five. Please explain your rankings.					
		LMH (Low,				
		Medium, High)	Rank	Explanation		
А	ASHRAE			Industry standard, reduce liability,		
A	ASHRAE	Н	3	but not as up to date		
В	ASPE	L				
С	IPC	L				
	IAPMO/ UPC (Uniform					
D	Plumbing Code)	М	4			
Е	Manufacturer's method	L				
				based on more update measured		
F	EHPWH Tool			data. Specifically intended for		
Г				heat pumps. More storage and		
		Н	2	less recovery. Personal preference		
	Measured data from					
G	the site or from a					
	similar occupancy	Н	1	if available		
	Other method					
	Other method					

Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.				
		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Water heater efficiency	М		
В	Cost	н	1	client's deciding factor between 2 similar
Б	Location where the water heater	П	1	system s
С	will be installed	М		
D	Incoming cold-water temperature	L		
E	Hot water temperature	L		
F	Master mixing valve temperature	L		
G	First hour rating	М		
Н	Recovery efficiency	М		
1	Heat rate	н	2	Location is important based on layout of building and space
J	Location where the storage tank(s) will be installed	н	3	Tanks take up space, heavy need space in the building.
K	Volume of storage (one large tank or a number of smaller ones. ASME tanks?)	M		
L	Size of storage tanks (volume, dimensions, ASME tanks?)	L		
М	Heat losses of the circulation loop	L		
Ν	Brand	L		
0	Is water heater sizing adjusted based on the presence of preheat sources (Solar, etc.)	L		
Р	Gallons per hour (recovery rate)	Н	2	Almost identical to (heat rate)
	other features			

	LMH (Low,		
	Medium, High)	Rank	Explanation
			if additional demand is on
Provide space for			the same peak as before
additional water heaters	Н	2	then more heaters
Provide space for			if additional demand is off
additional storage tanks	Н	3	peak then more heaters
Install larger storage as			
part of initial design	L		
Install additional storage			
tanks as part of initial			
design	L		
Install heater with larger			
heating capacity as part of			
initial design	L		
Provide additional			big deciding factor, most
capacity in the gas line or			upstream. Hard/Impossible
in the electrical panel	Н	1	to update later
Others			
Others			
	additional water heaters Provide space for additional storage tanks Install larger storage as part of initial design Install additional storage tanks as part of initial design Install heater with larger heating capacity as part of initial design Provide additional capacity in the gas line or in the electrical panel Others	Medium, High)Provide space for additional water heatersHProvide space for additional storage tanksHInstall larger storage as part of initial designLInstall additional storage tanks as part of initial designLInstall heater with larger heating capacity as part of initial designLProvide additionalLProvide additionalHOthersH	Medium, High)RankProvide space for additional water heatersH2Provide space for additional storage tanksH3Install larger storage as part of initial designLInstall additional storage tanks as part of initial designLInstall heater with larger heating capacity as part of initial designLInstallProvide additionalLInstall heater with larger heating capacity as part of initial designLProvide additionalLInstallOthersH1

	re are some key components needed	-		- ·
any	vadditional components? Please rank	LMH (Low,	e. Please	explain your rankings.
		Medium, High)	Rank	Explanation
A	Number of occupants	H	1	
B	Number of apartments	Н	4	
D	Demographics of the occupancy	11		
С	(senior, affordable, families, etc.)	н	2	
D	Number of bathrooms		2	
E	Type of fixtures	M		
F	Age of the plumbing fixtures	M		
G	Number of washing machines	1		
u	Location of washing machines (in	L		
Н	apartments, shared)	L		
	apartments, shared)	L		
				considering the load
				profile during peak,
	Time of day, the peok uses easur	н	5	potentially during 2
	Time of day the peak uses occur	п	5	peaks
				considering the load
				profile during peak,
	Duration of the model would de		_	potentially during 2
J	Duration of the peak periods	Н	5	peaks
K	Gallons per person per day	Н	2	
	Type of temperature maintenance			·····
	system (do you prefer circulation,			important for recirc
L	heat trace, etc.)	Н	3	sizing
	If circulation, the method of			
M	balancing the riser	L		
N	Hot water piping material	L		
~				important in design
0	Length of the hot water piping	M		but not sizing
_	Diameter and volume of the hot			important in design
Ρ	water distribution network	M		but not sizing
_	Configuration of the hot water			important in design
Q	distribution network	М		but not sizing
				important in design
R	Insulation on the hot water piping	М		but not sizing
	Installation considerations (Building			important in design
S	Height, space outdoors)	М		but not sizing
	Additional components			
	Additional components			

Hei	Here are some resources used to size water heating systems. Are there any other					
res	resources that you use? Please rank order the top five. Please explain your rankings.					
		LMH (Low,				
		Medium, High)	Rank	Explanation		
А	ASHRAE	М	4			
В	ASPE			not as updated with the times,		
D	ASFE	М	4	accredited processes		
С	IPC	L				
D	IAPMO/ UPC (Uniform					
	Plumbing Code)	L				
Е	Manufacturer's method	М	3	more liability		
F	EHPWH Tool	Н	1	only for heat pump water heaters		
	Measured data from					
G	the site or from a			important to gather these profiles		
	similar occupancy	М	2	especially with mixed loads		
	Other method					
	Other method					

	Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.				
Tea		LMH (Low,			
		Medium, High)	Rank	Explanation	
				mission driven, be as efficient as	
А	Water heater efficiency	н	3	possible	
В	Cost	Н	2	client determinant	
				safety/regulation	
	Location where the			considerations. Heater	
	water heater will be			capabilities need for fan, ducts,	
С	installed	н	4	vents etc.	
	Incoming cold-water				
D	temperature	М			
Е	Hot water temperature	М	1		
	Master mixing valve				
F	temperature	L			
G	First hour rating	Н	1		
Н	Recovery efficiency	Н			
Ι	Heat rate	Н	1	not flexible in need	
	Location where the				
	storage tank(s) will be				
J	installed	L			
	Volume of storage (one				
	large tank or a number of				
	smaller ones. ASME				
К	tanks?)	Н			
	Size of storage tanks				
	(volume, dimensions,				
L	ASME tanks?)	Н			
	Heat losses of the				
М	circulation loop	Н			
Ν	Brand	Н	5		
	Is water heater sizing				
	adjusted based on the				
	presence of preheat				
0	sources (Solar, etc.)	L		design considerations	
	Gallons per hour				
Ρ	(recovery rate)	Н	1		
	other features				

,00			1	
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
Α	water heaters	Н	2	
	Provide space for additional			
В	storage tanks	Н	2	
				oversizing system leads to
	Install larger storage as part			more stagnant water,
С	of initial design	L		more heat losses
				oversizing system leads to
	Install additional storage			more stagnant water,
D	tanks as part of initial design	L		more heat losses
	Install heater with larger			oversizing system leads to
	heating capacity as part of			more stagnant water,
Е	initial design	L		more heat losses
	Provide additional capacity in			
	the gas line or in the			hard to retrofit, upstream
F	electrical panel	Н	1	change to make
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

	ikings.	LMH (Low,		
		Medium, High)	Rank	Explanation
А	Number of occupants	н	1	demand (people use the water)
В	Number of apartments	L		used more often than others
	Demographics of the occupancy			families use more,
С	(senior, affordable, families, etc.)	н	2	singles use less
D	Number of bathrooms	М		
Е	Type of fixtures	L		
F	Age of the plumbing fixtures	L		
G	Number of washing machines	М		
Н	Location of washing machines (in apartments, shared)	L		
	Time of day the peak uses occur	L		
J	Duration of the peak periods	Н	3	
Κ	Gallons per person per day	L		
	Type of temperature maintenance system (do you prefer circulation,			
L	heat trace, etc.)	L		
М	If circulation, the method of balancing the riser	L		
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
Р	Diameter and volume of the hot water distribution network	L		
Q	Configuration of the hot water distribution network	L		
R	Insulation on the hot water piping	М		
S	Installation considerations (Building Height, space outdoors)	м		
	Water softener selection and operation			
	Additional components			

Hei	Here are some resources used to size water heating systems. Are there any other				
res	resources that you use? Please rank order the top five. Please explain your rankings.				
		LMH (Low,			
		Medium, High)	Rank	Explanation	
А	ASHRAE			ASHRAE are professionals'	
А	ASHKAL	Н	1	industry standard	
В	ASPE	Н	2	same as ASHRAE for multifamily	
С	IPC	L			
	IAPMO/ UPC				
D	(Uniform Plumbing				
	Code)	L			
E	Manufacturer's				
	method	М		hesitant	
F	EHPWH Tool	L			
	Measured data				
G	from the site or				
u	from a similar				
	occupancy	L			
	Other method				
	Other method				

Her	Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.				
		LMH (Low,			
		Medium, High)	Rank	Explanation	
Α	Water heater efficiency	H	3	l .	
В	Cost	Н	2	real life client preference	
	Location where the water				
С	heater will be installed	М			
	Incoming cold-water				
D	temperature	L			
Е	Hot water temperature	L			
	Master mixing valve				
F	temperature	L			
G	First hour rating	М			
Н	Recovery efficiency	М			
Ι	Heat rate	Н	1	meet the load, client cares about	
	Location where the storage				
J	tank(s) will be installed	М			
	Volume of storage (one				
	large tank or a number of				
K	smaller ones. ASME tanks?)	L			
	Size of storage tanks				
	(volume, dimensions, ASME				
L	tanks?)	Н	4		
	Heat losses of the				
М	circulation loop	L			
Ν	Brand	М			
	Is water heater sizing				
	adjusted based on the				
	presence of preheat				
0	sources (Solar, etc.)	N/A	ļ		
	Gallons per hour (recovery		_		
Р	rate)	Н	5		
	other features				

you				
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for			
А	additional water heaters	L		
	Provide space for			
В	additional storage tanks	Н	2	
	Install larger storage as			
С	part of initial design	L		
	Install additional storage			
	tanks as part of initial			
D	design	L		
	Install heater with larger			20-30 year equipment and no
	heating capacity as part of			engineer want to get a call 5
Е	initial design	Н	1	years down the line
	Provide additional			
	capacity in the gas line or			
F	in the electrical panel	L		function of E
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

ran	kings.			
		LMH (Low,		
		Medium, High)	Rank	Explanation
				Inputs to BPA sizing
А	Number of occupants	Н	1	calculator
				Inputs to BPA sizing
В	Number of apartments	Н	1	calculator
	Demographics of the occupancy			Important if there is
С	(senior, affordable, families, etc.)	М	3	load shifting
				Not used in BPA
D	Number of bathrooms	L		calculator
				Not used in BPA
Е	Type of fixtures	L		calculator
				Not used in BPA
F	Age of the plumbing fixtures	L		calculator
				Not used in BPA
G	Number of washing machines	L		calculator
	Location of washing machines (in			Not used in BPA
Н	apartments, shared)	L		calculator
				Important if there is
				load shifting. If time
				of use is not a
				concern, then sizing
				will be based on
Ι	Time of day the peak uses occur	М	3	peak demand.
				Important if there is
J	Duration of the peak periods	М	3	load shifting
				Uses other inputs
				and ASHRAE load
				assumptions to find
				gallons per day per
K	Gallons per person per day	Н	2	person
	Type of temperature maintenance			Part of the
	system (do you prefer circulation,			prescribed design
L	heat trace, etc.)	L	5	configurations.
	If circulation, the method of			Not used in BPA
М	balancing the riser	L		calculator
				Not used in BPA
Ν	Hot water piping material	L		calculator

				Not used in BPA
0	Length of the hot water piping	L		calculator
				They already
				consider distribution
				loses in prescribed
	Diameter and volume of the hot			design
Р	water distribution network	L	5	configurations.
				They already
				consider distribution
				loses in prescribed
	Configuration of the hot water			design
Q	distribution network	L	5	configurations.
				Not used in BPA
R	Insulation on the hot water piping	L		calculator
	Installation considerations (Building			Not used in BPA
S	Height, space outdoors)	L		calculator
				Inputs to BPA sizing
	Climate/OAT	Н		calculator
	Temp of return/supply water			Inputs to BPA sizing
	(@120F)	Н		calculator

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.					
103		LMH (Low,				
		Medium, High)	Rank	Explanation		
				Built into EHPWH Tool, but also		
				used by field engineers to cross		
A	ASHRAE			check the required		
		Н	4	gallons/day/person.		
В	ASPE	L		Not familiar with this.		
С	IPC	L		does not consider this.		
	IAPMO/ UPC (Uniform					
D	Plumbing Code)	L		does not consider this.		
				Work with manufacturers to		
				develop QPL and design sizing		
	Manufacturer's method			methods for each product.		
				Specific products in certain		
				design configurations that get		
E				approved on QPL. Manufacturers		
	Manufacturersmethou			also need to submit performance		
				curve for that product in that		
				approved design configuration.		
				BPA intervenes early to help		
				manufacturers get the ET to		
		М	5	market correctly.		
F	EHPWH Tool			Primary calculator method used		
Ľ		H	1	by BPA. Uses Title 24 engine.		
				Data used to establish baseline		
	Measured data from			energy usage and establish		
G	the site or from a			available inputs to sizing calculator		
	similar occupancy		_	(i.e. using temp sensors and flow		
		Н	3	meters)		
	Other method					
	Other method					

Here are some features that may be used to select a water heater. Are there any other features					
that	: are important. Please ra		five. Ple	ase explain your rankings.	
		LMH (Low,			
	1	Medium, High)	Rank	Explanation	
	Water heater			all QPL products are efficient, so this is	
А	efficiency	Н	5	less important	
В	Cost	Н	1	Top factor	
				Depends on ambient conditions to select	
	Location where the			product. i.e.,	
	water heater will be			cannot use a heat pump in an enclosed	
С	installed	Н	4	space	
				Used for sizing method + product	
				selection. Ex. Dairies use a lot of hot water	
				to milk cows uses 70F geothermal water	
	Incoming cold-water			source, so you cannot use a CO2 based	
D	temperature	Н	3	HPWH since there is not enough lift or DT.	
				critical sizing parameter in sizing	
	Hot water			calculator, but also	
Е	temperature	М		considered in product selection.	
	Master mixing valve			critical in design, not product selection.	
F	temperature	L		Part of QPL.	
				critical sizing parameter in sizing	
				calculator, but also	
G	First hour rating	М		considered in product selection.	
				critical sizing parameter in sizing	
				calculator, but also	
Н	Recovery efficiency	М		considered in product selection.	
				critical for product selection. Products	
				that can provide	
				optimal capacity without being oversized	
1	Heat rate	Н	2	considering modular setups.	
	Location where the				
	storage tank(s) will			Already considered in QPL approved	
J	be installed	L		designs.	
	Volume of storage				
	(one large tank or a				
	number of smaller			Already considered in QPL approved	
Κ	ones. ASME tanks?)	L		designs.	
	Size of storage tanks				
	(volume, dimensions,			Already considered in QPL approved	
L	ASME tanks?)	L		designs.	
	Heat losses of the			Already considered in QPL approved	
М	circulation loop	L		designs.	

N	Brand	М		Depends on available information on the brand to be selected for the QPL or may be selected as a great opportunity for demo
	Is water heater sizing			
	adjusted based on			
	the presence of			Same importance as incoming water
	preheat sources			temperature, which is important for
0	(Solar, etc.)	Н	3	product selection
	Gallons per hour			
Р	(recovery rate)	L		
				Validates the preapproved QPL designs.
				New tiers are established based on
	other features			submitted MV data.

		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Provide space for additional water heaters	Н	3	Along with tanks, WH space is needed to meet demand
В	Provide space for additional storage tanks	н	2	Storage tanks take up more space than additional WHs
С	Install larger storage as part of initial design	М	5	Hard to predict future demand beyond initial design phase
D	Install additional storage tanks as part of initial design	м	5	Hard to predict future demand beyond initial design phase
E	Install heater with larger heating capacity as part of initial design	н	1	This would reduce need for additional space
F	Provide additional capacity in the gas line or in the electrical panel	м	4	Hard to predict future demand beyond initial design phase
	Others	Н	3	Along with tanks, WH space is needed to meet demand
	Others	Н	2	Storage tanks take up more space than additional WHs

	e are some key components needed additional components? Please ran			
uny		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Number of occupants	L		
В	Number of apartments	М		
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	L		
				multiple bathrooms
D	Number of bathrooms	М		multiple points of draw
Е	Type of fixtures	М		
F	Age of the plumbing fixtures	М		older means higher flow
				multiple washing
				machines means more
G	Number of washing machines	М		draw
	Location of washing machines (in			location affects
Н	apartments, shared)	М		demand
				in the morning or at
				night depending on
I	Time of day the peak uses occur	М		demographic
J	Duration of the peak periods	М		
Κ	Gallons per person per day	Н	1	
	Type of temperature			
	maintenance system (do you			not having adequate
	prefer circulation, heat trace,			hot water in reasonable
L	etc.)	н	2	leads to waste
	If circulation, the method of			
М	balancing the riser	М		
Ν	Hot water piping material	М		material is important
0	Length of the hot water piping	L		
	Diameter and volume of the hot			
Р	water distribution network	М		minimize if possible
	Configuration of the hot water			based on architectural
Q	distribution network	М		layout of system
	Insulation on the hot water			, , ,
R	piping	М		
	Installation considerations			lower importance but of
S	(Building Height, space outdoors)	L		relevance
-	Other	_		
	Other			

Here	Here are some resources used to size water heating systems. Are there any other						
resc	resources that you use? Please rank order the top five. Please explain your rankings.						
		LMH (Low,					
		Medium, High)	Rank	Explanation			
А	ASHRAE	L		not of much use			
В	ASPE	М					
С	IPC	L					
D	IAPMO/ UPC (Uniform						
	Plumbing Code)	М					
Е	Manufacturer's method			basing on historical data			
	Manufacturers method	L		without verification			
F	EHPWH Tool	L					
	Measured data from the						
G	site or from a similar						
	occupancy	Н					
	Adding Scalability	М					
	Other method						

Here are some features that may be used to select a water heater. Are there any other features					
tha	t are important. Please rank order		se explain	your rankings.	
		LMH (Low,			
•		Medium, High)	Rank	Explanation	
A	Water heater efficiency	Н	3		
В	Cost	L			
•	Location where the water				
С	heater will be installed	М			
	Incoming cold-water				
D	temperature	L			
Е	Hot water temperature	М		scalding a concern	
	Master mixing valve			electronic safety controls	
F	temperature	L		MMV might be a waste	
G	First hour rating	М			
Н	Recovery efficiency	Н	1	maintain efficiency of unit	
				high priority, too high is a	
I.	Heat rate	Н	2	waste of energy	
	Location where the storage				
J	tank(s) will be installed	М			
	Volume of storage (one large				
	tank or a number of smaller				
К	ones. ASME tanks?)	L			
	Size of storage tanks (volume,			determine dimensional	
L	dimensions, ASME tanks?)	н	5	requirements	
	Heat losses of the circulation			· ·	
М	Іоор	н	4		
Ν	Brand	М		reliability and loyalty	
	Is water heater sizing adjusted				
	based on the presence of				
0	preheat sources (Solar, etc.)	L		owner driven	
	Gallons per hour (recovery				
Р	rate)	н	1		
	other features				

,				
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	М		
	Provide space for additional			
В	storage tanks	М		
	Install larger storage as part			
С	of initial design	Н	3	
	Install additional storage			
D	tanks as part of initial design	М		
	Install heater with larger			higher capacity can make
	heating capacity as part of			it so higher storage is not
Е	initial design	Н	2	needed
	Provide additional capacity in			
	the gas line or in the electrical			
F	panel	Н	1	need it for demand
	Others			
	Others			

	e are some key components needed additional components? Please ran	-		- ·
arry	additional components: Tlease rail	LMH (Low,		
		Medium, High)	Rank	Explanation
				drives calculations from
				ASHRAE and ASPE. This
А	Number of occupants	Н	1	establishes demand
B	Number of apartments	Н	1	
				different demographics
	Demographics of the occupancy			consume different
С	(senior, affordable, families, etc.)	Н	5	amounts
D	Number of bathrooms	L		
Е	Type of fixtures	L		
F	Age of the plumbing fixtures	L		
G	Number of washing machines	L		
0.	Location of washing machines (in			
н	apartments, shared)	М		
1	Time of day the peak uses occur	L		
•				driver in the boiler
J	Duration of the peak periods	н	2	system
0			-	driver in the heat pump
Κ	Gallons per person per day	н	3	system
	Type of temperature		Ű	
	maintenance system (do you			
	prefer circulation, heat trace,			
L	etc.)	н	4	
-	If circulation, the method of		-	
М	balancing the riser	L		
N	Hot water piping material	L		
0	Length of the hot water piping	L		
•	Diameter and volume of the hot			
Р	water distribution network	М		swing tank sizing
•	Configuration of the hot water			
Q	distribution network	L		
~	Insulation on the hot water			
R	piping	М		
	Installation considerations			
S	(Building Height, space outdoors)	L		
-	Other	_		
	Other			

Hei	Here are some resources used to size water heating systems. Are there any other						
res	resources that you use? Please rank order the top five. Please explain your rankings.						
		LMH (Low,					
		Medium, High)	Rank	Explanation			
А	ASHRAE	Н	2				
В	ASPE	Н	1				
С	IPC	L					
D	IAPMO/ UPC (Uniform						
	Plumbing Code)	L					
Е	Manufacturer's						
	method	М					
F	EHPWH Tool	Н	3	only for use in Heat Pump			
	Measured data from						
G	the site or from a						
	similar occupancy	L					
	Other method						
	Other method						

Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.					
tha	t are important. Please rank or	LMH (Low,	lease e	kplain your rankings.	
		Medium, High)	Rank	Explanation	
А	Water heater efficiency	M	Karik		
B	Cost	M			
0	Location where the water	1*1			
С	heater will be installed	н	4		
<u> </u>	Incoming cold-water		-		
D	temperature	1			
E	Hot water temperature	L			
<u> </u>	Master mixing valve	E			
F	temperature	1			
G	First hour rating	L			
H	Recovery efficiency	H	3		
1	Heat rate	Н	1		
•	Location where the storage		1		
J	tank(s) will be installed	м			
	Volume of storage (one				
	large tank or a number of				
К	smaller ones. ASME tanks?)	М			
	Size of storage tanks				
	(volume, dimensions, ASME				
L	tanks?)	н	2		
	Heat losses of the				
М	circulation loop	М			
Ν	Brand	М		familiarity of certain products	
	Is water heater sizing				
	adjusted based on the				
	presence of preheat				
0	sources (Solar, etc.)	М		high if avail	
	Gallons per hour (recovery				
Ρ	rate)	Н	1		
	other features				

,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	i rankings.	/		
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for			
	additional water			
А	heaters	Н	2	more flexible with size
	Provide space for			
	additional storage			heaviest and hardest to get into
В	tanks	Н	1	building
	Install larger storage			
С	as part of initial design	L		
	Install additional			
	storage tanks as part			
D	of initial design	L		
	Install heater with			
	larger heating			
	capacity as part of			
Е	initial design	L		
	Provide additional			
	capacity in the gas			
	line or in the electrical			
F	panel	Н	3	
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

Turi	kings.	LMH (Low,		
		Medium, High)	Rank	Explanation
•				drives calculations from ASHRAE and ASPE. This establishes
A	Number of occupants	Н	1	demand
B	Number of apartments Demographics of the occupancy	H	1	different demographics consume different
С	(senior, affordable, families, etc.)	Н	5	amounts
D	Number of bathrooms	L		
Е	Type of fixtures	L		
F	Age of the plumbing fixtures	L		
G	Number of washing machines	L		
Н	Location of washing machines (in apartments, shared)	М		
I	Time of day the peak uses occur	L		
J	Duration of the peak periods	Н	2	driver in the boiler system driver in the heat
к	Gallons per person per day	н	3	pump system
L	Type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	Н	4	
М	If circulation, the method of			
N N	balancing the riser Hot water piping material	L		
N 0	Length of the hot water piping			
P	Diameter and volume of the hot water distribution network	M		swing tank sizing
Q	Configuration of the hot water distribution network	L		
R S	Insulation on the hot water piping Installation considerations (Building Height, space outdoors) Other	L		
	Other			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
		LMH (Low,			
		Medium, High)	Rank	Explanation	
А	ASHRAE	Н	2		
В	ASPE	Н	1		
С	IPC	L			
D	IAPMO/ UPC (Uniform				
	Plumbing Code)	L			
Е	Manufacturer's method	М			
F	EHPWH Tool	Н	3	only for use in Heat Pump	
G	Measured data from the site				
G	or from a similar occupancy	L			
	Other method				
	Other method				

	re are some features that may			•
теа	tures that are important. Pleas	LMH (Low,	top five. I	Please explain your rankings.
		Medium, High)	Rank	Explanation
A	Water heater efficiency	Mediulii, Figh) M	Ralik	Explanation
A B		M		
D	Cost Location where the water	IMI		
~			1	
С	heater will be installed	Н	4	
-	Incoming cold-water			
D	temperature	L		
E	Hot water temperature	L		
	Master mixing valve			
F	temperature	L		
G	First hour rating	L		
Н	Recovery efficiency	Н	3	
I	Heat rate	Н	1	
	Location where the storage			
J	tank(s) will be installed	М		
	Volume of storage (one			
	large tank or a number of			
Κ	smaller ones. ASME tanks?)	М		
	Size of storage tanks			
	(volume, dimensions, ASME			
L	tanks?)	н	2	
	Heat losses of the			
М	circulation loop	м		
-		-		familiarity of certain
Ν	Brand	М		products
	Is water heater sizing			
	adjusted based on the			
	presence of preheat			
0	sources (Solar, etc.)	м		high if avail
-	Gallons per hour (recovery			
Р	rate)	н	1	
•	other features			

/**				
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	Н	2	more flexible with size
	Provide space for additional			heaviest and hardest to get
В	storage tanks	Н	1	into building
	Install larger storage as part			
С	of initial design	L		
	Install additional storage			
D	tanks as part of initial design	L		
	Install heater with larger			
	heating capacity as part of			
Е	initial design	L		
	Provide additional capacity			
	in the gas line or in the			
F	electrical panel	Н	3	
	Others			
	Others			

any additional components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please explain your rational components? Please rank order the top five. Please rank order to the top five. Please rank order the top five. Please rank order to the top five. Please rank or top five. Please rank order to the top five. Please rank or top five. Please rank orderank or top five. Please rank order to top	Are there
Medium, High)RankExplanationImage: Number of occupantsH1how many person per dayANumber of occupantsH1understandirBNumber of apartmentsMImage: Number of apartmentsMC(senior, affordable, families, etc.)MImage: Number of pathroomsImage: Number of pathroomsDNumber of bathroomsLImage: Number of pathroomsImage: Number of pathroomsImage: Number of pathroomsEType of fixturesLImage: Number of washing machinesImage: Number of washing machinesImage: Number of washing machinesGNumber of washing machinesImage: Number of washing machinesImage: Number of washing machinesImage: Number of washing machinesITime of day the peak uses occurH5Image: Number of washing machinesImage: Number of washing machinesJDuration of the peak periodsH5Image: Number of washing machinesImage: Number of washing machinesKGallons per person per dayH2Image: Number of washing machinesKGallons per person per dayH2Image: Numer anouncombuilding can I/3 of the totKGallons per person per dayH2Image: Numer anouncombuilding can I/3 of the tot	nkings.
A Number of occupants H 1 understandir B Number of apartments M 1 understandir B Number of apartments M 1 understandir C (senior, affordable, families, etc.) M 1 1 D Number of bathrooms L 1 1 E Type of fixtures L 1 1 G Number of washing machines M 1 1 H apartments, shared) L 1 1 1 I Time of day the peak uses occur H 5 5 J Duration of the peak periods H 5 1 K Gallons per person per day H 2 1 1 K Gallons per person per day H 2 1 1 1 Type of temperature maintenance 1/3 of the tot 1 1 3 1 1	
ANumber of occupantsH1using the wat cover expect density. Dem understandirBNumber of apartmentsMImage: Cover expect density. Dem understandirBNumber of apartmentsMImage: Cover expect density. Dem understandirC(senior, affordable, families, etc.)MImage: Cover expect understandirDNumber of bathroomsLImage: Cover expect understandirEType of fixturesLImage: Cover expect understandirFAge of the plumbing fixturesLImage: Cover expect understandirGNumber of washing machinesMImage: Cover expect understandirGNumber of washing machinesMImage: Cover expect understandirITime of day the peak uses occurH5JDuration of the peak periodsH5KGallons per person per dayH2KGallons per person per dayH2IType of temperature maintenanceImage: Image: Cover expect understandir understandir understandir understandir understandir	
ANumber of occupantsH1understandirBNumber of apartmentsMDemographics of the occupancyC(senior, affordable, families, etc.)MDNumber of bathroomsLEType of fixturesLFAge of the plumbing fixturesLGNumber of washing machinesMLocation of washing machinesMITime of day the peak uses occurH5JDuration of the peak periodsH5KGallons per person per dayH2Vape of temperature maintenance1/3 of the tot	•
ANumber of occupantsH1understandirBNumber of apartmentsM1understandirBNumber of apartmentsM1understandirDDemographics of the occupancy (senior, affordable, families, etc.)M11DNumber of bathroomsL111EType of fixturesL111FAge of the plumbing fixturesL111GNumber of washing machinesM111Location of washing machines (in H apartments, shared)L111ITime of day the peak uses occurH551JDuration of the peak periodsH511KGallons per person per dayH2understandir water around building can 1/3 of the tot	
ANumber of occupantsH1understandirBNumber of apartmentsMImage: Standard Stand	
B Number of apartments M Demographics of the occupancy C C (senior, affordable, families, etc.) M D Number of bathrooms L E Type of fixtures L F Age of the plumbing fixtures L G Number of washing machines M Location of washing machines (in L H apartments, shared) L I Time of day the peak uses occur H 5 J Duration of the peak periods H 5 K Gallons per person per day H 2 understandir Fenergy to pu water around building can 1/3 of the tot	
Demographics of the occupancy (senior, affordable, families, etc.)MDNumber of bathroomsLEType of fixturesLFAge of the plumbing fixturesLGNumber of washing machinesMLocation of washing machines (in H apartments, shared)LITime of day the peak uses occurHJDuration of the peak periodsHKGallons per person per dayHZUnderstandir water around building can 1/3 of the tot	g
C (senior, affordable, families, etc.) M D Number of bathrooms L E Type of fixtures L F Age of the plumbing fixtures L G Number of washing machines M Location of washing machines (in H H apartments, shared) L I Time of day the peak uses occur H 5 J Duration of the peak periods H 5 K Gallons per person per day H 2 understandir K Gallons per person per day H 2 understandir Type of temperature maintenance 1/3 of the tot 1/3 of the tot	
DNumber of bathroomsLEType of fixturesLFAge of the plumbing fixturesLGNumber of washing machinesMLocation of washing machines (in H apartments, shared)LITime of day the peak uses occurHJDuration of the peak periodsHKGallons per person per dayHZUnderstandir water around building can 1/3 of the tot	
EType of fixturesLFAge of the plumbing fixturesLGNumber of washing machinesMLocation of washing machines (in H apartments, shared)LITime of day the peak uses occurHJDuration of the peak periodsHKGallons per person per dayHZUnderstandir water around building can 1/3 of the tot	
F Age of the plumbing fixtures L G Number of washing machines M I Location of washing machines (in H apartments, shared) L I Time of day the peak uses occur H 5 J Duration of the peak periods H 5 K Gallons per person per day H 2 Demand understandir building can 1/3 of the tot	
G Number of washing machines M Location of washing machines (in L H apartments, shared) L I Time of day the peak uses occur H 5 J Duration of the peak periods H 5 K Gallons per person per day H 2 Understandir energy to pu water around building can 1/3 of the tot	
Location of washing machines (in apartments, shared) L I Time of day the peak uses occur H 5 J Duration of the peak periods H 5 K Gallons per person per day H 2 Demand K Type of temperature maintenance 1/3 of the tot 1/3 of the tot	
H apartments, shared) L I Time of day the peak uses occur H 5 J Duration of the peak periods H 5 K Gallons per person per day H 2 Demand K Gallons per person per day H 2 understandir Duration of the peak periods H 10 10 10 K Gallons per person per day H 2 10 10 K Type of temperature maintenance 1/3 of the tot 1/3 of the tot	
I Time of day the peak uses occur H 5 J Duration of the peak periods H 5 K Gallons per person per day H 2 Demand K Gallons per person per day H 2 understandir V V V V V V V V V V V V V V V V V V V V	
J Duration of the peak periods H 5 K Gallons per person per day H 2 Demand K Gallons per person per day H 2 understandir Image: How the peak periods H 2 Image: How the peak periods Image: How the peak periods K Gallons per person per day H 2 Image: How the peak periods Image: How the peak periods K Gallons per person per day H 2 Image: How the peak periods Image: How the peak periods K Gallons per person per day H 2 Image: How the peak peak peak peak peak peak peak pea	
K Gallons per person per day H 2 Demand understandir K Gallons per person per day H 2 understandir energy to pu water around building can 1/3 of the tot Image: Comparison per day Image: Comparison per day Image: Comparison per day	
K Gallons per person per day H 2 understandir Image: H 2 understandir energy to put water around building can building can 1/3 of the tot	
energy to pu water around building can 1/3 of the tot	
water around building canType of temperature maintenance1/3 of the tot	g
Type of temperature maintenancebuilding can1/3 of the tot	sh hot
Type of temperature maintenance 1/3 of the tot	the
	oe 1/2 to
system (do you prefer circulation, domestic ho	al
	water
L heat trace, etc.) H 3 use.	
If circulation, the method of MF is a 24/7	energy
M balancing the riser H 3 drain on the	
N Hot water piping material L	
O Length of the hot water piping M	
Diameter and volume of the hot	
P water distribution network M	
Configuration of the hot water	
Q distribution network M	
R Insulation on the hot water piping M	
Installation considerations (Building	
S Height, space outdoors) M	
Other	
Other	

Hei	Here are some resources used to size water heating systems. Are there any other						
res	resources that you use? Please rank order the top five. Please explain your rankings.						
	LMH (Low, Rank Explanation						
		Medium, High)					
А	ASHRAE	Н	2	traditional sizing tool			
В	ASPE	М					
С	IPC	М					
D	IAPMO/ UPC (Uniform						
	Plumbing Code)	Н	4				
Е	Manufacturer's method	L					
F	EHPWH Tool	Н	1	Updating with lots of data			
	Measured data from						
G	the site or from a						
	similar occupancy	Н	3	affective if possible			
	Other method	Н	2	traditional sizing tool			
	Other method						

	e are some features that may be u			-
tha	t are important. Please rank order t		se expla	in your rankings.
		LMH (Low,		
		Medium, High)	Rank	Explanation
A	Water heater efficiency	H	4	
В	Cost	М		
С	Location where the water heater will be installed	Н	2	depending on equipment/ refrigerant type. Location can have a huge impact on capacity, efficiency, and reliability
	Incoming cold-water			
D	temperature	L		
E	Hot water temperature	L		
F	Master mixing valve temperature	L		
G	First hour rating	М		
Н	Recovery efficiency	М		
				central plants need a balance between capacity and storage. Equipment costs more but storage tanks take up more space. More
I	Heat rate	Н	1	storage can handle longer peak
J	Location where the storage tank(s) will be installed Volume of storage (one large tank or a number of smaller ones.	L		
к	ASME tanks?)	м		
IX .	Size of storage tanks (volume,			central plants need a balance between capacity and storage. Equipment costs more but storage tanks take up more space. More
L	dimensions, ASME tanks?)	Н	1	storage can handle longer peak
	Heat losses of the circulation			
М	Іоор	М		
Ν	Brand	М		
	Is water heater sizing adjusted based on the presence of			
0	preheat sources (Solar, etc.)	L		
Ρ	Gallons per hour (recovery rate)	М		
	Average expected air temperature of water heater location (outside/inside/temp			some refrigerants are effective in
	outside)	Н	3	different temps
			, v	

yuu	i Talikings.			
		LMH (Low,		
		Medium, High)	Rank	Explanation
				central plant tanks take up a lot
	Provide space for			of space so necessary to
А	additional water heaters	Н	2	account for space
				central plant tanks take up a lot
	Provide space for			of space so necessary to
В	additional storage tanks	Н	2	account for space
	Install larger storage as			oversizing can lead to issues in
С	part of initial design	Н	4	efficiency and capacity
	Install additional storage			
	tanks as part of initial			
D	design	L		
	Install heater with larger			
	heating capacity as part			
Е	of initial design	М		
	Provide additional			
	capacity in the gas line or			if not big enough, huge barrier to
F	in the electrical panel	Н	1	increase in demand
	Controls capability to			Increase capacity by telling
	manage plant			things to turn on sooner rather
	functionality	Н	3	than later
	Others			

	e are some key components needed	-		
any	additional components? Please rank	LMH (Low, Medium,		
		High)	Rank	Explanation
				accessible information from ASHRAE and anecdotal sources regarding per person
Α	Number of occupants	Н	1	consumption
В	Number of apartments	Н	5	
С	Demographics of the occupancy (senior, affordable, families, etc.)	L		
D	Number of bathrooms	М		
E	Type of fixtures	L		all of sizing literature focus on high flow
F	Age of the plumbing fixtures	L		
G	Number of washing machines	М		
н	Location of washing machines (in apartments, shared)	н	4	
Ι	Time of day the peak uses occur	L		
J	Duration of the peak periods	Н	2	
К	Gallons per person per day	Н	3	if available
L	Type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	м		
	If circulation, the method of			
М	balancing the riser	М		
Ν	Hot water piping material	L		
0	Length of the hot water piping	М		
Р	Diameter and volume of the hot water distribution network	М		
	Configuration of the hot water			
Q	distribution network	М		
R	Insulation on the hot water piping	М		
S	Installation considerations (Building Height, space outdoors)	М		
	Other			
	Other			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
	LMH (Low, Medium, High) Rank Explanation				
А	ASHRAE	н	3	useful to check as a reference because familiarity and availability	
В	ASPE	M			
С	IPC	L			
D	IAPMO/ UPC (Uniform Plumbing Code)	L			
Е	Manufacturer's method	Н	1		
F	EHPWH Tool	М		useful as a reference	
G	Measured data from the site or from a similar occupancy	Н	2	if available	
	Other method				
	Other method				

	e are some features that may are important? Please rank o			r heater. Are there any other features
unau		LMH (Low,		
		Medium, High)	Rank	Explanation
А	Water heater efficiency	H	3	in initial sizing
B	Cost	Н	2	especially for heat pumps
-	Location where the water			
С	heater will be installed	н	5	L for gas, H heat pumps
	Incoming cold-water			
D	temperature	L		
Е	Hot water temperature	L		standard
	Master mixing valve			
F	temperature	L		
G	First hour rating	L		
Н	Recovery efficiency	Н	4	
				heat rate and size can be inversely
I	Heat rate	н	1	proportional
	Location where the			
	storage tank(s) will be			
J	installed	М		
	Volume of storage (one			
	large tank or a number of			
	smaller ones. ASME			
Κ	tanks?)	L		
	Size of storage tanks			
	(volume, dimensions,			
L	ASME tanks?)	Н	1	
	Heat losses of the			
М	circulation loop	М		
Ν	Brand	Н	1	
	Is water heater sizing			
	adjusted based on the			
	presence of preheat			
0	sources (Solar, etc.)	L		
	Gallons per hour (recovery			
Ρ	rate)	Н	1	related to capacity
	Others			

,00			-	
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	Н	3	
	Provide space for additional			
В	storage tanks	Н	2	
	Install larger storage as part			
С	of initial design	L		
	Install additional storage			
D	tanks as part of initial design	L		
	Install heater with larger			the easiest and cheapest.
	heating capacity as part of			Not a lot of infrastructure
Е	initial design	Н	1	changes
	Provide additional capacity			
	in the gas line or in the			
F	electrical panel	М		
	Conversion to Heat pump	Н	2	region specific
	Others			

	re are some key components needed	-		
any	v additional components? Please ran	LMH (Low,		
		Medium, High)	Rank	Explanation
				accessible information from ASHRAE and anecdotal sources regarding per person
А	Number of occupants	н	1	consumption
В	Number of apartments	H	5	
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	L		
D	Number of bathrooms	М		
				all of sizing literature
Е	Type of fixtures	L		focus on high flow
F	Age of the plumbing fixtures	L		<u>_</u>
G	Number of washing machines	М		
	Location of washing machines (in			
н	apartments, shared)	Н	4	
Ι	Time of day the peak uses occur	L		
J	Duration of the peak periods	Н	2	
Κ	Gallons per person per day	Н	3	if available
L	Type of temperature maintenance system (do you prefer circulation, heat trace, etc.)	М		
	If circulation, the method of			
М	balancing the riser	М		
Ν	Hot water piping material	L		
0	Length of the hot water piping	М		
Ρ	Diameter and volume of the hot water distribution network	М		
Q	Configuration of the hot water distribution network	М		
R	Insulation on the hot water piping	M	1	
S	Installation considerations (Building Height, space outdoors) Other	М		
	Other			

Her	Here are some resources used to size water heating systems. Are there any other					
res	resources that you use? Please rank order the top five. Please explain your rankings.					
	LMH (Low, Medium, High) Rank explanation					
А	ASHRAE	н	3	useful to check as a reference because familiarity and availability		
В	ASPE	M	5			
C	IPC	L				
D	IAPMO/ UPC (Uniform Plumbing Code)	L				
Е	Manufacturer's method	Н	1			
F	EHPWH Tool	М		useful as a reference		
G	Measured data from the site or from a similar occupancy	н	2	if available		
	Other method					
	Other method					

	t are important. Please rank orde		ase exp	
		LMH (Low,	Davida	Fundamentian
		Medium, High)	Rank	Explanation
A	Water heater efficiency	Н	3	in initial sizing
В	Cost	Н	2	especially for heat pumps
	Location where the water			
С	heater will be installed	Н	5	L for gas, H heat pumps
	Incoming cold-water			
D	temperature	L		
Е	Hot water temperature	L		standard
	Master mixing valve			
F	temperature	L		
G	First hour rating	L		
Н	Recovery efficiency	Н	4	
				heat rate and size can be
I	Heat rate	н	1	inversely proportional
	Location where the storage			
J	tank(s) will be installed	М		
	Volume of storage (one large			
	tank or a number of smaller			
Κ	ones. ASME tanks?)	L		
	Size of storage tanks (volume,			
L	dimensions, ASME tanks?)	н	1	
	Heat losses of the circulation	-	-	
м	loop	м		
N	Brand	H	1	
	Is water heater sizing	-	-	
	adjusted based on the			
	presence of preheat sources			
0	(Solar, etc.)			
-	Gallons per hour (recovery			
Ρ	rate)	н	1	related to capacity
			· ·	
	Others			

,00				
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	Н	3	
	Provide space for additional			
В	storage tanks	Н	2	
	Install larger storage as part			
С	of initial design	L		
	Install additional storage			
D	tanks as part of initial design	L		
	Install heater with larger			the easiest and cheapest.
	heating capacity as part of			Not a lot of infrastructure
Е	initial design	Н	1	changes
	Provide additional capacity			
	in the gas line or in the			
F	electrical panel	М		
	Others	Н	2	region specific
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

Tarik	lings.	LMH (Low,		
		Medium, High)	Rank	Explanation
A	Number of occupants	H	1	
B	Number of apartments	H	2	
			2	not commonly
	Demographics of the occupancy			discussed, but
С	(senior, affordable, families, etc.)	н	3	necessary
D	Number of bathrooms	M	5	necessary
		1*1		types of fixtures=
				number of water
Е	Type of fixtures	н	1	closets, showers,
F		M	I	
г G	Age of the plumbing fixtures Number of washing machines	M M		
u u		I*I		
н	Location of washing machines (in	L		
	apartments, shared)			
	Time of day the peak uses occur	L		
J	Duration of the peak periods	M		
К	Gallons per person per day	M		
	Type of temperature			
	maintenance system (do you			
	prefer circulation, heat trace,			
L	etc.)	L		
	If circulation, the method of			
M	balancing the riser	L		
N	Hot water piping material	M		
0	Length of the hot water piping	М		
	Diameter and volume of the hot			
Р	water distribution network	М		
	Configuration of the hot water			
Q	distribution network	М		
				design consideration,
R	Insulation on the hot water piping	L		but not sizing
	Installation considerations			design consideration,
S	(Building Height, space outdoors)	L		but not sizing
	Other			
	Other			

Question 4

Her	Here are some resources used to size water heating systems. Are there any other					
reso	resources that you use? Please rank order the top five. Please explain your rankings.					
LMH (Low, Number						
		Medium, High)	Rank	Explanation		
А	ASHRAE	Н	1	a lot of resources in this case		
В	ASPE	М				
С	IPC	Н	2			
D	IAPMO/ UPC (Uniform					
	Plumbing Code)	Н	3			
Е	Manufacturer's					
	method	L				
F	EHPWH Tool	М				
	Measured data from					
G	the site or from a					
	similar occupancy	L		ideal if available		
	Other method					
	Other method					

	Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.					
		LMH (Low,				
		Medium, High)	Rank	Explanation		
А	Water heater efficiency	M				
В	Cost	М				
	Location where the water heater					
С	will be installed	Н	5			
	Incoming cold-water					
D	temperature	L				
Е	Hot water temperature	L				
F	Master mixing valve temperature	L				
G	First hour rating	Н	2			
Н	Recovery efficiency	Н	4			
Ι	Heat rate	Н	3			
	Location where the storage					
J	tank(s) will be installed	М				
	Volume of storage (one large					
	tank or a number of smaller ones.					
Κ	ASME tanks?)	М				
	Size of storage tanks (volume,					
L	dimensions, ASME tanks?)	М				
	Heat losses of the circulation					
М	loop	L				
Ν	Brand	L				
	Is water heater sizing adjusted					
	based on the presence of					
0	preheat sources (Solar, etc.)	L				
				the one that is biggest		
				difference between gas and HP system. Factor to		
Р	Gallons per hour (recovery rate)	н	1	adjust		
	Others		I			
	Othera					

		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	М		
	Provide space for additional storage			easiest, cheapest
В	tanks	Н	1	to plan for
	Install larger storage as part of initial			
С	design	L		
	Install additional storage tanks as			
D	part of initial design	L		
	Install heater with larger heating			
Е	capacity as part of initial design	М		
	Provide additional capacity in the			
F	gas line or in the electrical panel	М		
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

- Tarr	kings.	LMH (Low,		
		Medium, High)	Rank	Explanation
A	Number of occupants	H	1	
В	Number of apartments	L	1	
	Demographics of the			
	occupancy (senior, affordable,			
С	families, etc.)	н		
D	Number of bathrooms	L		
Е	Type of fixtures	М		
F	Age of the plumbing fixtures	L		
G	Number of washing machines	М		
	Location of washing machines			
н	(in apartments, shared)	М		
	Time of day the peak uses			
I	occur	L		
J	Duration of the peak periods	Н		
				number of occupants
Κ	Gallons per person per day	Н	2	gppd leads to demand
				circulation is most
				common, if not
	Type of temperature			important to distinguish.
	maintenance system (do you			Code requirements for
	prefer circulation, heat trace,		4	temperature
L	etc.)	Н	4	maintenance in NY
м	If circulation, the method of	NA		
M N	balancing the riser	M L		
0	Hot water piping material Length of the hot water piping	M L		
0	Length of the not water piping	IVI		best way to account for
				heat loss from
				distribution network.
	Diameter and volume of the hot			Nonconsumption load
Р	water distribution network	н	5	used by the central plant
-	Configuration of the hot water			
Q	distribution network	н		
È	Insulation on the hot water			
R	piping	н		

s	Installation considerations (Building Height, space outdoors)	н		
	Collected data from an existing building	Н	3	actual collected data gives you the duration of the peak, retrofit
	Other			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.					
	· · ·	LMH (Low,				
		Medium, High)	Rank	Explanation		
А	ASHRAE	Н	3	caveat that some inconsistencies in ASHRAE		
В	ASPE	L		do not use		
С	IPC	L		do not use		
D	IAPMO/ UPC (Uniform					
	Plumbing Code)	L		do not use		
Е	Manufacturer's method	М				
F	EHPWH Tool			like ASHRAE, but easier to point to		
Г	EHF WH 1001	Н	2	and more defensible		
	Measured data from the					
G	site or from a similar			Best way to gather the true load		
	occupancy	Н	1	profile		
	Utility Bills	Н	4	cross check measured data		

Question 4

Other method

				r heater. Are there any other features
that	are important. Please rank orc	LMH (Low,	lease ex	kplain your rankings.
		Medium, High)	Rank	ovalenation
A	Water heater efficiency	Hedium, High)	4 Rank	explanation
B	,	М	4	
В	Cost	IVI		
~	Location where the water			
С	heater will be installed	H		
				L in the case of site condition, H in
_	Incoming cold-water			the case of what the heater can
D	temperature	L		handle
				market cares about legionella,
Е	Hot water temperature	Н	3	health/safety concerns
				less important that hot water temp.
	Master mixing valve			hot water temp ensures MMV is
F	temperature	L		met
G	First hour rating	М		
Н	Recovery efficiency	М		
I	Heat rate	Н	1	need to meet load demand
	Location where the storage			
J	tank(s) will be installed	L		
	Volume of storage (one			
	large tank or a number of			
К	smaller ones. ASME tanks?)	L		
	Size of storage tanks			dimensions of whole system due to
	(volume, dimensions, ASME			limited space in doorways,
L	tanks?)	н	2	buildings, etc.
_	Heat losses of the			
м	circulation loop	L		
				Special consideration to previous
Ν	Brand	н	5	experience and brand reputation
	Is water heater sizing		Ŭ	
	adjusted based on the			
	presence of preheat			
0	sources (Solar, etc.)	н		
0	Gallons per hour (recovery	11		
Р	rate)	L		
<u>۲</u>	-	L		
1	Others			

,		/.	T	
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	Н	2	
				due to square footage
	Provide space for additional			limitation in NY, a huge
В	storage tanks	Н	1	commodity
	Install larger storage as part of			
С	initial design	L		
	Install additional storage tanks			
D	as part of initial design	L		
	Install heater with larger			
	heating capacity as part of			
Е	initial design	L		
	Provide additional capacity in			
	the gas line or in the electrical			
F	panel	Н	3	
				doorways and square
	Space and Structure	Н	1	footage.
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

-	kings.	LMH (Low,		
		Medium, High)	Rank	Explanation
				this is the primary
				driver of hot water
Α	Number of occupants	Н	1	demand
_				surrogate for number
В	Number of apartments	H	1	of occupants
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	M		
D	Number of bathrooms	H	2	related to demand
Е	Type of fixtures	M		
F	Age of the plumbing fixtures	L		
				high usage of hot
G	Number of washing machines	Н	4	water
	Location of washing machines (in			
Н	apartments, shared)	M		
	Time of day the peak uses occur	М		
J	Duration of the peak periods	Н	5	demand
Κ	Gallons per person per day	Н	3	
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	н		
	If circulation, the method of			
М	balancing the riser	М		
Ν	Hot water piping material	L		
0	Length of the hot water piping	М		
	Diameter and volume of the hot			
Ρ	water distribution network	М		
	Configuration of the hot water			
Q	distribution network	М		
R	Insulation on the hot water piping	М		
	Installation considerations			
S	(Building Height, space outdoors)	М		
	Other			
	Other			

	Here are some resources used to size water heating systems. Are there any other						
res	resources that you use? Please rank order the top five. Please explain your rankings.						
		LMH (Low,	Number				
		Medium, High)	Rank	explanation			
А	ASHRAE						
В	ASPE						
С	IPC						
D	IAPMO/ UPC (Uniform						
	Plumbing Code)						
Е	Manufacturer's method						
F	EHPWH Tool						
	Measured data from the						
G	site or from a similar						
	occupancy						
	Utility Bills						
	Other method						

				er heater. Are there any other features
tha	at are important. Please rank o	LMH (Low,	lease e	xplain your rankings.
		Medium, High)	Rank	Explanation
				overall lifecycle cost, for people
А	Water heater efficiency	н	4	motivated by carbon/sustainability
В	Cost	Н	3	
	Location where the water			can be major limiting case, making it
С	heater will be installed	Н	1	a fundamental design consideration
	Incoming cold-water			
D	temperature	М		
Е	Hot water temperature	М		
	Master mixing valve			
F	temperature	М		
				mostly single family, not as much for
G	First hour rating	L		MF
Н	Recovery efficiency	Н		
Ι	Heat rate	Н	2	must meet requirements
	Location where the storage			
J	tank(s) will be installed	Н		
	Volume of storage (one			
	large tank or a number of			can be major limiting case, making it
Κ	smaller ones. ASME tanks?)	Н	1	a fundamental design case
	Size of storage tanks			
	(volume, dimensions, ASME			can be major limiting case, making it
L	tanks?)	Н	1	a fundamental design consideration
	Heat losses of the			
M	circulation loop			
Ν	Brand Is water heater sizing	L		
	adjusted based on the			
	presence of preheat			
0	sources (Solar, etc.)	н	5	if available, big impact on sizing.
	Gallons per hour (recovery			
Р	rate)	н	2	FHR for MF, also speaks to delivery
	Warranties (how anode			,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
	rods)	М		
	,	1	1	

'				
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	М		
	Provide space for additional			
В	storage tanks	М		
	Install larger storage as part of			larger storage, standby
С	initial design	Н	2	losses would be greater
	Install additional storage tanks as			
D	part of initial design	М		
	Install heater with larger heating			oversizing, won't require
Е	capacity as part of initial design	Н	1	more space
	Provide additional capacity in			
	the gas line or in the electrical			as an insurance policy
F	panel	Н	3	would be low cost
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

ra	nkings.			1
		LMH (Low,		
		Medium, High)	Rank	Explanation
				key information on
А	Number of occupants	Н	1	demand
В	Number of apartments	Н	4	
	Demographics of the occupancy			
С	(senior, affordable, families, etc.)	Н	4	
D	Number of bathrooms	Н		
				water efficiency of the
Е	Type of fixtures	Н	5	fixtures
F	Age of the plumbing fixtures	Н		
G	Number of washing machines	М		
	Location of washing machines (in			
Н	apartments, shared)	М		
				important for recovery
1	Time of day the peak uses occur	н	3	time
J	Duration of the peak periods	Н	2	
				a result of the prior
				information, key
К	Gallons per person per day	н	1	information on demand
	Type of temperature maintenance			
	system (do you prefer circulation,			
L	heat trace, etc.)	L		
	If circulation, the method of	_		
м	balancing the riser	L		
N	Hot water piping material	L		
0	Length of the hot water piping			
-	Diameter and volume of the hot			
Р	water distribution network	м		
H	Configuration of the hot water	1*1		
Q	distribution network	1		
R	Insulation on the hot water piping			
Λ	Installation considerations	L		
s	(Building Height, space outdoors)	L		
3		L		
	Other			
	Other			

Hei	Here are some resources used to size water heating systems. Are there any other					
res	resources that you use? Please rank order the top five. Please explain your rankings.					
	LMH (Low,					
		Medium, High)	Rank	Explanation		
Α	ASHRAE			less accurate then EHPWH		
A	ASHRAE	Н	2	Tool		
В	ASPE	Н	3			
С	IPC	L				
D	IAPMO/ UPC (Uniform					
	Plumbing Code)	L				
				not because of trust but		
Е	Manufacturer's method			need Manufacturer approval		
		Н	1	and buy off		
F	EHPWH Tool			well-developed tool, more		
1		Н	1	updated ASHRAE values		
	Measured data from the					
G	site or from a similar					
	occupancy	Н	1			
	Utility Bills					
	Other method					

	e are some features that may			
rea	tures that are important. Pleas	LMH (Low,	top five.	Please explain your rankings.
		Medium, High)	Rank	Explanation
^	Water bester officiency	Hedium, High)	2 Rank	
A B	Water heater efficiency Cost	H	3	
Б	Location where the water		3	
С	heater will be installed	м		
C		Ivi		almost no limitations on sizing
D	Incoming cold-water	н	5	almost no limitations on sizing
	temperature	H		systems
Е	Hot water temperature	п	4	
-	Master mixing valve			
F	temperature	L		
G	First hour rating	M		
Η.	Recovery efficiency	M		
Ι	Heat rate	М		
	Location where the storage			
J	tank(s) will be installed	М		
	Volume of storage (one			
	large tank or a number of			
Κ	smaller ones. ASME tanks?)	М		
	Size of storage tanks			
	(volume, dimensions, ASME			
L	tanks?)	Н	1	energy storage
	Heat losses of the			
М	circulation loop	L		
Ν	Brand	L		
	Is water heater sizing			
	adjusted based on the			
	presence of preheat			
0	sources (Solar, etc.)	М		
	Gallons per hour (recovery			
Ρ	rate)	Н	1	
	Refrigeration type	М		

/		LMH (Low,	Number	
		Medium, High)	Rank	Explanation
	Provide space for additional water			
А	heaters	Н	3	
	Provide space for additional			
В	storage tanks	Н	2	
С	Install larger storage as part of initial design	Н	1	lf gas system, easily switch out hot water generator. Cap the gas system and switch with electric water heater
	Install additional storage tanks as			
D	part of initial design	Н	1	
E	Install heater with larger heating capacity as part of initial design	Н	4	
F	Provide additional capacity in the gas line or in the electrical panel	Н	1	more electrical
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

ran	kings.			
		LMH (Low,		
		Medium, High)	Rank	explanation
				Above apartments, In L-income
				there may be much Her
				occupancy than typically
				assumed due to multi-
А	Number of occupants	н	3	generational living situations.
В	Number of apartments	М		
	Demographics of the			
	occupancy (senior,			
С	affordable, families, etc.)	М		
D	Number of bathrooms	М		
				When considering building with existing fixtures that were last
				installed in the 90s compared to
				new fixtures, this would be an H
				consideration. AEA typically does not consider but this is important
Е	Type of fixtures	н	2	in the "real world"
	Type of fixtures Age of the plumbing		2	
F	fixtures			
Г		L		Two is ally all a with a control
	Number of washing	NA		Typically deals with central
G	machines	M		washing systems, L income
	Location of washing			
	machines (in			
Н	apartments, shared)	L		
	Time of day the peak			
	uses occur	M		
Ι.	Duration of the peak			
J	periods	M		
				Based on the type of building,
				load shapes are consistent
				across this building type. So, he
				can consider the overall
				consumption assuming the same
	Gallons per person per			load shape. Considers
Κ	day	H	1	demographic.

	Type of temperature			
	maintenance system			
	(do you prefer			
	circulation, heat trace,			
L	etc.)	М		
	If circulation, the			Typically, all risers are located
	method of balancing			next to each other. supply,
М	the riser	Н		return, etc.
	Hot water piping			
Ν	material	L		
	Length of the hot water			
0	piping	М		
	Diameter and volume of			
	the hot water			
Р	distribution network	М		
				Network could be tight or
				sprawling. Architect does not
				typically consider this and
	Configuration of the hot			locates central system that is
	water distribution			convenient for design but not
Q	network	Н	4	optimal for distribution.
				Addressed in existing buildings
				to bring load down for electric
	Insulation on the hot			replacements. Huge issue for
R	water piping	Н	5	existing
	Installation			
	considerations (Building			
S	Height, space outdoors)	М		
	Other			
	Other			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
1630					
		Medium, High)	Rank	explanation	
А	ASHRAE	Н	1	Used by Company A Tool, so equally important	
В	ASPE			Used for smaller systems,	
	_	Н	2	using fixture counts.	
С	IPC	L			
D	IAPMO/ UPC (Uniform Plumbing Code)	L			
E	Manufacturer's method	М	4	Sometimes used based on manufacturer	
F	EHPWH Tool	Н	1	Work directly with Company A, i.e. Company A project. But they have considered if this tool is oversized. All comparing storage and recovery, which are important.	
	Measured data from the				
G	site or from a similar			Very effective way to meet	
	occupancy	Н	3	demand for similar sites.	
	Utility Bills				
	Other method				

•					
Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.					
tha	t are important. Please i		o five. Ple	ease explain your rankings.	
		LMH (Low,			
		Medium, High)	Rank	explanation	
				The variations in efficiency between	
				different HPWH is typically not an	
				important factor when replacing gas	
				equipment. Typically plant efficiency is	
				considered independent of individual	
				HPWH efficiency. Efficiency can be	
				important to consider in colder	
	Water heater			environments, i.e. CO2 vs Model A heat	
Α	efficiency	Н	4	pumps, to meet loads at Ler temps.	
				May have a few viable options, but	
			_	significant cost difference will favor least	
В	Cost	Н	3	expensive.	
	Location where the				
_	water heater will be			very different forms factors for HPWH	
С	installed	Н	1	systems.	
	Incoming cold-water				
D	temperature	L			
	Hot water				
Е	temperature	L			
	Master mixing valve				
F	temperature	L			
G	First hour rating	L			
Н	Recovery efficiency	М			
				Must meet the sizing demand. Look at	
Ι	Heat rate	Н	2	capacity and space to determine design.	
	Location where the				
	storage tank(s) will				
J	be installed	M			
	Volume of storage				
	(one large tank or a				
	number of smaller			Tradeoffs between storage and recovery.	
Κ	ones. ASME tanks?)	М	5	Designer can opt for either to meet load.	
	Size of storage tanks				
	(volume, dimensions,				
L	ASME tanks?)	М			
	Heat losses of the				
М	circulation loop	L			
Ν	Brand	M			

	Is water heater sizing adjusted based on the presence of preheat sources		
0	(Solar, etc.)	L	
	Gallons per hour		
Р	(recovery rate)	М	
	Others		

yo	ur rankings.			
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for			
А	additional water heaters	М	5	
	Provide space for			
В	additional storage tanks	М	4	Not seen
				Can benefit project to all for load
	Install larger storage as			shifting without need for
С	part of initial design	Н	1	increased demand.
	Install additional storage			
	tanks as part of initial			
D	design	Н	2	Same as (c)
				If load shifting, you need to
				recover storage in smaller
				timeframe. So, it can be
				beneficial without the need for
				Her load. There are more heat
	Install heater with larger			pumps installed instead of larger
	heating capacity as part			heat pumps for redundancy and
Е	of initial design	Н	3	prevent downtime.
	Provide additional			
	capacity in the gas line			
F	or in the electrical panel	L		
	Others			
	Others			

	e are some key components neede			
any	additional components? Please rar	LMH (Low,	ive. Plea	se explain your rankings.
		Medium, High)	Rank	explanation
Α	Number of occupants	M		
				driver for how much
В	Number of apartments	Н	2	water is needed
	Demographics of the occupancy			demographics speak to
С	(senior, affordable, families, etc.)	Н	3	peak period/ time
				#1 because usually the
				amount of water/ flow
D	Number of bathrooms	Н	1	needed
				don't apply in new
Е	Type of fixtures	L		construction,
F	Age of the plumbing fixtures	L		
G	Number of washing machines	Н	4	
	Location of washing machines (in			
Н	apartments, shared)	Н	5	
I	Time of day the peak uses occur	М		
J	Duration of the peak periods	М		
К	Gallons per person per day	М		
	Type of temperature			
	maintenance system (do you			
	prefer circulation, heat trace,			
L	etc.)	М		
	If circulation, the method of			
М	balancing the riser	H		
Ν	Hot water piping material	М		
0	Length of the hot water piping	H		
	Diameter and volume of the hot			
Р	water distribution network	L		
	Configuration of the hot water			
Q	distribution network	М		
	Insulation on the hot water			
R	piping	L		NA in new construction
	Installation considerations			
S	(Building Height, space outdoors)	L		
	Other			
	Other			

	Here are some resources used to size water heating systems. Are there any other resources that you use? Please rank order the top five. Please explain your rankings.				
		LMH (Low,			
		Medium, High)	Rank	explanation	
А	ASHRAE	L			
В	ASPE	L			
С	IPC	М			
D	IAPMO/ UPC (Uniform Plumbing			more of sizing pipes	
	Code)	Н	2	than system sizing	
Е	Manufacturer's method	Н	1	sizing systems globally	
F	EHPWH Tool	L			
G	Measured data from the site or				
G	from a similar occupancy	Н	3	if avail	
	Utility Bills	Н	4		
	Other method				

	e are some features that may sures that are important. Pleas			•
icut		LMH (Low,		
		Medium, High)	Rank	explanation
A	Water heater efficiency	M	I COLIN	
~	Water neater emclency	1*1		the biggest driver in new
В	Cost	н	2	construction
D	Location where the water		2	
С	heater will be installed	н	4	
C		П	4	
П	Incoming cold-water	н	5	
D	temperature	н М	5	
E	Hot water temperature	IM		
-	Master mixing valve			
F	temperature	M		
G	First hour rating	M		individual water heaters
Η	Recovery efficiency	Н		
I	Heat rate	м		new construction allowing for more flexibility
	Location where the			
	storage tank(s) will be			
J	installed	М		
	Volume of storage (one			
	large tank or a number of			
	smaller ones. ASME			
K	tanks?)	М		
	Size of storage tanks			
	(volume, dimensions,			
L	ASME tanks?)	н	3	
	Heat losses of the		_	
М	circulation loop	L		
N	Brand	L		
	Is water heater sizing			
	adjusted based on the			
	presence of preheat			
0	sources (Solar, etc.)	м		
0				Determines how much
	Gallons per hour (recovery			storage and would
Р	rate)	н	1	determine sizing
<u> </u>	Others		1	

	LMH (Low,		
	Medium, High)	Rank	Explanation
Provide space for additional			
water heaters	М		
Provide space for additional			
storage tanks	Н	1	expandability
Install larger storage as part			
of initial design	Н	2	
Install additional storage			
tanks as part of initial design	Н	2	
Install heater with larger			
heating capacity as part of			
initial design	М		
Provide additional capacity			
in the gas line or in the			
electrical panel	М		
Others			
Others			
	Provide space for additional water heaters Provide space for additional storage tanks Install larger storage as part of initial design Install additional storage tanks as part of initial design Install heater with larger heating capacity as part of initial design Provide additional capacity in the gas line or in the electrical panel Others	LMH (Low, Medium, High)Provide space for additional water heatersMProvide space for additional storage tanksHInstall larger storage as part of initial designHInstall additional storage tanks as part of initial designHInstall heater with larger heating capacity as part of initial designMProvide additional capacity in the gas line or in the electrical panelM	LMH (Low, Medium, High)RankProvide space for additional water heatersMProvide space for additional storage tanksMInstall larger storage as part of initial designH11Install additional storage tanks as part of initial designH2Install heater with larger heating capacity as part of initial designHProvide additional capacity in the gas line or in the electrical panelMOthersM

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

rai	nkings.			1
		LMH (Low,		
		Medium, High)	Rank	explanation
А	Number of occupants	Н	1	
В	Number of apartments	Н	1	for heat pump systems
	Demographics of the			
	occupancy (senior, affordable,			
С	families, etc.)	М		
D	Number of bathrooms	Н	1	number of fixtures
Е	Type of fixtures	L		
F	Age of the plumbing fixtures	Н	1	flowrate
G	Number of washing machines	L		
	Location of washing machines			
Н	(in apartments, shared)	L		
	Time of day the peak uses			L for combustion, H for
Т	occur	L/H	2	heat pump
				L for combustion, H for
J	Duration of the peak periods	L/H	1	heat pump
Κ	Gallons per person per day	Н	1	heat pumps
	Type of temperature			
	maintenance system (do you			
	prefer circulation, heat trace,			
L	etc.)	L/H	3	L for gas, H for heat pump
	If circulation, the method of			
М	balancing the riser	L		
Ν	Hot water piping material	L		
0	Length of the hot water piping	L		
	Diameter and volume of the hot			
Ρ	water distribution network	L		
	Configuration of the hot water			
Q	distribution network	Н	3	heat pumps
	Insulation on the hot water			very important for
R	piping	Н	2	[customer]
	Installation considerations			
	(Building Height, space			very important for
S	outdoors)	н	2	[customer]
	Other			

Here are some resources used to size water heating systems. Are there any other						
reso	resources that you use? Please rank order the top five. Please explain your rankings.					
		LMH (Low,				
		Medium, High)	Rank	explanation		
				more scientific resources,		
А	ASHRAE			more empirical evidence		
		Н	1	with ASHRAE		
В	ASPE	Н	2			
С	IPC	М				
D	IAPMO/ UPC (Uniform					
	Plumbing Code)	М				
Е	Manufacturar's mathed			a function of the others		
	Manufacturer's method	L		more traditional resources		
				heat pumps, Company A		
F	EHPWH Tool			has most empirical		
		Н	1	evidence		
G	Measured data from the site					
G	or from a similar occupancy	М				
	Utility Bills					
	Other method					

Here are some features that may be used to select a water heater. Are there any other features					
that	are important. Please rank o		. Please	explain your rankings.	
		LMH (Low,	Daula	aun lauration	
		Medium, High)	Rank	explanation	
•	Mater haster officiancy		1	MF buildings, cost of energy is top	
A	Water heater efficiency	Н	1	priority	
В	Cost	H	2		
	Location where the water				
С	heater will be installed	H	2	physical size of tool	
_	Incoming cold-water				
D	temperature	L			
Е	Hot water temperature	L			
	Master mixing valve				
F	temperature	L			
G	First hour rating	Н		storage water heater	
Н	Recovery efficiency	Н		storage water heater	
				how to balance capacity and storage	
1	Heat rate	Н	4	capability	
	Location where the				
	storage tank(s) will be				
J	installed	L		so long as not freezing	
	Volume of storage (one				
	large tank or a number of				
	smaller ones. ASME				
К	tanks?)	L			
	Size of storage tanks				
	(volume, dimensions,				
L	ASME tanks?)	Н	3		
	Heat losses of the				
М	circulation loop	L		H for heat pumps	
Ν	Brand	Н			
	Is water heater sizing				
	adjusted based on the				
	presence of preheat				
0	sources (Solar, etc.)	L			
	Gallons per hour				
Р	(recovery rate)	н	5	def for heat pumps	
	Others				
	1		1		

you	ii Tarikii igo.			
		LMH (Low,		
		Medium, High)	Rank	Explanation
	Provide space for			
А	additional water heaters	М		
	Provide space for			
В	additional storage tanks	Н	1	heat pumps
	Install larger storage as			
С	part of initial design	Н	1	
	Install additional			
	storage tanks as part of			
D	initial design	М		
	Install heater with larger			
	heating capacity as part			
Е	of initial design	М	2	
	Provide additional			
	capacity in the gas line			
F	or in the electrical panel	Н	2,5	heat pumps 2, gas 5
	Others			
	Others			

Question 3

Here are some key components needed for the sizing of a water heating system. Are there any additional components? Please rank order the top five. Please explain your rankings.

ra	nkings.			
		LMH (Low,		
		Medium, High)	Rank	explanation
				First thing to consider when
А	Number of occupants	Н	1	using sizing tool.
				Related to number of
В	Number of apartments	М		occupants.
	Demographics of the			
	occupancy (senior,			Related to number of
С	affordable, families, etc.)	М		occupants.
				Next thing to consider when
D	Number of bathrooms	Н	2	using sizing tool.
				Next thing to consider when
Е	Type of fixtures	Н	3	using sizing tool.
F	Age of the plumbing fixtures	L		
				Next thing to consider when
G	Number of washing machines	Н	4	using sizing tool.
	Location of washing			
	machines (in apartments,			
Н	shared)	L		
	Time of day the peak uses			
Ι	occur	L		
J	Duration of the peak periods	L		
Κ	Gallons per person per day	М		Result from using sizing tools.
				need to install fL meter on
				return to properly manage
				circulation. Temperature
				maintenance is not preferred
				for constant pumps without
				knowing fL. Even systems with
	Type of temperature			variable fL options are
	maintenance system (do you			typically bypassed since it is
	prefer circulation, heat trace,			hard to properly manage fL
L	etc.)	L		and temperature.
	If circulation, the method of			Last thing to consider in sizing
Μ	balancing the riser	Н	5	tool.
Ν	Hot water piping material	L		
	Length of the hot water			
0	piping	L		

P	Diameter and volume of the hot water distribution network	L	
	Configuration of the hot		
Q	water distribution network	L	
R	Insulation on the hot water piping	М	Depends if insulation on the entire system or just exposed piping. Oversized systems typically cover poor insulation anyways, so this is not considered.
	Installation considerations		
	(Building Height, space		
S	outdoors)	М	Same as previous (r)
	Other		
	Other		

He	Here are some resources used to size water heating systems. Are there any other					
res	resources that you use? Please rank order the top five. Please explain your rankings.					
		LMH (Low,				
		Medium, High)	Rank	explanation		
А	ASHRAE	L		Doesn't use this.		
В	ASPE	L		Doesn't use this.		
С	IPC	L		Doesn't use this.		
D	IAPMO/ UPC (Uniform					
U	Plumbing Code)	L		Doesn't use this.		
Е	Manufacturer's method			[Company B, Company C]		
L		Н	3	(direct fired)		
				used for heat pumps.		
F	EHPWH Tool			Recently used the most		
l'				due to increased HPWH		
		Н	1	installs.		
				Backup method. Based on		
G	Measured data from the site			experience you can backup		
	or from a similar occupancy			final design. Cannot size a		
		М	4	site since they are unique.		
	Utility Bills					
	Other method					

Here are some features that may be used to select a water heater. Are there any other features that are important. Please rank order the top five. Please explain your rankings.				
		LMH (Low,		
		Medium, High)	Rank	explanation
	Water heater		-	
А	efficiency	М		
	,			Cost depends on location. Again, the cost
				for larger water heaters is usually not that
				much for the same models. The location
				may increase/decrease costs for
				installation or retrofitting depending on
В	Cost	Н	4	available space, indoor/outdoor.
	Location where the			
	water heater will be			Location affects the type of water heaters
С	installed	Н	3	and affects the cost as mentioned above.
				More important for heat pumps in colder
				environments. typical constant 63.8F cold
	Incoming cold-water			water in found across CA so this is not
D	temperature	L		considered when selecting.
				These days, there is no need to supply
				greater than 120F unless there is a bad
	Hot water			circulation system or bad crossover. Most
Е	temperature	L		water heaters can be easily adjusted to Her temps, so this not important.
	Master mixing valve	L		The temps, so this not important.
F	temperature	1		Same reasoning as response for (E)
G	First hour rating	L		Sizing tools already do this
H	Recovery efficiency			Sizing tools already do this
		_		Essential to sizing. Primary consideration
1	Heat rate	н	1	when selecting.
	Location where the			Storage should be as close as possible to
	storage tank(s) will be			the water heater to avoid losses. But this
J	installed	М	5	is not as important as other factors.
	Volume of storage			
	(one large tank or a			
	number of smaller			
Κ	ones. ASME tanks?)	L		
				interrelated with capacity. Designer can
	Size of storage tanks			consider Ler capacity heater with more
	(volume, dimensions,			storage, or vice versa to meet demand for
L	ASME tanks?)	H	2	storage water heating systems.
	Heat losses of the			
М	circulation loop	L		

Ν	Brand	L	Depends on business relationships.
0	Is water heater sizing adjusted based on the presence of preheat sources (Solar, etc.)	L	Water heater sizing is done considering these additional heat sources are not always available. So, these are considered redundancies.
Р	Gallons per hour (recovery rate)	L	
	Others		

Duravida anaga far	LMH (Low, Medium, High)		
Dravida anaca far		Rank	Explanation
	Mediani, mgny	Kank	This is important especially for
Provide space for additional water heaters	Н	2	indoor/enclosed installations.
additional water heaters	H	2	Equally important as additional space for water heaters. Depends on how much more demand to meet. If there is only a small increase demand that can be met from increasing from 40–50gallon to 70–80 gallons then water heater storage will only increase in height. But larger demands will require much more space. Designer can choose more water heaters or
Provide space for			increased storage to meet demand,
additional storage tanks	Н	3	so it depends on the designer.
Install larger storage as part of initial design	L		
Install additional storage tanks as part of initial design	L		
Install heater with larger heating capacity as part of initial design	L	5	Last resort unless you know the future demand to reduce costs.
Provide additional capacity in the gas line or in the electrical panel	Н	1	most expensive retrofit.
ensure proper ventilation for combustible water heaters	М	4	This is something to consider for indoor installations.
	additional storage tanks Install larger storage as part of initial design Install additional storage tanks as part of initial design Install heater with larger heating capacity as part of initial design Provide additional capacity in the gas line or in the electrical panel ensure proper ventilation for combustible water	additional storage tanksHInstall larger storage as part of initial designLInstall additional storage tanks as part of initial designLInstall heater with larger heating capacity as part of initial designLProvide additional capacity in the gas line or in the electrical panelHensure proper ventilation for combustible water heatersM	additional storage tanksH3Install larger storage as part of initial designLInstall additional storage tanks as part of initial designLInstall heater with larger heating capacity as part of initial designLProvide additional capacity in the gas line or in the electrical panelH1ensure proper ventilation for combustible water heatersM4

	Here are some key components needed for the sizing of a water heating system. Are there					
any	additional components? Please		p five. H	lease explain your rankings.		
		LMH (Low,	Rank	ovaluation		
A	Number of occupants	Medium, High)	Ralik	explanation		
B	Number of apartments	H	2	determine demand		
D	Demographics of the	11	2			
	occupancy (senior, affordable,					
С	families, etc.)	М				
-				overall peak capacity and		
				load (specifically # of		
D	Number of bathrooms	н	1	showers)		
Е	Type of fixtures	L				
F	Age of the plumbing fixtures	L				
				determining peak demand/		
G	Number of washing machines	Н	3	load		
	Location of washing machines					
Н	(in apartments, shared)	Н	4			
	Time of day the peak uses					
I.	occur	М				
J	Duration of the peak periods	L				
К	Gallons per person per day	L				
	Type of temperature					
	maintenance system (do you					
	prefer circulation, heat trace,					
L	etc.)	L				
	If circulation, the method of					
М	balancing the riser	L				
Ν	Hot water piping material	L				
0	Length of the hot water piping	М				
	Diameter and volume of the					
Ρ	hot water distribution network	М				
	Configuration of the hot water					
Q	distribution network	M				
	Insulation on the hot water					
R	piping	L				
	Installation considerations					
6	(Building Height, space					
S	outdoors)	L				
	Other					
	Other					

Here are some resources used to size water heating systems. Are there any other						
resc	resources that you use? Please rank order the top five. Please explain your rankings.					
		LMH (Low,				
		Medium, High)	Rank	explanation		
А	ASHRAE	L				
В	ASPE	L				
С	IPC	L				
D	IAPMO/ UPC (Uniform					
	Plumbing Code)	М				
E	Manufacturer's method			no engineers on staff to ensure proper sizing manufacturers can ensure		
		н	1	proper sizing		
F	EHPWH Tool	L				
G	Measured data from the site					
u	or from a similar occupancy	М				
	Utility Bills					
	Other method					

	re are some features that m	,		,
rea	tures that are important. Ple	LMH (Low,	le top live. Pie	ase explain your rankings.
		Medium, High)	Rank	explanation
A	Water heater efficiency	M	Rank	
	That of Houton officially			customer is paying v
В	Cost	н	1	important
-	Location where the		•	
	water heater will be			
С	installed	L		
-	Incoming cold-water			
D	temperature	L		
E	Hot water temperature	М		
	Master mixing valve			
F	temperature	L		
G	First hour rating	Н	3	ensure proper sizing
Н	Recovery efficiency	М		
	Heat rate	М		
	Location where the			
	storage tank(s) will be			
J	installed	L		
	Volume of storage (one			
	large tank or a number of			
	smaller ones. ASME			
Κ	tanks?)	М		
	Size of storage tanks			
	(volume, dimensions,			
L	ASME tanks?)	М		
	Heat losses of the			
М	circulation loop	М		
				loyalty- will the
				manufacturer stand
Ν	Brand	Н	4	beside a project
	Is water heater sizing			
	adjusted based on the			
_	presence of preheat			
0	sources (Solar, etc.)	L		
_	Gallons per hour			ensure its ability to meet
Ρ	(recovery rate)	Н	2	demand
	Incentives	Н	1	

-	5			
		LMH (Low, Medium, High)	Rank	Explanation
	Provide space for additional			
А	water heaters	Н	2	
	Provide space for additional			
В	storage tanks	Н	4	
	Install larger storage as part of			
С	initial design	Н	3	
	Install additional storage tanks			
D	as part of initial design	L		
	Install heater with larger heating			simplest way to increase
Е	capacity as part of initial design	Н	1	demand
	Provide additional capacity in			
	the gas line or in the electrical			
F	panel	М		
	Others			
	Others			

Appendix 2: Site Specific Sizing Tool Screenshots

Site 1

MFG Tool 2

Input

Apartment Building	Sizing
Complete the equipment settings	and application sizing fields to have Pro-Size calculate the estimated hot "Continue" button to view the recommended A. O. Smith heaters for
Custom Cottings	Switch to SI/Metric units
System Settings	
Equipment:	 Water Heaters Only (no external storage)
	O Water Heaters with external storage if required
	 Commercial Tankless Heaters (no storage)
	O Commercial Tankless Heaters PLUS Storage Tanks
	O Heat Pump Heaters
	O Boilers with external storage tank
Fuel Type:	Natural Gas 🗸
Equipment Location:	Indoor 🗸
Other Requirements:	Low NOx - Requirements of < 40 ng/J or 55 PPM
	Ultra Low NOx - Requirements of < 14 ng/J or 20 PPM
	ASME Approved
Display CDN Products:	141
# of Heaters:	Not Specified (Auto)
Altitude:	Less than 2000 ft 🔹 🗸
Application Data	
Temperatures	
Cold Water Temp:	65 °F
Stored Water Temp:	130 °F
Load Profile	
Building Use:	Medium Peak Demand V More Info
Peak Demand Period:	1 HOURS (Custom? ✓)
Unit Application Loads	
Shower Head Flowrate:	2.5 USGPM
Units with 1 Bath:	72 Persons per unit: 1.5 w/ Clothes Washer
Units with 1-1/2 Baths:	0 Persons per unit: 2 w/ Clothes Washer
Units with 2 Baths:	0 Persons per unit: 2.5 w/ Clothes Washer
Units with 2-1/2 Baths:	0 Persons per unit: 3 Uw/ Clothes Washer
Laundry Room or Coin-Op	Laundry
Include Coin-Operated	Laundry
Model 1 - Quantity:	6 Capacity: 15 LB
Model 2 - Quantity:	0 Capacity: 0 LB
Additional Load and Inten	tional Oversize
Additional Load:	0 USGPH (@ stored temp)
Design Oversize	0% 🗸
Load Summary	
Peak Demand:	911 USGPH Temperature Rise: 65 °F
	Select A. O. Smith Products Now 💿

To view detailed your application	product information, se	lect the recommer	ided heater ti	hat you feel best :	suits
Load Summar	y.				
Peak Demand:	911 USGPH	Tem	perature Rise: 65	. eF	
Recommen	ided Products				
	BTH-500 Mxi Cyclone® Mxi Mod	ulating			Select
1	# Heaters: Heater Storage (ea): Input (ea):	1 119 USG 499,900 Btu/hr		886 USGPH @ 6 969 USGPH 914 USGPH	5 °F Rise
c	New External Tanks: Total Usable Storage:		Est. Storage Recovery: % Of Demand:	8 min 106% (1-hour pe	ak)
	BTHL-500A Cyclone® LV (Larg	e Volume)			Selec
•	# Heaters: Heater Storage (ea): Input (ea):	1	Heater Recovery: 1st Hour Delivery: 3 Hour Average:	857 USGPH @ 65 1,011 USGPH 908 USGPH	5 °F Rise
	New External Tanks: Total Usable Storage:		Est. Storage Recovery: % Of Demand:	15 min 111% (1-hour pr	ak)
261	BTH-250 Mxi Cyclone® Mxi Mod	ulating			Selec
-	# Heaters: Heater Storage (ea): Input (ea):	2	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	895 USGPH @ 6 1,035 USGPH 942 USGPH 13 min	5 °F Rise
C	New External Tanks: Total Usable Storage:		% Of Demand:	114% (1-hour pe	ak)
	BTH-300 Mxi Cyclone® Mxi Mod	ulating			Select
1	# Heaters: Heater Storage (ea): Input (ea):	2		1,074 USGPH @ 1,240 USGPH 1,129 USGPH	65 °F Rise
c	New External Tanks: Total Usable Storage:		Est. Storage Recovery: % Of Demand:	13 min 136% (1-hour pe	ak)

Input				
		SYSTEM	SETTING	5
	To overrie	de a default paramete	r, select fron	the drop down list
	Installation Type		Tempera	ture Units
	Indoor	~	Fahrer	heit (*F) 🗸
	Fuel Type		Incomin	g Water Temperature (*F) 🚺
	Natural Gas	~	65	O
	ASME Required		Stored T	emperature (*F) 🔺
	No	~	140	O
	Immersion Thermostat Required		Altitude	(ft)
	No	~	0	0
	Low NOx Installation 📀			
	No	~		
	WARNING - Water temperature	e over 125°F (52°C) can	cause severe	burns instantly or death from scalds.
	OPTIONAL SETTINGS			
	Number of Water Heaters		Number	of New Storage Tanks
	Not Specified	~		becified V
	Hot specified		1	
		APPLICA	TION DA	ITA
		Enter the red	quirements l	below
	Units with 1 Bath	Shower Heads		w/ In-suite Clothes Washer
	72	2.5 GPM	~	
	Units with 11/2 Bath	Shower Heads		w/ In-suite Clothes Washer
	0	2.5 GPM	~	w in-suce clothes washer
	Units with 2 Bath	Shower Heads		
	0	2.5 GPM	~	w/ In-suite Clothes Washer
	Units with 21/2 Bath	Shower Heads		
	0	2.5 GPM	~	w/ In-suite Clothes Washer
	Units with 3 Bath	Shower Heads		
	0	2.5 GPM	~	w/ In-suite Clothes Washer
	Units with 3½ Bath	Shower Heads		
	0	2.5 GPM	~	w/ In-suite Clothes Washer
	Shower Minutes Per Hour 🥝			
	0			
	Diversity Factor (%) 🥹			
	30 ¥ —O			
	Other GPH (at Stored Temp)			
	0			

	7
ADDITIONAL FA	CILITY LOADS
Select any additional load(s) you want to in	clude that were not accounted for above.
Include Laundry	
Include Food Service/Restaurant	
	Chart Area
WASHING	MACHINES
Enter the number of washing machine	s and capacity for each model below
Washer #1 😫	
Quantity	6
Capacity (lbs)	15
Temperature Required	140 °F 🗸
Add Washer	
The typical mid-size residential washing machine has an range anywhere from 15 pounds up to 50 pounds.	average load capacity of 11 pounds while commercial models

	CONDER	NSING RECOMMENDATION		
	U.H.E® Commercial Wate	er Heater (60-100 Gallon)		
(70)	Heaters Required	1	Heater Model No.	LUHE100T300E3N(A)
87 O (Heater Capacity	100 USG	Input per Hour	300,000 BTU/HR
Address of	Thermal Efficiency	92%	Venting	Power / Power Direct
	Storage Tanks	None	Usable Storage	70 USG
	Recovery	442 USGPH @ 75 *F Rise	Approx. 1st Hour Delivery	512 USG
	Approx: 3 Hour Avg. Delivery	465 USG	Approx. Storage Recovery	14 MINUTES
• •	% of Demand Satisfied	105%	_	
			Se	lect
	CONDE	NSING RECOMMENDATION		
	U.H.E® Commercial Wate	r Hester (120 Gallon)		
	U.H.E® Commercial Wate	er Heater (120 Gallon)	Heater Model No.	LUHE120T4003N(A)
	Heater Capacity	119 USG	Input per Hour	399,999 BTU/HR
1º	Thermal Efficiency	94%	Venting	
	Storage Tanks	None	Usable Storage	Power / Power Direct 83 USG
	Recovery	602 USGPH @ 75 *F Rise	Approx. 1st Hour Delivery	685 USG
10	Approx. 3 Hour Avg. Delivery	630 USG	Approx. Storage Recovery	12 MINUTES
· · · .	% of Demand Satisfied	140%	Approx storage recordly	12 MINUTES
5			Se	lect
	VOLUME WA	TER HEATER RECOMMENDATI	DN	
		#1		
	Mighty Therm®2 Volum	o Water Heaters		
	Heaters Required	1	Heater Model No.	MT2V0300
	Heaters Required		Heater Model No.	No Pump 200-400
111	Heater Capacity	0 USG	Input per Hour	300,000 BTU/HR
1	Thermal Efficiency	85%	Venting	N/A
	Storage Tanks	1 @ 119 USG	Tank Model	A0078800/A0070101
(B)	Usable Storage	95 USG	Recovery	408 USGPH @ 75 *F Rise
	Approx. 1st Hour Delivery	503 USG	Approx. 3 Hour Avg. Delivery	440 USG
	Approx. Storage Recovery	17 MINUTES	% of Demand Satisfied	103%
			s	elect
	VOLUME WA	TER HEATER RECOMMENDATION	DN	
		#2		
	Mighty Therm®2 Volum	e Water Heaters		
	Heaters Required	31	Heater Model No.	MT2V0400 No Pump 200-400
11 Y T.	Heater Capacity	0 USG	Input per Hour	Pump Mounted 200-400 S 399,900 BTU/HR
	Heater Capacity Thermal Efficiency	0 USG 85%	Venting	399,900 BTU/HR N/A
	Storage Tanks	1 @ 80 USG	Tank Model	A0073100/A0073101
				544 USGPH @ 75 *F Rise
	Usable Storage Approx. 1st Hour Delivery	64 USG 608 USG	Recovery Approx. 3 Hour Avg. Delivery	544 USGPH @ 75 'F Rise 565 USG
	Approx. 1st Hour Delivery Approx. Storage Recovery	9 MINUTES	96 of Demand Satisfied	124%
	Approx sonage necessary	5 Milliones		elect
	CONDENSING VOLUN	NE WATER HEATER RECOMMEN	NDATION	
	NeoTherm® Volume Wat	er Heaters		
L Der	Heaters Required	1	Heater Model No.	NTV285
	Heater Capacity	0 USG	Input per Hour	285,000 BTU/HR
	Thermal Efficiency	95%	Venting	N/A
the second second second	Storage Tanks	1 @ 80 USG	Tank Model	A0073100/A0073101
	Usable Storage	64 USG	Recovery	433 USGPH @ 75 *F Rise
THE REAL PROPERTY AND ADDRESS OF ADDRES	Approx. 1st Hour Delivery	497 USG	Approx. 3 Hour Avg. Delivery	455 USG
	Approx. Storage Recovery	11 MINUTES	% of Demand Satisfied	102%
			Se	lect

Input							
Application Type	Apartment/	Multi-f	amily				•
Unit Type	Water Heate	er					•
Storage (gl)	N/A						•
Fuel Type	All						•
Installation Zip Code	90015		Amount	Auto 💌]		
Inlet (°F)	65		Outlet (°F)	130	El	ev. (ft)	D
Load (auto 🔽)	Peak	•	Peak (hr)	2	Re	c . (hr)	1
ASME			Low NOx		Ultra-Lov	w NOx	
Fixtures							—
Click Here To Add	d Fixture 🔻	Qty	Flow (GPH)	Flow (GPM)	Time (min)	Temp (°F)	Edit
Single	Bath Units			2.5	12	105	
1 1/2	Bath Units			3	12	105	
2	Bath Units	72		5	12	105	
Automatic Washin	g Machines		15			120	
Public la	avatory sink		5			105	
Se	ervice Sinks		10			120	

PRODUCTS (DELIVERY REQUIRED: 1419 US GALLONS)

-	Model	GX90-550 NG (★)	Quantity	2
	Input	550000 BTU	Delivery	1767 US Gallons
	Size	90 US Gallons	Recovery	821 US GPH at 65 °F rise
9 - 9	Fuel Type	Gas	Storage Tank	N/A
E.	Efficiency	80%	-	
est Delive	er Model			
	Model	GX90-600N	Quantity	2
1 2 9	Input	600000 BTU	Delivery	1916 US Gallons
	Size	90 US Gallons	Recovery	895 US GPH at 65 °F rise
	Fuel Type	Gas	Storage Tank	N/A
	Efficiency	80%		
	Model	GHE119SS-500	Quantity	2
-0 -	Input	499900 BTU	Delivery	1938 US Gallons
- 0 - 1	Input Size	119 US Gallons	Delivery Recovery	1938 US Gallons 886 US GPH at 65 °F rise
	Size	119 US Gallons	Recovery	886 US GPH at 65 °F rise
	Size Fuel Type	119 US Gallons Gas (High Eff)	Recovery	886 US GPH at 65 °F rise
	Size Fuel Type Efficiency	119 US Gallons Gas (High Eff) 95%	Recovery Storage Tank	886 US GPH at 65 °F rise N/A
	Size Fuel Type Efficiency Model	119 US Gallons Gas (High Eff) 95% GHE119SS-500 LP	Recovery Storage Tank Quantity	886 US GPH at 65 °F rise N/A

EHPWH Tool

Input

				California Specification Mode
TOTAL PEOPLE	& APARTMENTS	APARTMENT SIZE & OCCUPANCY RAT	55	
	Number of Apartments	Occupancy Rate ③ California - RASS Data	Peak Gallons per Day per Person ③ User Defined	 California by Bedroor
Studio	0	1.37	25 1	49
1 Bedroom	0	1.74	25	49
2 Bedroom	72	2.57	1	49 0 49
3 Bedroom	0	3.11	25	49
4 Bedroom	0	4.23	25	49
5 Bedroom	0	3.77	25	49
5 Bedroom	U	3.77		49


Water Temperature

Design Cold	Supply	Hot Storage	
65 °F	130 °F	130 °F	Aquastat Fraction Drawdown
			40 % 85 %

Results

The graph below represents the trade off between storage volume and heating capacity. The method result is the green curve in the graph. The system sized from user inputs is the blue diamond. Users should pick any point above the green curve to determine their system sizing.

Use the slider bar below the plot to select a different size system.



RECOMMENDATIONS

The recommended minimum heating capacity shown below is the **minimum** needed average output capacity of the selected equipment at the design cold air temperature in your climate zone. Note that you must also account for manufacturer specific defrost penalty.

Heating Capacity 🤊

12.6 kW · 43.0 kBTU/hr

Swing Resistance Element 🤊

292.70 kBTU/hr

Tank Volume <a>? **2,389.00** Gallons

Swing Tank Volume ③ 80 Gallons

CA Title 24 Swing Tank Volume ③ 80 Gallons THIS SYSTEM WAS SIZED FOR

Building Load 185.0 People

Apartments 72 Units

Daily Hot Water Usage **49.0** Gallons per Day per Person

Total Hot Water 9,066.96 Gallons per Day

Recirculation Loop Heat Loss 100 Watts per Apartment



SEND US YOUR FEEDBACK

Site 2

put	
System Settings	Switch to SI/Metric units.
Equipment:	Water Heaters Only (no external storage)
	Water Heaters with external storage if required
	Commercial Tankless Heaters (no storage)
	Commercial Tankless Heaters PLUS Storage Tanks
	O Heat Pump Heaters
	O Boilers with external storage tank
Fuel Type:	Natural Gas
Equipment Location:	Indoor 🗸
Other Requirements:	Low NOx - Requirements of < 40 ng/J or 55 PPM
	Ultra Low NOx - Requirements of < 14 ng/J or 20 PPM
	ASME Approved
Display CDN Products:	
# of Heaters:	Not Specified (Auto)
Altitude:	Less than 2000 ft 🔹
Application Data	
Temperatures	
Cold Water Temp:	58 °F
Stored Water Temp:	120 °F
Load Profile	
Building Use:	Medium Peak Demand V
Peak Demand Period:	1 HOURS (Custom? ♥)
Unit Application Loads	2
Shower Head Flowrate:	2.5 USGPM
Units with 1 Bath:	18 Persons per unit: 1.5 Uw/ Clothes Washer
Units with 1-1/2 Baths:	0 Persons per unit: 2 W/ Clothes Washer
Units with 2 Baths:	0 Persons per unit: 2.5 W/ Clothes Washer
Units with 2-1/2 Baths:	0 Persons per unit: 3 W/ Clothes Washer
Laundry Room or Coin-Op La	undry
Include Coin-Operated La	-
Model 1 - Quantity:	0 Capacity: 0 LB
Model 2 - Quantity:	0 Capacity: 0 LB
allow to the second	
Additional Load and Intentio Additional Load:	0 USGPH (@ stored temp)
Design Oversize	0% V
Design Oversize	V /0 ¥
Load Summary	
Peak Demand:	274 USGPH Temperature Rise: 62 °F

Recommend	BTH-150 Mxi Cyclone® Mxi Mod # Heaters: Heater Storage (ea): Input (ea): New External Tanks:	1 100 USG 150,000 Btu/hr 0	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	
	Total Usable Storage: BTR-154 Master-Fit@ Multif # Heaters: Heater Storage (ea): Input (ea): New External Tanks: Total Usable Storage:	lue Gas 1 81 USG 154,000 Btu/hr 0	% Of Demand: Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery: % Of Demand:	130% (1-hour peak) Select 240 USGPH @ 62 °F Rise 297 USGPH 209 USGPH 20 min 108% (1-hour peak)
	BTR-180 Master-Fit@ Multif # Heaters: Heater Storage (ea): Input (ea): New External Tanks: Total Usable Storage:	1 81 USG 180,000 Btu/hr 0	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery: % Of Demand:	Select 282 USGPH @ 62 °F Rise 339 USGPH 301 USGPH 17 min 124% (1-hour peak)
	BTR-199 Master-Fit@ Multif = Heaters: Heater Storage (ea): Input (ea): New External Ta Cha Total Usable Storage:	1 81 USG 199,000 Btu/hr rt Area	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery: % Of Demand:	Select 311 USGPH @ 62 °F Rise 368 USGPH 30 USGPH 16 min 134% (1-hour peak)

Input

	SYSTEM SE			
		elect from the drop down lis	t	
Installation Type		Temperature Units		
Indoor	~	Fahrenheit (°F)		~
Fuel Type Natural Gas	~	Incoming Water Temperat	ure (*F) 🚺	
	·	58	-0	_
ASME Required	~	Stored Temperature (°F)		
	•	120 C)	_
Immersion Thermostat Required	~	Altitude (ft)		
		• •		_
Low NOx Installation 🥹				
No	~			
OPTIONAL SETTINGS				
Number of Water Heaters		Number of New Storage T	anks	
Not Specified	*	Not Specified		~
Intentional Oversize Percent		Storage Tank Type 🥹		
0%	*	Not Specified		*
Pre-Existing Storage (Gal)		Storage Tank Capacity (Ga	Ŋ	
0		Not Specified		~
% of Demand Satisfied, Minimum Se	election 🕜			
100	0			
		CATION DATA		
I have with 1 Park	Enter the r	CATION DATA		
Units with 1 Bath	Enter the r Shower Head	CATION DATA requirements below	In-suite Clothes Washer	
18	Enter the r Shower Head 2.5 GPM	cation data requirements below is	In-suite Clothes Washer	
18 Units with 1½ Bath	Enter the r Shower Head 2.5 GPM Shower Head	CATION DATA requirements below is w/	In-suite Clothes Washer	
18 Units with 1½ Bath 0	Enter the r Shower Head 2.5 GPM	EATION DATA requirements below is w/ 1 is		
18 Units with 1½ Bath 0 Units with 2 Bath	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	s w/l	In-suite Clothes Washer	
18 Units with 1½ Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM	s s w/1 s s s s s s s		
18 Units with 1½ Bath 0 Units with 2 Bath	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	CATION DATA equirements below is	in-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM	CATION DATA equirements below is	In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head Shower Head	cation data equirements below is is is is is is is is is is is is is	in-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM	EATION DATA equirements below is w/l is w/l is w/l is w/l is w/l is w/l is w/l is w/l is is w/l is is is is is is is is is is	in-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM	CATION DATA equirements below is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	cation data equirements below is is is is is is is is is is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	cation data equirements below is is is is is is is is is is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0 Shower Minutes Per Hour	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	cation data equirements below is is is is is is is is is is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	cation data equirements below is is is is is is is is is is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0 Shower Minutes Per Hour	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	cation data equirements below is is is is is is is is is is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	cation data equirements below is is is is is is is is is is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	
18 Units with 1½ Bath 0 Units with 2 Bath 0 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0 Units with 5½ Bath 0	Enter the r Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head 2.5 GPM Shower Head	cation data equirements below is is is is is is is is is is	In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer In-suite Clothes Washer	

	CORDER			
	U.H.E® Commercial Wate	er Heater (60-100 Gallon)		
(0)	Heaters Required	1	Heater Model No.	LUHE60T125E3N(A)
	Heater Capacity	60 USG	Input per Hour	125,000 BTU/HR
· · · · · · · · · · · · · · · · · · ·	Thermal Efficiency		Venting	
	Storage Tanks	96% None	Usable Storage	Power / Power Direct 42 USG
	Recovery	232 USGPH @ 62 "F Rise		42 USG 274 USG
			Approx. 1st Hour Delivery	15 MINUTES
	Approx. 3 Hour Avg. Delivery % of Demand Satisfied	246 USG 278%	Approx. Storage Recovery	IS MINUTES
	to of Demand Satisfied	278%		
			s	elect
	CONDEN	SING RECOMMENDATION		
	Compen			
	U.H.E [®] Commercial Wate	er Heater (60-100 Gallon)		
(9)	Heaters Required	1	Heater Model No.	LUHE60T150E3N(A)
20	Heater Capacity	60 USG	Input per Hour	150,000 BTU/HR
-	Thermal Efficiency	93%	Venting	Power / Power Direct
	Storage Tanks	None	Usable Storage	42 USG
	Recovery	270 USGPH @ 62 *F Rise	Approx. 1st Hour Delivery	312 USG
	Approx. 3 Hour Avg. Delivery	284 USG	Approx. Storage Recovery	13 MINUTES
* 0	% of Demand Satisfied	316%		
				elect
	Mighty Therm®2 Volume	#1		
	Heaters Required	1	Heater Model No.	MT2V0200
				No Pump 200-400 📑
				Pump Mounted 200-400
	Heater Capacity	0 USG	Input per Hour	199,900 BTU/HR
	Thermal Efficiency	85%	Venting	N/A
	Storage Tanks	1 @ 80 USG	Tank Model	A0073100/A0073101
	Usable Storage	64 USG	Recovery	329 USGPH @ 62 *F Rise
	Approx. 1st Hour Delivery	393 USG	Approx. 3 Hour Avg. Delivery	350 USG
	Approx. Storage Recovery	15 MINUTES	% of Demand Satisfied	398%
			Se	lect
	VOLUME WAT	ER HEATER RECOMMENDATIO	N	
	Mighty Therm®2 Volume	Water Heaters		
	Heaters Required	1	Heater Model No.	MT2V0200
				No Pump 200-400 Pump Mounted 200-400
111	Heater Capacity	0 USG	Input per Hour	
	Heater Capacity Thermal Efficiency	0 USG 85%	Input per Hour Venting	Pump Mounted 200-400
111				Pump Mounted 200-400 L 199,900 BTU/HR
111	Thermal Efficiency Storage Tanks	85% 1 @ 119 USG	Venting	Pump Mounted 200-400 199,900 BTU/HR N/A A0078800/A0070101
11	Thermal Efficiency	85%	Venting Tank Model	Pump Mounted 200-400 199,900 BTU/HR N/A
			Heater Model No.	


put on type	water meater						
Product Line	All						
Voltage Input	×110VAC 50/	the second s		Contraction of the local division of the loc	and the second sec		1-ph
	× 208VAC 3-; × No externa				VAC 3-ph	×480VAC	3-ph
Application Type	Apartment/M	ulti-famil	у				٣
Storage (gl)	N/A						
Fuel Type	All						
Installation Zip Code		,	Amount	Auto	*		
Inlet (*F)	58	Out	tlet (*F)	120		Elev. (ft)	0
Load (auto 🗹)	Peak	• Pe	ak (hr)	1		Rec. (hr)	1
ASME		Lo	w NOx		Ultra-I	Low NOx	
Fixtures							-
Click Here To A	dd Fixture *	Qty	Flow (GPH				P Edit
Sin	gle Bath Units	18		2.5	12	105	
1	1/2 Bath Units			3	12	105	
	2 Bath Units			5	12	105	
Automatic Wasł	hing Machines		15			120	
Publi	c lavatory sink		5			105	
	Service Sinks		10			120	

PRODUCTS (DELIVERY REQUIRED: 409 US GALLONS)

	Model	G100-270 (★)	Quantity	/ 1		
9	Input	270000 BTU	Delivery	492 U	S Gallons	
	Size	100 US Gallons	Recover	ry 422 U	S GPH at 62 °F rise	
•••	Fuel Type	Gas	Storage	Tank N/A		
-	Efficiency	80%				
Anou	iei mouei					
est Deliv	ery Match 🔹					
Cor Doni	ory materi					
	Model	G100-270 LP	(Quantity	1	
-	Input	270000 BTU	0	Delivery	492 US Gallons	
	Size	100 US Gallons	F	Recovery	422 US GPH at 62 °F rise	
•••	Fuel Type	Gas	5	Storage Tank	N/A	
	Efficiency	80%				
	Model	GHE100SS-250	(Quantity	1	
	Input	250000 BTU	(Delivery	539 US Gallons	
	Size	100 US Gallons	F	Recovery	469 US GPH at 62 °F rise	
0.4	Fuel Type	Gas (High Eff)	5	Storage Tank	N/A	
0	Efficiency	96%				
	Model	GHE100SS-250 LP	0	Quantity	1	
	Input	250000 BTU	(Delivery	539 US Gallons	
	Size	100 US Gallons	F	Recovery	469 US GPH at 62 °F rise	
0-1	Fuel Type	Gas (High Eff)	5	Storage Tank	N/A	
6	Efficiency	96%				
	Model	E85-81-G	0	Quantity	1	
•	Input	81 kW	0	Delivery	589 US Gallons	
	Size	85 US Gallons	F	Recovery	530 US GPH at 62 °F rise	
	Fuel Type	Electric	5	Storage Tank	N/A	

EHPWH Tool

Input



 Building Type
 Market rate multifamily building load shape based on Ecotope research.

 Multifamily
 Total hot water usage is based on the number of people and gallons used per person per day from inputs below.


TOTAL PEOPLE	& APARTMENTS	APARTMENT SIZE & OCCUPANCY RA	TES	<u>•</u>		
	Number of Apartments	Occupancy Rate 💿		Peak Gallons per Day per Person ③		California by Bedroor
	Aparanento	California - RASS Data 💙		ASHRAE Medium	~	
Studio	6	1.37	1		49 0 49	
					49	
Bedroom	12	1.74	1		0 49	
Bedroom	0	2.57	1		49	
Bedroom	0	3.11	1		49	
					40	
Bedroom	0	4.23	1		49 0 49	
Bedroom	0	3.77			49	

Results

The graph below represents the trade off between storage volume and heating capacity. The Ecosizer method result is the green curve in the graph. The system sized from user inputs is the blue diamond. Users should pick any point above the green curve to determine their system sizing.

Use the slider bar below the plot to select a different size system.

Primary Sizing Curve



RECOMMENDATIONS

The recommended minimum heating capacity shown below is the **minimum** needed average output capacity of the selected equipment at the design cold air temperature in your climate zone. Note that you must also account for manufacturer specific defrost penalty.

Tank Volume <a>>**368.00** Gallons

Swing Tank Volume <a>

 40 Gallons

CA Title 24 Swing Tank Volume ③ 80 Gallons Heating Capacity ③ 43.10 kBTU/hr

Swing Resistance Element ⁽²⁾ 3.1 kW · 10.7 kBTU/hr THIS SYSTEM WAS SIZED FOR

Building Load 29.1 People

Apartments 18 Units

Daily Hot Water Usage 49 Gallons per Day per Person

Total Hot Water 1,425.90 Gallons per Day

Recirculation Loop Heat Loss 100 Watts per Apartment



SEND US YOUR FEEDBACK

Site 3



nput		
Results Selection		Switch to SI/Metric units
	System Settings	
Payback Calculator	Equipment:	
Product Literature	Equipment.	Water Heaters Only (no external storage)
		Water Heaters with external storage if required
		 Commercial Tankless Heaters (no storage)
		Commercial Tankless Heaters PLUS Storage Tanks
		O Heat Pump Heaters
		\bigcirc Boilers with external storage tank
	Fuel Type:	Natural Gas 🗸
	Equipment Location:	Indoor 🗸
	Other Requirements:	Low NOx - Requirements of < 40 ng/J or 55 PPM
		Ultra Low NOx - Requirements of < 14 ng/J or 20 PPM
		ASME Approved
	Display CDN Products:	
	# of Heaters:	Not Specified (Auto)
	Altitude:	Less than 2000 ft 🗸
	Application Data	
	Temperatures	
	Cold Water Temp:	65 °F
	Stored Water Temp:	135 °F
	Load Profile	
	Building Use:	Medium Peak Demand V
	Peak Demand Period:	1 HOURS (Custom? V)
	Unit Application Londo	
	Unit Application Loads Shower Head Flowrate:	2.5 USGPM
	Units with 1 Bath:	0 Persons per unit: 1.5 w/ Clothes Washer
	Units with 1-1/2 Baths:	0 Persons per unit: 2 W/ Clothes Washer
	Units with 2 Baths:	16 Persons per unit: 2.5 W/ Clothes Washer
	Units with 2-1/2 Baths:	0 Persons per unit: 3 W/ Clothes Washer
		Laura da s
	Laundry Room or Coin-Op I	
	Include Coin-Operated I Model 1 - Overstitut	
	Model 1 - Quantity:	0 Capacity: 0 LB
	Model 2 - Quantity:	0 Capacity: 0 LB
	Additional Load and Intent	tional Quercize
	Additional Load and Intent	0 USGPH (@ stored temp)
	Design Oversize	0% 🗸
	Load Summary	
	Peak Demand:	306 USGPH Temperature Rise: 70 °F
	reak Demanu:	Soo osorn Temperature Rise: 70 °F

ion

Search Results To view detailed product information, select the recommended 4 heater that you feel best s Steps your application. Load Summary Peak Demand: 286 USGPH Temperature Rise: 75 °F alculator terature Recommended Products BTH-150 Mxi Cyclone® Mxi Modulating # Heaters: 1 Heater Recovery: 237 USGPH @ 75 Heater Storage (ea): 100 USG 1st Hour Delivery: 307 USGPH 150,000 Btu/hr 3 Hour Average: Input (ea): 261 USGPH Est. Storage Recovery: 25 min New External Tanks: 0 Total Usable Storage: 70 USG % Of Demand: 108% (1-hour pe BTH-199 Mxi Cyclone® Mxi Modulating # Heaters: 1 Heater Recovery: 313 USGPH @ 75 Heater Storage (ea): 100 USG 1st Hour Delivery: 383 USGPH 199,000 Btu/hr 3 Hour Average: Input (ea): 337 USGPH Est. Storage Recovery: 19 min New External Tanks: 0 Total Usable Storage: 70 USG % Of Demand: 134% (1-hour pe BTHL-150A Cyclone® LV (Large Volume) # Heaters: 1 Heater Recovery: 233 USGPH @ 75 Heater Storage (ea): 250 USG 1st Hour Delivery: 408 USGPH 150,000 Btu/hr 3 Hour Average: Input (ea): 292 USGPH Est. Storage Recovery: 64 min New External Tanks: 0 Total Usable Storage: 175 USG % Of Demand: 143% (1-hour pe **BTR-180** Master-Fit® Multiflue Gas # Heaters: 1 233 USGPH @ 75 Heater Recovery: Heater Storage (ea): 81 USG 1st Hour Delivery: 290 USGPH 180,000 Btu/hr 3 Hour Average: Input (ea): 252 USGPH Est. Storage Recovery: 21 min New External Tanks: 0 Total Usable Storage: 57 USG % Of Demand: 101% (1-hour pe

Show Alternate Products ...

Input

	â	•	
	SYSTEM S	ETTINGS	
То	override a default parameter,	select from the drop down list	
Installation Type		Temperature Units	
Indoor	~	Fahrenheit (°F)	-
Fuel Type		Incoming Water Temperature (°F) 🟮	
Natural Gas	~	65 0	-
ASME Required		Stored Temperature (°F) 🔺	
No	~	135	
Immersion Thermostat Require	d	Altitude (ft)	
No	~	0	_
Low NOx Installation 0			
No	~		
	Enter the requirem	ents below	
Units with 1 Bath	Enter the requirem Shower Heads	ents below	
Units with 1 Bath		w/In-suite Clothes Washer	
	Shower Heads	V In-suite Clothes Washer	
0	Shower Heads		
0 Units with 1½ Bath	Shower Heads 2.5 GPM Shower Heads	w/ In-suite Clothes Washer w/ In-suite Clothes Washer	
0 Units with 11/2 Bath 0	Shower Heads 2.5 GPM Shower Heads 2.5 GPM	w/ In-suite Clothes Washer w/ In-suite Clothes Washer	
0 Units with 1½ Bath 0 Units with 2 Bath	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer w/ In-suite Clothes Washer w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM		
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer w/ In-suite Clothes Washer w/ In-suite Clothes Washer w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM		
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0 Units with 3 Bath	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0 Units with 3 Bath 0	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM	 w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0 Units with 3½ Bath 0 Units with 3½ Bath 0 Units with 3½ Bath	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0 Units with 3½ Bath	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0 Shower Minutes Per Hour @	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0 Units with 3½ Bath 0 Shower Minutes Per Hour 7	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer 	
0 Units with 1½ Bath 0 Units with 2 Bath 16 Units with 2½ Bath 0 Units with 3½ Bath 0 Diversity Factor (%)	Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	 w/ In-suite Clothes Washer 	

Image: Second		VOLUME WATER H	EATER RECOMMENDATIO	N		
Notice Registed 1 Heater Model No. M120000 Heater Cipacity 0.055 Hond per Hour 1993000 BTU/ARE Strange Tanis 1 0.055 Hond per Hour 1993000 BTU/ARE Strange Tanis 1 0.055 Hond per Hour 1993000 BTU/ARE Strange Tanis 1 0.055 Hond per Hour 1993000 BTU/ARE Strange Tanis 1 0.055 Hond per Hour 199300 BTU/ARE Strange Tanis 1 0.055 Hond per Hour 199300 BTU/ARE Strange Tanis 1 1 Hond Per Hour 199300 BTU/ARE Strange Tanis 1 1 Hond Per Hour 199300 BTU/ARE Strange Tanis 1 1 Hond Per Hour 199300 BTU/ARE						
Image: Standard			ter Heaters			
Weater Capacity 0.05G Ireat prima 200.000 BTU/ARI Thermal Efficiency 0.55 Wrinig According to the Model According to the Model Storage Taxis 1.0000 Storage 64.0055 Recovery 201.05GPH and the Prior 201.05GPH and the Prior Storage Taxis 1.0000 Storage 64.0055 Recovery 301.05G Approx. Storage Recovery 16.55 Recovery 301.05G Approx. Storage Recovery 16.55 Recovery 301.05G VOLUME WATER HEATTER RECOMMENDATION Recovery 301.05G Volume Water Heaters Mighty Therm # 2 Volume Water Heaters Mighty Therm # 2 Volume Water Heaters Heater Capacity 0.055 Input per Hour 199.000 STU/ARI Storage Taxis 1.0000 Not per Hour 199.000 STU/ARI Storage Taxis 1.00000 Not per Hour 199.000 STU/ARI Storage Taxis 1.00000 No		Heaters Required	1	Heater Model No.	MT2V0200	
Heater Capacity 0.055 injust per Hour 199,900 BTU/HB Thermal Efficiency 6.55 Wrining NA Storage Taxia 1.96 0.055 Text Model According Model No Lable Storage 6.4055 Recordy 2.21 U.SchH # 70 °F Rise Apprent. Its Hour Delivery 355 US5 Apprent.3 Hour Ang. Delivery 313 US5 Apprent. Its Hour Delivery 355 US5 Apprent.3 Hour Ang. Delivery 313 US5 Apprent. Its Hour Delivery 16 MINUTES Not Delivery 313 US5 Apprent. Its Hour Delivery 16 MINUTES Not Delivery 313 US5 Apprent. Its Hour Delivery 16 MINUTES Not Delivery 313 US5 Apprent. Its Hour Delivery 10 US5 Heater Ang. Delivery 310 US5 Heater Capacity 0 US5 Heater Model No. MT2/V0200 Not Delivery 2 US5 Recovery 2 US5 Not Delivery 320 US5 Heater Capacity 0 US5 Invit Model No. MT2/V0200 NA Storage Taxia 1 @ 119 US5 Invit Model No. NO Lable Storage 55 US5 Recovery 2 US US6						
Sorage Tarks 1 @ 80 USS Tark Model A0073100(A007301) Ubbit Strage 64 USS Recovery 291 USGPH @ 70 F Rise Approx. Tet Hour Delivery 355 USS Approx. Star Hour Delivery 315 USS Approx. Star Hour Delivery 16 MINUTES Nor Ang. Delivery 315 USS Approx. Star Hour Delivery 16 MINUTES Nor Ang. Delivery 315 USS VOLUME WATER HEATER RECOMMENDATION Approx. Star Hour Perform VOLUME WATER HEATER RECOMMENDATION Approx. Star Hour Perform Mighty Therm © 2 Volume Water Heaters Meater Required 1 Heater Model No. MI2V0200 NECONFUL Meater Stangeled 1 Heater Model No. MI2V0200 Networks 1 @ 119 USS Tech Model Accorescource on NA Strange 1 @ 119 USS Tech Model Accorescource on NA Strange 1 @ 119 USS Tech Model Accorescource on NA Approx. Tar Hour Delivery 337 USS Approx. Star Mag. Delivery 231 USG Approx. Starup B Recovery 25 MINUTES Not Derand Statified<	1111	Heater Capacity	0 USG	Input per Hour	199,900 BTU/HR	
Usaile Storage 64 USG Recovery 291 USGPH (#) 70 * Rise Approx. 1st Hour Delivery 355 USG Approx. 3 Hour Ang. Delivery 313 USG Approx. Sternage Recovery 16 MINUTES % of Demand Satisfied 247% Select VOLUME WATER HEATER RECOMMENDATION Agence. Text Heat File Recovery 1 Heater Model No. MT2V0200 Mighty Therm # 2 Volume Water Heaters Heater Capacity 0 USG Kept per Hour 199,3900 BTU/HR NATE Capacity 0 USG Kept per Hour 199,3900 BTU/HR Heater Capacity 0 USG Kept per Hour 199,3900 BTU/HR USERPH Counce USERPH Counce Lotted Status Boale 25 USG Approx. 1st Hour Delivery 387 USG Approx. 3 Hour Ang. Delivery 233 USG Approx. 1st Hour Delivery 387 USG Approx. 3 Hour Ang. Delivery 233 USG Approx. 1st Hour Delivery 387 USG Approx. 3 Hour Ang. Delivery 233 USG Approx. 1st Hour Delivery 381 USG Approx. 1st Hour Delivery	A CONTRACTOR OF THE OWNER OF	Thermal Efficiency	85%	Venting	N/A	
Approx. 1st Hour Belivery 355 USG Approx. 3 Hour Arg. Delivery 313 USG Approx. 30rage Recovery 16 MINUTES % of Demand Saturfied 247% Select USUME WATER HEATER RECOMMENDATION 22 Mighty Therm % 2 Volume Water Heaters Mater Capacity 0 USG Irent per Hour 199,900 ETU/AR Thermal Efficiency 85% Versing NA Sorage Tarks 1 @ 119 USG Approx. 3 Hour Arg. Delivery 231 USGAN 00774 Approx. 3 Hour Arg. Delivery 231 USGAN 00774 Select Delivery 25 MINUTES % of Demand Saturfied 226% Delivery 2014 Delivery 357 USGA Approx. 3 Hour Arg. Delivery 323 USGAN 00774 Sorage Tarks 1 @ 119 USG Approx. 3 Hour Arg. Delivery 323 USGAN 00774 Delivery 25 MINUTES % of Demand Saturfied 226% Delivery 25 MINUTES % of Demand Saturfied 266% Delivery 25 MINUTES % of Demand Saturfied 266% Delivery 25 MINUTES % of Demand Saturfied 256% Delivery 25 MINUTES % of Demand Saturfied 256% Delivery 000 ETU/AR Mater Capacity 0 USG Approx. 3 Hour Arg. Delivery 323 USGAN 00775 Delivery 25 MINUTES % of Demand Saturfied 266% Delivery 27 MINUTES % of Demand Saturfied 266% Delivery 27 MINUTES % of Demand Saturfied 266% Delivery 000 ETU/AR Mater Capacity 0 USG Net Med Adv73000/A0073100 Mater Minuter 1000 Delivery 0 0005 Net Model Mode 100 Apro7300/A0073100/A	1	Storage Tanks	1 @ 80 USG	Tank Model	A0073100/A0073101	
Approx. Storage Recovery 16. MINUTES % of Demand Saturded 247% Select ULUME WATER HEATER RECOMMENDATION A2 Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Not Therma *2 Volume Water Heaters Mighty Therm *2 Volume Water Heaters Sociage Tanis Mighty Therm *2 Volume Water Heaters Nort Tanis Model Mo. <		Usable Storage	64 USG	Recovery:	291 USGPH @ 70 *F Rise	
Select UDUDAE WARTER HEATER RECOMMENDATION Za Mighty Therm # 2 Volume Water Heaters Mighty Therm # Volume Water Heaters Mighty Therm # Volume Water Heaters Query Biology B		Approx. 1st Hour Delivery	355 USG	Approx, 3 Hour Avg. Delivery	313 USG	
DULUME WATER HEATER RECOMMENDATION Interme # 2 Volume Water Heaters Mighty Therm # 1 @ 119 USG Mighty Therm # 1 @ 119 USG Approx. 11 @ 119 USG Aprox. 3 Hour Aug Delivery 231 USG Approx. 11 @ 119 USG Aprox. 3 Hour Aug Delivery 232 USG Approx. 11 @ 100 USG Approx. 3 Hour Aug Delivery 232 USG Approx. 5 Interma Volume Water Heaters Montherm Volume Water Heaters Montherm * Volume Water Heaters Montherm * Volume Water Heaters Minut % 1 @ Hour & Solume % Montherm * Volume Water Heaters Montherm * Volume Water Heaters Minut % 1 @ Hour & Solume % Montherm * Volume Water Heaters		Approx. Storage Recovery	16 MINUTES	% of Demand Satisfied	247%	
Provide the set of the				Sele	ict	
Westers Required 1 Heater Model No. MT2V0200 No Pump: 300-400 No P		VOLUME WATER H		N		
Non-Therms Volume Water Heater Approx. Servey 231 USGPH OUSG Input per Hour 199,900 BTU/HR NA Sorage BisSinage NA Sorage NA Sorage BisSinage 95 USG Recovery 231 USGPH 0.055 Heater Aug. Delivery 231 USGPH 70 'F Rise Approx. Storage 95 USG Recovery 231 USGPH 223 USGPH 224 USGPH 2		Mighty Therm®2 Volume Wa	ter Heaters			
Heater Capacity 0 USG Input per Hour 199,900 BTU/HR Themal Efficiency 85% Verning N/A Sorage Tanka 1 @ 119 USG Tank Model AD0758000/A0070001 Input per Hour 199,900 BTU/HR Usable Storage 95 USG Recovery 291 USGPH @ 70 *F Rise Approx. 3 Hour Ang. Delivery 323 USG Approx. 1st Hour Delivery 387 USG Approx. 3 Hour Ang. Delivery 323 USG Approx. 50rage Recovery 25 MINUTES % of Demand Satisfied 268% Select NoteTherm® Volume Water Heater NeoTherm® Volume Water Heaters Heater Sequired 1 Heater Model No. N27550 NeoTherm® Volume Water Heaters Heater Sequired 1 Heater Model No. N27550 Heater Sequired 1 Heater Model No. N27550 Sorage Tanks 1 @ 80 USG Input per Hour 150,000 BTU/H Sorage Tanks 1 @ 80 USG Input per Hour 150,000 BTU/H Sorage Tanks 1 @ 80 USG Tant Model Ac0771800/A0072101		Heaters Required	1	Heater Model No.	MT2V0200	
Hester Capacity 0 USG Input per Hour 199,900 BTU/HR Thermal Efficiency 85% Venting N/A Sorage Tarks 1 @ 119 USG Tark Model AccretocyAccretoria N/A Utable Storage 95 USG Recovery 291 USGPH @ 70 'F Rise Approx. tat Hour Delivery 387 USG Approx. 3 Hour Aug. Delivery 323 USG Approx. Storage Recovery 25 MINUTES % of Demand Satisfied 268% Select CONDENSING VOLUME WATER HEATER RECOMMENDATION MeoTherm * Volume Water Heaters Heaters Required 1 Heater Model No. MITYSO Sonage Tarks 1 @ 80 USG Input per Hour 550,000 BTU/H Sonage Tarks 1 @ 80 USG Input per Hour 550,000 BTU/H List Fourday 0 USG Input per Hour 550,000 BTU/H MeoTherm * Volume Water Heaters Meater Capacity 0 USG Input per Hour 550,000 BTU/H Meater Sage 1 @ 80 USG Tark Model Accretory100/Accretoria Sonage Tarks 1 @ 80 USG Recovery					No Pump 200-400	
Image: Storage Tarks 1 @ 119 USG Tark Model Acc72800/Acc70101 Usable Storage 95 USG Recovery 291 USGPH @ 70 *F. Rise Approx. 1st Hour Delivery 387 USG Approx. 3 Hour Avg. Delivery 323 USG Approx. 5torage Recovery 25 MINUTES % of Demand Satisfied 268% Select Select <td colspa<="" td=""><td>- 511</td><td>Haster Canacity</td><td>0.055</td><td>locat per Hour</td><td></td></td>	<td>- 511</td> <td>Haster Canacity</td> <td>0.055</td> <td>locat per Hour</td> <td></td>	- 511	Haster Canacity	0.055	locat per Hour	
Storage Tarks 1 @ 119 USG Tark Model A0078800/A0070101 Utable Storage 95 USG Recovery 291 USGPH @ 70 'F Rise Approx. 1st Hour Delivery 387 USG Approx. 3 Hour Aug. Delivery 323 USG Approx. Storage Recovery 25 MINUTES % of Demand Satisfied 268% Select CONDENSING VOLUME WATER HEATER RECOMMENDATION Provide Water Heaters Heater Sequired 1 Heater Capacity 0 USG Immail Efficiency 10% NOV Storage Tarks 1 @ 80 USG Tark Model Aco73100/Aco73101 Storage Tarks 1 @ 80 USG Tark Model Aco73100/Aco73101 Mater Sequired Tark Model Aco73100/Aco73101						
Utable Storage 95 USG Recovery 291 USGPH (# 70 *F Rise Approz. 1st Hour Delivery 387 USG Approz. 3 Hour Avg. Delivery 323 USG Approz. Storage Recovery 25 MINUTEs % of Demand Satisfied 268% Select CONDENSING VOLUME WATER HEATER RECOMMENDATION PreoTherm * Volume Water Heaters Heater Sequired 1 Heater Model No. NEVISO Heater Capacity 0 USG Irput per Hour 150,000 BTU/H Thermal Efficiency 10% Verting N// Storage Tarks 1 (% 80 USG Tark Model Approx. 244 USGPH (% 70 *F Risk Approx. 1st Hour Delivery 308 USG Approx. Approx. 3 Hour Avg. Delivery 266 USG	1					
Approx. 1st Hour Delivery 367 USG Approx. 3 Hour Aug. Delivery 323 USG Approx. Storage Recovery 25 MINUTES % of Demand Satisfied 268% Select CONDENSING VOLUME WATER HEATER RECOMMENDATION Improve Satisfied 268% MeoTherm * Volume Water Heaters Heater Required 1 Heater Model No. NTV150 Heater Required 1 Heater Model No. NTV150 Heater Capacity 0 USG Irput per Hour 150,000 BTU/H Thermal Efficiency 10% Verting No. Storage Tarks 1 @ 80 USG Tark Model Ac073100/A6073101 Quarke Storage 64 USG Recovery 266 USG Approx. 1st Hour Delivery 308 USG Approx. As to Log Delivery 266 USG						
Approx. Storage Recovery 25 MINUTES % of Demand Satisfied 268% Select CONDENSING VOLUME WATER HEATER RECOMMENDATION CONDENSING VOLUME WATER HEATER RECOMMENDATION CONDENSING VOLUME WATER HEATER RECOMMENDATION Provide Water Heaters Heater Sequired 1 Heater Sequired 1 Heater Model No. NTV150 Heater Capacity 0 USG Input per Hour 150,000 BTU/H Thermal Efficiency 10% 50 USG Tark. Model According Colspan="2">According Colspan="2">According Colspan="2">Conset Faiss Lingle Storage 64 USG Tark. Model According Colspan="2">According Colspan="2">Colspan= Colspan="2">Colspan="2" Colspan="2">Colspan="2" Colspan="2" Colspan="2" Colspan="2" Colspan="2" Colspan="2" Colspan="2" Colspan="2" Colspan="2" <td cols<="" td=""><td>_</td><td></td><td>775.25</td><td></td><td></td></td>	<td>_</td> <td></td> <td>775.25</td> <td></td> <td></td>	_		775.25		
Select CONDENSING VOLUME WATER HEATER RECOMMENDATION Image: Condensing Volume Water Heaters Image: Condensing Volume Water Heaters NeoTherm® Volume Water Heaters Image: Condension of the second of the seco				 AS Contraction and Transition of The Second Contraction o		
NeoTherm® Volume Water Heaters Heater Required 1 Heater Model No. HTV150 Heater Capacity 0 USG Input per Hour 150,000 BTU/H Thermal Efficiency 0256 Venting N/ Storage Tanks 1 @ 80 USG Tank Model Accoration/Accoration Unable Storage 64 USG Recovery 244 USGPH @ 70 *F Ris Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 USG		Alifornii finitalija partovaria	25 MINUTES			
NeoTherm® Volume Water Heaters Heater Required 1 Heater Model No. NETV150 Heater Capacity 0 USG Input per Hour 150,000 BTU/H Thermal Efficiency 0256 Venting N/ Storage Tanks 1 @ 80 USG Tank Model Accoratio/Accoration Unable Storage 64 USG Recovery 244 USGPH @ 70 * P Ris Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 USG		CONDENSING VOLUM	E WATER HEATER RECOMM	MENDATION		
Heaters Required 1 Heater Model No. MITVISO Heater Capacity 0 USG Input per Hour 150,000 BTU/H Heater Capacity 0 USG Input per Hour 150,000 BTU/H Thermal Efficiency 0 25% Verting N/L Storage Tarks 1 @ 80 USG Tark Model Accoration/Accoration Unable Storage 64 USG Recovery 244 USGPH @ 70 *F Ris Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 USG			2			
Heater Capacity 0 USG Input per Hour 150,000 BTU/H Thermal Efficiency 55% Venting N/ Storage Tanks 1 @ 80 USG Tank Model A0073100/A0073101 Unable Storage 64 USG Recovery 244 USGPH @ 70 °F Ris Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 USG		NeoTherm® Volume Wate	er Heaters			
Thermal Efficiency BS% Venting N/ Storage Tanks 1 @ 80 USG Tank Model A0073100/A0073101 Unable Storage 64 USG Recovery 244 USGPH @ 70 *F Ris Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 USG	-	Heaters Required	21	Heater Model No.	NTVISO	
Storage Tanks 1 @ 80 USG Tank Model A0073100/A0073101 Unable Storage 64 USG Recovery 244 USGPH @ 70 *F Ris Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 USG		Heater Capacity	0 USG	input per Hour	150,000 BTU/H	
Unable Storage 64 USG Recovery 244 USGPH (# 70 * F Ris Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 US		Thermal Efficiency	95%	Venting	N/	
Approx. 1st Hour Delivery 308 USG Approx. 3 Hour Avg. Delivery 266 US		Storage Tanks	1 @ 80 USG	Tani: Model	A0073100/A0073101	
		Usable Storage	64 USG	Recovery	244 USGPH @ 70 °F Ris	
Approx. Storage Recovery 20 MINUTES % of Demand Satisfied 214		Annene Set Hour Dailware	308 USG	Approx 3 Hour Aug. Delivery	266 US	
	and the second	Paperon in root beiney				

Input							
Unit Type	Water Heat	er					*
Fuel Type	Gas						*
Product Line	All						*
Voltage Input	×240VAC 1-	-ph × 277	VAC 1-ph VAC 3-ph	0 Hz × 120 × 480VAC 1 × 480VAC 3	-ph × 200		AC 1-ph
Application Type	Apartment/	Multi-famil	y				*
Storage (gl)	N/A						*
Installation Zip Code		,	Amount	Auto *]		
Inlet (*F)	65	Ou	tlet (*F)	135	E	lev. (ft) 0	
Load (auto 🗆)	Peak	* P	eak (hr)	1	R	ec. (hr) 1	
ASME		b	ow NOx		Ultra-Lo	w NOx	
Fixtures							-
Click Here To Add	d Fixture *	Qty	Flow (GPH)	Flow (GPM)	Time (min)	Temp (°F)	Edit
Single	Bath Units			2.5	12	105	
1 1/2	Bath Units			3	12	105	
2	Bath Units	16		5	12	105	
Automatic Washin	g Machines		15			120	
Public la	watory sink		5			105	
Se	ervice Sinks		10			120	

PRODUCTS (DELIVERY REQUIRED: 549 US GALLONS)

	: GHE100SU-400			
	Model	GHE100SU-400 (*)	Quantity	1
3	Input	399000 BTU	Delivery	726 US Gallons
	Size	100 US Gallons	Recovery	656 US GPH at 70 *F rise
2	Fuel Type	Gas (High Eff)	Storage Tank	N/A
. 4	Efficiency	95%		
Select Another	Model			
Closest Delivery	Match *			
	Model	GHE1005U-400 LP	Quantity	1
40 3	Input	399000 BTU	Delivery	726 US Gallons
-	Size	100 US Gallons	Recovery	656 US GPH at 70 °F rise
oz	Fuel Type	Gas (High Eff)	Storage Tank	N/A
4	Efficiency	95%		
	Model	GHE100SS-400	Quantity	1
3	Input	399900 BTU	Delivery	728 US Gallons
	Size	100 US Gallons	Recovery	658 US GPH at 70 °F rise
1 de la	Fuel Type	Gas (High Eff)	Storage Tank	N/A
	Efficiency	95%		
	Model	GX90-500N	Quantity	1
· · ·	Input	500000 BTU	Delivery	756 US Gallons
2	Size	90 US Gallons	Recovery	693 US GPH at 70 *F rise
-	Fuel Type	Gas	Storage Tank	N/A
a	Efficiency	80%		
	Model	GX90-500P	Quantity	1
2	Input	500000 BTU	Delivery	756 US Gallons
1.0	Size	90 US Gallons	Recovery	693 US GPH at 70 °F rise
	Fuel Type	Gas	Storage Tank	N/A
e	Efficiency	80%		
	Model	GX90-550 NG	Quantity	1
	Input	550000 BTU	Delivery	825 US Gallons
1	Size	90 US Gallons	Recovery	762 US GPH at 70 °F rise
	Fuel Type	Gas	Storage Tank	N/A

EHPWH Tool


Input

				0	California Specification Mode 🤊
TOTAL PEOPLE	& APARTMENTS	APARTMENT SIZE & OCCUPANCY RATE	5		
	Number of Apartments	Occupancy Rate 💿	Peak Gallons per Day per Person ③		California by Bedroom
	Aparamenta	California - RASS Data 💉	User Defined	~	
Studio	0	1.37	1	49	
			25		
1 Bedroom	0	1.74	1	49	
2 Bedroom	16	2.57	1	49 () 49	
			25	10	
3 Bedroom	0	3.11	1	49	
4 Bedroom	0	4.23	1	49	
5 Bedroom	0	3.77	25	49	

Results

The graph below represents the trade off between storage volume and heating capacity. The method result is the green curve in the graph. The system sized from user inputs is the blue diamond. Users should pick any point above the green curve to determine their system sizing.

Use the slider bar below the plot to select a different size system.



THIS SYSTEM WAS SIZED FOR

Building Load 41.1 People

Apartments 16 Units

Daily Hot Water Usage 49.0 Gallons per Day per Person

Total Hot Water 2,014.88 Gallons per Day

Recirculation Loop

Heat Loss 100 Watts per Apartment

SAVE RESULTS TO PDF

SEND US YOUR FEEDBACK

RECOMMENDATIONS

The recommended minimum heating capacity shown below is the **minimum** needed average output capacity of the selected equipment at the design cold air temperature in your climate zone. Note that you must also account for manufacturer specific defrost penalty.

Tank Volume (2) 533.00 Gallons Heating Capacity ③ 75.60 kBTU/hr

2.8 kW . 9.6 kBTU/hr

Swing Tank Volume [®] 40 Gallons

CA Title 24 Swing Tank Volume ③ 80 Gallons

HOT WATER SIMULATION

Swing Resistance Element ()

Site 4

Input	
Equipment Location:	Indoor V
Other Requirements:	Low NOx - Requirements of < 40 ng/J or 55 PPM
	Ultra Low NOx - Requirements of < 14 ng/J or 20 PPM
	ASME Approved
Display CDN Products:	
# of Heaters:	Not Specified (Auto)
Altitude:	Less than 2000 ft 🗸
Application Data	
Temperatures	
Cold Water Temp:	65 °F
Stored Water Temp:	140 °F
Load Profile	
Building Use:	Medium Peak Demand 🗸 More Info
Peak Demand Period:	1 HOURS (Custom? 💙)
Unit Application Loads	
Shower Head Flowrate:	2.5 USGPM
Units with 1 Bath:	62 Persons per unit: 1.5 🗌 w/ Clothes Washer
Units with 1-1/2 Baths:	0 Persons per unit: 2 W/ Clothes Washer
Units with 2 Baths:	0 Persons per unit: 2.5 🗌 w/ Clothes Washer
Units with 2-1/2 Baths:	0 Persons per unit: 3 Uv/ Clothes Washer
Laundry Room or Coin-Op	Laundry
Include Coin-Operated	Laundry
Model 1 - Quantity:	10 Capacity: 15 LB
Model 2 - Quantity:	0 Capacity: 0 LB
Additional Load and Inten	ional Oversize
Additional Load:	0 USGPH (@ stored temp)
Design Oversize	0% 🗸
Load Summary	
Peak Demand:	546 USGPH Temperature Rise: 75 °F

Output				
Load Summary	e.			
Peak Demand:	846 USGPH	Temp	pera 75	°F
Recommen	ded Products			
	BTH-500 Mxi Cyclone® Mxi Mod	ulating		Select
* 💼	# Heaters: Heater Storage (ea): Input (ea):	1 119 USG 499,900 Btu/hr	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	768 USGPH @ 75 °F Rise 851 USGPH 796 USGPH 9 min
5 . C	New External Tanks: Total Usable Storage:	0 83 USG	% Of Demand:	101% (1-hour peak)
	BTHS-750A Cyclone® XL			Select
	# Heaters: Heater Storage (ea): Input (ea):	1 120 USG 750,000 Btu/hr	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	1,176 USGPH @ 75 °F Rise 1,260 USGPH 1,204 USGPH 6 min
1	New External Tanks: Total Usable Storage:	0 84 USG	% Of Demand:	149% (1-hour peak)
	BTHL-500A Cyclone® LV (Larg	je Volume)		Select
•	# Heaters: Heater Storage (ea): Input (ea):	1 220 USG 499,900 Btu/hr	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	743 USGPH @ 75 °F Rise 897 USGPH 794 USGPH 18 min
	New External Tanks: Total Usable Storage:	0 154 USG	% Of Demand:	106% (1-hour peak)
0	BTH-250 Mxi Cyclone® Mxi Mod	ulating		Select
•	# Heaters: Heater Storage (ea): Input (ea):	2 100 USG 250,000 Btu/hr	Heater Recovery: 1st Hour Delivery: 3 Hour Average: Est. Storage Recovery:	776 USGPH @ 75 °F Rise 916 USGPH 823 USGPH 15 min
- C	New External Tanks: Total Usable Storage:	0 140 USG	% Of Demand:	108% (1-hour peak)

MFG Tool 1

Input

		- 0	€)			
	SY	STEM S	SETTINGS			
	To override a default p	parameter	r, select from t	he drop down list		
Installation	п Туре		Temperatu	re Units		
Indoor		~	Fahrenhe	eit (*F)	~	
Fuel Type			Incoming V	Water Temperature (*F) 🚺		
Natural	Gas	~	65			
ASME Reg	uland.					
No	bired	~		nperature (*F) 🛕		
			140			
	Thermostat Required		Altitude (ft	0		
No		~	0	0		
Low NOx I	nstallation 🥹					
No		~				
A	/ARNING - Water temperature over 125'F (5210 can	cause severe bu	ins instantly or death from sca	Hs.	
Z	neere maar temperature orer res ry		COUSE SETERE DO			
	APPLICAT	ION DA				
	APPLICAT Enter the requ	ION DA				
Units with 1 Bath	APPLICAT Enter the requ Shower Heads	ION DA	below	suite Clothes Washer		
62	APPLICAT Enter the requi Shower Heads 2.5 GPM	ION DA	below	suite Clothes Washer		
62 Units with 1½ Bat	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads	rion da irrements b	w/ In-s	suite Clothes Washer suite Clothes Washer		
62 Units with 1½ Bat	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM	ION DA	w/ In-s			
62 Units with 1½ Bat O Units with 2 Bath	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads	rion DA	w/ In-s			
62 Units with 1½ Bat 0 Units with 2 Bath 0	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM	rion da irrements b	w/ In-s	suite Clothes Washer		
62 Units with 1½ Bat 0 Units with 2 Bath 0 Units with 2½ Bat	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM h Shower Heads	TION DA	w/ In-s	suite Clothes Washer		
62 Units with 1½ Bat 0 Units with 2 Bath 0 Units with 2½ Bat 0	APPLICAT Enter the required Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM h Shower Heads 2.5 GPM	rion DA	w/ In-s	suite Clothes Washer suite Clothes Washer		
62 Units with 11/2 Bat 0 Units with 2 Bath 0 Units with 2/2 Bat 0 Units with 3 Bath	APPLICAT Enter the required Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM h Shower Heads 2.5 GPM shower Heads Shower Heads	rion DA	w/ In-3 w/ In-3 w/ In-3 w/ In-3	suite Clothes Washer suite Clothes Washer		
62 Units with 11/2 Bat 0 Units with 2 Bath 0 Units with 21/8 Bat 0 Units with 3 Bath 0	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM	TION DA	w/ In-3 w/ In-3 w/ In-3 w/ In-3	suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 1½ Bat 0 Units with 2 Bath 0 Units with 2½ Bat 0 Units with 3 Bath 0 Units with 3½ Bat	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM	rion DA irrements b	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 11/2 Bat 0 Units with 2 Bath 0 Units with 21/8 Bat 0 Units with 3 Bath 0	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM	rion DA	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 1½ Bat 0 Units with 2 Bath 0 Units with 2½ Bat 0 Units with 3 Bath 0 Units with 3½ Bat	APPLICAT Enter the required Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM	rion DA irrements b	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 1½ Bat 0 Units with 2 Bath 0 Units with 2½ Bat 0 Units with 3 Bath 0 Units with 3½ Bat 0	APPLICAT Enter the required Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM	rion DA irrements b	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 11/2 Bat 0 Units with 2 Bath 0 Units with 21/2 Bat 0 Units with 3 Bath 0 Units with 31/2 Bat 0 Shower Minutes P	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM w H Shower Heads 2.5 GPM Shower Heads 2.5 GPM w H Shower Heads 2.5 GPM	rion DA irrements b	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 11/2 Bat 0 Units with 2 Bath 0 Units with 21/2 Bat 0 Units with 31 Bath 0 Units with 31/2 Bat 0 Shower Minutes P 7	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM w H Shower Heads 2.5 GPM Shower Heads 2.5 GPM w H Shower Heads 2.5 GPM	rion DA irrements b	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 1½ Bat 0 Units with 2 Bath 0 Units with 2½ Bat 0 Units with 3½ Bath 0 Units with 3½ Bath 0 Shower Minutes P 7 Diversity Factor (%	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM	rion DA irrements b	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer suite Clothes Washer		
62 Units with 1½ Bat 0 Units with 2 Bath 0 Units with 2½ Bat 0 Units with 3½ Bat 0 Units with 3½ Bath 0 Shower Minutes P 7 Diversity Factor (% 30	APPLICAT Enter the requ Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM h Shower Heads 2.5 GPM	rion DA irrements b	below w/ In-s w/ In-s w/ In-s w/ In-s	suite Clothes Washer suite Clothes Washer suite Clothes Washer suite Clothes Washer		

137%

Output

	Mighty Therm®2 Volume Wa	ter Heaters		
	Heaters Required	1	Heater Model No.	MT2V0400
				No Pump 200-400 📑
dik				Pump Mounted 200-400
	Heater Capacity	0 USG	Input per Hour	399,900 BTU/HR
8	Thermal Efficiency	85%	Venting	N/A
	Storage Tanks	1 @ 80 USG	Tank Model	A0073100/A0073101
	Usable Storage	64 USG	Recovery	544 USGPH @ 75 'F Rise
	Approx. 1st Hour Delivery	608 USG	Approx. 3 Hour Avg. Delivery	565 USG
	Approx. Storage Recovery	9 MINUTES	% of Demand Satisfied	107%
	VOLUME WATER H	EATER RECOMMENDATIC		lect
	VOLUME WATER H			lect
	VOLUME WATER H Pennant® Volume Water Hea	#2		lect
		#2		lect PNCV0500
	Pennant® Volume Water Hea	W2	DN .	PNCV0500 No Pump 500-2000
	Pennant® Volume Water Hea Heaters Required	#2 ters 1	PN Heater Model No.	PNCV0500 No Pump 500-2000 Pump Mounted 500-2000
	Pennant® Volume Water Hea Heaters Required Heater Capacity	#2 ters 1 0 USG	Heater Model No.	PNCV0500 No Pump 500-2000 Pump Mounted 500-2000 500.000 BTU/HR
	Pennant® Volume Water Hea Heaters Required Heater Capacity Thermal Efficiency	#2 ters 1	PN Heater Model No.	PNCV0500 No Pump 500-2000 Pump Mounted 500-2000
	Pennant® Volume Water Hea Heaters Required Heater Capacity	#2 ters 1 0 USG	Heater Model No.	PNCV0500 No Pump 500-2000 Pump Mounted 500-2000 500.000 BTU/HR

10 MINUTES % of Demand Satisfied

Approx. Storage Recovery

put							
Unit Type	Water Heate	ər					
Product Line	All						٣
Voltage Input	×110VAC 5	0/60 Hz	× 110VAC 6	60 Hz ×1	20V ×1	20VAC	
	×208VAC 1	-ph ×24	OVAC 1-ph	×277VA	C 1-ph	×480VA	C 1-ph
	×208VAC 3	-ph ×24	40VAC 3-ph	×277VA	C 3-ph	×480VA	C 3-ph
	×No extern	al power	required				
Application Type	Apartment/	Multi-fam	ily				Ŧ
Storage (gl)	N/A						٣
Fuel Type	All						Ŧ
Installation Zip Code		1	Amount	uto 🔻			
Inlet (°F)	65	Ou	tlet (°F)	140	E	Elev. (ft)	0
Load (auto 🗌)	Peak	* Pe	eak (hr)	i i	R	ec. (hr)	1
ASME		Lo	W NOx		Ultra-Lo	w NOx	
Fixtures							-
Click Here To Ac	d Fixture *	Qty	Flow (GPH)	Flow (GPM)	Time (min)	Temj (°F)	P Edit
Singl	le Bath Units	62		2.5	12	105	
1 1/	2 Bath Units			3	12	105	
	2 Bath Units	0		5	12	105	
Automatic Washin	ng Machines	10	15			140	 Image: A start of the start of
Public	lavatory sink		5			105	

	Model	GHE100SU-400 (★)	Quantity	2
- 0 5	Input	399000 BTU	Delivery	1365 US Gallons
**	Size	100 US Gallons	Recovery	613 US GPH at 75 °F rise
1	Fuel Type	Gas (High Eff)	Storage Tank	N/A
-	Efficiency	95%		
ect Anoth	erv Match			
	Model	GHE100SU-400 LP	Quantity	2
- 5	Input	399000 BTU	Delivery	1365 US Gallons
	Size	100 US Gallons	Recovery	613 US GPH at 75 °F rise
	Fuel Type	Gas (High Eff)	Storage Tank	N/A
27	. act type		•	
07.4	Efficiency	95%		
			Quantity	2
	Efficiency	95%		2 1419 US Gallons
	Efficiency Model	95% GX90-500N	Quantity	
	Efficiency Model Input	95% GX90-500N 500000 BTU	Quantity Delivery	1419 US Gallons
	Efficiency Model Input Size	95% GX90-500N 500000 BTU 90 US Gallons	Quantity Delivery Recovery	1419 US Gallons 646 US GPH at 75 °F rise
	Efficiency Model Input Size Fuel Type	95% GX90-500N 500000 BTU 90 US Gallons Gas	Quantity Delivery Recovery	1419 US Gallons 646 US GPH at 75 °F rise
	Efficiency Model Input Size Fuel Type Efficiency	95% GX90-500N 500000 BTU 90 US Gallons Gas 80%	Quantity Delivery Recovery Storage Tank	1419 US Gallons 646 US GPH at 75 °F rise N/A

EHPWH Tool

Input

				0	California Specification Mode
TOTAL PEOPLE &	APARTMENTS	APARTMENT SIZE & OCCUPANCY RATES	0		
	Number of Apartments	Occupancy Rate ③ California - RASS Data	Peak Gallons per Day per Person ③ ASHRAE Medium	~	 California by Bedroom
Studio	62	1.37	1	49 49	
1 Bedroom	0	1.74	1	49	
2 Bedroom	0	2.57	1	49 () 49	
3 Bedroom	0	3.11	1	49 4 9	
4 Bedroom	0	4.23	1	49 4 9	
5 Bedroom	0	3.77	1	49 0 49	

Water Temperature


Design Cold	Supply	Hot Storage		
65 °F	140 °F	140 °F	Aquastat Fraction	Drawdown
			40 %	85 %

Results

The graph below represents the trade off between storage volume and heating capacity. The Ecosizi id result is the green curve in the graph. The system sized from user inputs is the blue diamond. Users should pick any point above the green curve to determine their system sizing.

Use the slider bar below the plot to select a different size system.

Primary Sizing Curve



RECOMMENDATIONS

The recommended minimum heating capacity shown below is the **minimum** needed average output capacity of the selected equipment at the design cold air temperature in your climate zone. Note that you must also account for manufacturer specific defrost penalty.

Tank Volume
1,063.00 Gallons

Swing Tank Volume <a>

80 Gallons

CA Title 24 Swing Tank Volume ③ 80 Gallons Heating Capacity ③ 152.90 kBTU/hr

Swing Resistance Element <a>o 10.8 kW · 37.0 kBTU/hr

THIS SYSTEM WAS SIZED FOR

Building Load 84.9 People

Apartments 62 Units

Daily Hot Water Usage 49 Gallons per Day per Person

Total Hot Water 4,162.06 Gallons per Day

Recirculation Loop Heat Loss 100 Watts per Apartment



Site 5

put	
System Settings	
Equipment:	Water Heaters Only (no external storage)
	O Water Heaters with external storage if required
	O Commercial Tankless Heaters (no storage)
	O Commercial Tankless Heaters PLUS Storage Tanks
	O Heat Pump Heaters
	O Boilers with external storage tank
Fuel Type:	Natural Gas 🗸
Equipment Location:	Indoor 🗸
Other Requirements:	Low NOx - Requirements of < 40 ng/J or 55 PPM
	Ultra Low NOx - Requirements of < 14 ng/J or 20 PPM
	ASME Approved
Display CDN Products:	
# of Heaters:	Not Specified (Auto)
Altitude:	Less than 2000 ft
Application Data	
Temperatures	
Cold Water Temp:	65 °F
Stored Water Temp:	130 °F
Load Profile	
Building Use:	Medium Peak Demand 🗸 More Info
Peak Demand Period:	1 HOURS (Custom? 🔽)
Unit Application Loads	
Shower Head Flowrate:	2.5 USGPM
Units with 1 Bath:	1 Persons per unit: 1.5 W/ Clothes Washer
Units with 1-1/2 Baths:	0 Persons per unit: 2 w/ Clothes Washer
Units with 2 Baths:	48 Persons per unit: 2.5 w/ Clothes Washer
Units with 2-1/2 Baths:	0 Persons per unit: 3 // w/ Clothes Washer
Laundry Room or Coin-Op	Laundry
Include Coin-Operated	
Model 1 - Quantity:	6 Capacity: 15 LB
Model 2 - Quantity:	0 Capacity: 0 LB
Additional Load and Intent	ional Oversize
Additional Load:	0 USGPH (@ stored temp)
Design Oversize	
Seargh Overaize	····

Select

- Select

- Select

Output



BTHS-750A Cyclone® XL			Select
# Heaters:	1	Heater Recovery:	1,357 USGPH @ 65 °F Rise
Heater Storage (ea):	120 USG	1st Hour Delivery:	1,441 USGPH
Input (ea):	750,000 Btu/hr	3 Hour Average: Est. Storage Recovery:	1,385 USGPH 5 min
New External Tanks: Total Usable Storage:	0 84 USG	% Of Demand:	123% (1-hour peak)
fotor obable otorager		lo of Demand.	120 /0 (1 nour peak)



BTH-300 Mxi Cyclone[®] Mxi Modulating

# Heaters:	2	Heater Recovery:	1,074 USGPH @ 65 °F Rise
Heater Storage (ea):	119 USG	1st Hour Delivery:	1,240 USGPH
Input (ea):	300,000 Btu/hr	3 Hour Average:	1,129 USGPH
		Est. Storage Recovery:	13 min
New External Tanks:	0		
Total Usable Storage:	167 USG	% Of Demand:	106% (1-hour peak)
	167 USG	% Of Demand:	106% (1-hour peak)



BTH-400 Mxi Cyclone[®] Mxi Modulating

# Heaters:	2	Heater Recovery:	1,415 USGPH @ 65 °F Rise
Heater Storage (ea):	119 USG	1st Hour Delivery:	1,582 USGPH
Input (ea):	399,900 Btu/hr	3 Hour Average:	1,471 USGPH
		Est. Storage Recovery:	10 min
New External Tanks:	0		
Total Usable Storage:	167 USG	% Of Demand:	135% (1-hour peak)



BTHL-300A Cyclone® LV (Large Volume)

Heaters: 2 Heater Storage (ea): 220 USG Input (ea):

300,000 Btu/hr

New External Tanks: 0 Total Usable Storage: 308 USG % Of Demand:

Heater Recovery:	1,052 USGPH @ 65 °F Rise
1st Hour Delivery:	1,360 USGPH
3 Hour Average:	1,155 USGPH
Est. Storage Recovery:	25 min

60 USGPH 55 USGPH min

116% (1-hour peak)

MFG Tool 1

Input

Installation Trac	To override a default parameter			
Installation Type		Temperature		
Indoor	~	Fahrenheit	(*)	~
Fuel Type		Incoming Wa	ater Temperature (°F) 🚺	
Natural Gas	~	65	O	
ASME Required		Stored Temp	erature (°F) 🛕	
No	~	140	O	
Immersion Thermostat Req	uired	Altitude (ft)		
No	~	0	0	
Low NOx Installation 🥹				
No	~			
Units with 1 Bath	APPLICATIO Enter the requirer Shower Heads	ments below	//In-suite Clothes Washer	
Units with 1 Bath	APPLICATIO Enter the required	ments below	/ In-suite Clothes Washer	
1 Units with 1½ Bath	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads	wents below		
1 Units with 1½ Bath 0	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM	nents below	r/ In-suite Clothes Washer r/ In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	v w		
1 Units with 1½ Bath 0 Units with 2 Bath 48	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM	w w	r/ In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads	• • • • • • • • • • • • • • • • • • •	r/ In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath 0	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM	v w	// In-suite Clothes Washer // In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads		// In-suite Clothes Washer // In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath 0 Units with 3 Bath 0	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM	v v v v v v v v v v v v v v v v v v v	/ In-suite Clothes Washer / In-suite Clothes Washer / In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath 0 Units with 3 Bath	APPLICATIO Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads		/ In-suite Clothes Washer / In-suite Clothes Washer / In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3½ Bath	APPLICATION Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM		// In-suite Clothes Washer // In-suite Clothes Washer // In-suite Clothes Washer // In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3 Bath 0 Units with 3½ Bath	APPLICATION Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM		// In-suite Clothes Washer // In-suite Clothes Washer // In-suite Clothes Washer // In-suite Clothes Washer	
1 Units with 1½ Bath 0 Units with 2 Bath 48 Units with 2½ Bath 0 Units with 3 Bath 0 Units with 3 Bath 0 Units with 3½ Bath 0 Shower Minutes Per Hour	APPLICATION Enter the required Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM Shower Heads 2.5 GPM		// In-suite Clothes Washer // In-suite Clothes Washer // In-suite Clothes Washer // In-suite Clothes Washer	

		#1		
	Mighty Therm®2 Volume Wat	ter Heaters		
	Heaters Required	1	Heater Model No.	MT2V0400 No Pump 200-400 Pump Mounted 200-400
1111	Heater Capacity	0 USG	Input per Hour	399,900 BTU/HR
6	Thermal Efficiency	85%	Venting	N/A
	Storage Tanks	1 @ 80 USG	Tank Model	A0073100/A0073101
	Usable Storage	64 USG	Recovery	544 USGPH @ 75 °F Rise
	Approx. 1st Hour Delivery	608 USG	Approx. 3 Hour Avg. Delivery	565 USG
	Approx. Storage Recovery	9 MINUTES	% of Demand Satisfied	103%
			Se	lect

VOLUME WATER HEATER RECOMMENDATION #2

Pennant® Volume Water Heaters

1

Heaters Required	1	Heater Model No.	PNCV0500
			No Pump 500-2000 📗
			Pump Mounted 500-2000
Heater Capacity	0 USG	Input per Hour	500,000 BTU/HR
Thermal Efficiency	85%	Venting	N/A
Storage Tanks	1 @ 119 USG	Tank Model	A0078800/A0070101
Usable Storage	95 USG	Recovery	680 USGPH @ 75 °F Rise
Approx. 1st Hour Delivery	775 USG	Approx. 3 Hour Avg. Delivery	712 USG
Approx. Storage Recovery	10 MINUTES	% of Demand Satisfied	131%


MFG Tool 3

Inp	out							
	Unit Type	Water Heate	er					¥
	Fuel Type	All						Ŧ
	Product Line	All						*
	Voltage Input	×110VAC 5	0/60 Hz	×110VAC 6	0 Hz X120V	/ ×120VA	C) × 208	SVAC 1-ph
		-			×480VAC 1-		/AC 3-ph	
			· · ·		×480VAC 3-	ph		
		×No extern	al powe	r required				
	Application Type	Apartment/	Multi-fa	mily				Ŧ
	Storage (gl)	N/A						Ŧ
	Installation Zip Code			Amount	Auto *)		
	Inlet (°F)	65]	Outlet (°F)	130	Ele	ıv. (ft)	0
	Load (auto 🗌)	Peak	*	Peak (hr)	1	Red	c. (hr)	1
	ASME			Low NOx		Ultra-Low	NOx	
	Fixtures							_
	Click Here To Ad	d Fixture 👻	Qty	Flow (GPH)	Flow (GPM)	Time (min)	Temp (°F)	Edit
	Single	Bath Units	1		2.5	12	105	
	1 1/2	8 Bath Units			3	12	105	
	2	8 Bath Units	48		5	12	105	
	Automatic Washin	g Machines	6	15			130	\checkmark
	Public la	avatory sink		5			105	
	s	ervice Sinks		10			120	

-	Model	GX90-715 NG (★)	Quantity	2
	Input	715000 BTU	Delivery	2259 US Gallons
	Size	90 US Gallons	Recovery	1067 US GPH at 65 °F rise
	Fuel Type	Gas	Storage Tank	N/A
	Efficiency	80%		
t Delivery Mat	del xh *			

EHPWH Tool

Input



Market rate multifamily building load shape based on Ecotope research. Total hot water usage is based on the number of people and gallons used per person per day from inputs below.


TOTAL PEOPLE	& APARTMENTS	APARTMENT SIZE & OCCUPANCY RATI	rs 🤊	
	Number of Apartments	Occupancy Rate (2) California - RASS Data	Peak Gallons per Day per Person ③ ASHRAE Medium	California by Bedroon
Studio	1	1.37	1	49 (49)
Bedroom	0	1.74	1	49 (@49
Bedroom	36	2.57	1	49 • 49
Bedroom	12	3.11	1	49 • 49
Bedroom	0	4.23	1	49 () 49
Bedroom	0	3.77	1	49

Results

The graph below represents the trade off between storage volume and heating capacity. The method result is the green curve in the graph. The system sized from user inputs is the blue diamond. Users should pick any point above the green curve to determine their system sizing.

Use the slider bar below the plot to select a different size system.

Primary Sizing Curve



THIS SYSTEM WAS SIZED FOR

Building Load 131.2 People

Apartments 49 Units

Daily Hot Water Usage 49 Gallons per Day per Person

Total Hot Water 6,429.29 Gallons per Day

Recirculation Loop

Heat Loss 100 Watts per Apartment

SAVE RESULTS TO PDF

SEND US YOUR FEEDBACK

RECOMMENDATIONS

The recommended minimum heating capacity shown below is the **minimum** needed average output capacity of the selected equipment at the design cold air temperature in your climate zone. Note that you must also account for manufacturer specific defrost penalty.

Tank Volume 🤊

1,696.00 Gallons

Swing Tank Volume ③ 50 Gallons

CA Title 24 Swing Tank Volume ③ 80 Gallons



Heating Capacity ③ 207.90 kBTU/hr

Swing Resistance Element ③ 8.6 kW · 29.3 kBTU/hr

Site 6

Μ	FG	Tool	2
	· · ·		_

Input	
Fuel Type:	Natural Gas 🗸
Equipment Location:	Indoor 🗸
Other Requirements:	Low NOx - Requirements of < 40 ng/J or 55 PPM
	Ultra Low NOx - Requirements of < 14 ng/J or 20 PPM
	ASME Approved
Display CDN Products:	
# of Heaters:	Not Specified (Auto)
Altitude:	Less than 2000 ft 🔹 🗸
Application Data	
Temperatures	
Cold Water Temp:	66 °F
Stored Water Temp:	130 °F
Load Profile	
Building Use:	Medium Peak Demand 🗸 More Info
Peak Demand Period:	1 HOURS (Custom? 🗹)
Unit Application Loads	
Shower Head Flowrate:	2.5 USGPM
Units with 1 Bath:	101 Persons per unit: 1.5 🗌 w/ Clothes Washer
Units with 1-1/2 Baths:	0 Persons per unit: 2 W/ Clothes Washer
Units with 2 Baths:	Persons per unit: 2.5 Uw/ Clothes Washer
Units with 2-1/2 Baths:	0 Persons per unit: 3 W/ Clothes Washer
Laundry Room or Coin-Op La	aundry
✓ Include Coin-Operated La	undry
Model 1 - Quantity:	8 Capacity: 15 LB
Model 2 - Quantity:	0 Capacity: 0 LB
Additional Load and Intentio	onal Oversize
Additional Load:	0 USGPH (@ stored temp)
Design Oversize	

Select

1,378 USGPH @ 64 °F Rise

1,462 USGPH

1,406 USGPH

126% (1-hour peak)

Output

Peak Demand:

1,163 USGPH

Temperature Rise:

64 °F

Recommended Products



BTHS-750A Cyclone® XL # Heaters: 1 Heater Recovery: Heater Storage (ea): 120 USG 1st Hour Delivery: 750,000 Btu/hr 3 Hour Average: Input (ea): Est. Storage Recovery: 5 min New External Tanks: 0 Total Usable Storage: 84 USG % Of Demand:





New External Tanks: 0 Total Usable Storage: 167 USG



- Select

% Of Demand:

138% (1-hour peak)



BTHL-300A Cyclone® LV (Large Volume)

Heaters: 2 Heater Storage (ea): 220 USG

Input (ea):

New External Tanks: 0 Total Usable Storage: 308 USG

Heater Recovery: 1,069 USGPH @ 64 °F Rise 1st Hour Delivery: 1,377 USGPH 300,000 Btu/hr 3 Hour Average: 1,171 USGPH Est. Storage Recovery: 25 min

> % Of Demand: 118% (1-hour peak)



MFG Tool 1

	SYSTEM	SETTINGS
To override a	default paramete	er, select from the drop down list
Installation Type		Temperature Units
Indoor	~	Fahrenheit (°F)
Fuel Type		Incoming Water Temperature (*F)
Natural Gas	~	66 O
ASME Required		Stored Temperature (°F)
No	~	140
Immersion Thermostat Required		Altitude (ft)
No	~	• 0
Low NOx Installation 🥝		
No	~	
WARNING - Water temperature ov	er 125°F (52°C) can	n cause severe burns instantly or death from scalds.
OPTIONAL SETTINGS		Number of New Stores Tasks
Number of Water Heaters		Number of New Storage Tanks
Number of Water Heaters Not Specified	~	Not Specified
Number of Water Heaters Not Specified Intentional Oversize Percent		Not Specified 🗸
Number of Water Heaters Not Specified	~	Not Specified
Number of Water Heaters Not Specified Intentional Oversize Percent		Not Specified 🗸

	APPLICATION	I DATA
	Enter the requireme	ents below
Units with 1 Bath	Shower Heads	
101	2.5 GPM	w/ In-suite Clothes Washer
Units with 11/2 Bath	Shower Heads	
0	2.5 GPM	✓ w/ In-suite Clothes Washer
Units with 2 Bath	Shower Heads	
0	2.5 GPM	w/ In-suite Clothes Washer
Units with 21/2 Bath	Shower Heads	
0	2.5 GPM	✓ w/ In-suite Clothes Washer
Units with 3 Bath	Shower Heads	
0	2.5 GPM	✓ w/ In-suite Clothes Washer
Units with 3½ Bath	Shower Heads	
0	2.5 GPM	v / In-suite Clothes Washer
Shower Minutes Per Hour 🥝		
7 —O—		
Diversity Factor (%)		
30 ~ —O—		
Other GPH (at Stored Temp)		
0		

NeoTherm® XTR	

Heaters Required	1	Heater Model No.	NT2V399
Heater Capacity	0 USG	Input per Hour	399,000 BTU/HR
Thermal Efficiency	96.7%	Venting	N/A
Storage Tanks	1 @ 80 USG	Tank Model	A0073100/A0073101
Usable Storage	64 USG	Recovery	626 USGPH @ 74 °F Rise
Approx. 1st Hour Delivery	690 USG	Approx. 3 Hour Avg. Delivery	647 USG
Approx. Storage Recovery	8 MINUTES	% of Demand Satisfied	103%

Input										
Unit Type	Water Heater								*	
Product Line	All								*	
Voltage Input	×110VAC 50/60 Hz ×110VAC 60 Hz ×120V ×120VAC									
						C 1-ph ×480				
	×208VAC 3-ph ×240VAC 3-ph ×277VAC 3-ph ×480VAC 3-ph ×No external power required									
	×No externa	power	required	£)						
Application Type	Apartment/M	ulti-fam	ily						٣	
Storage (gl)	N/A *									
Fuel Type	All									
istallation Zip Code			Amount	Au	to *					
Inlet (°F)	66	Outlet (°F) Peak (hr) Low NOx		13	130		Elev. (ft) 0			
Load (auto 🗌)	Peak			1		F	Rec. (hr) 1			
ASME					Ultra-L		.ow NOx			
Fixtures									_	
Click Here To Ac	d Fixture 👻	Qty	Flow (GPH		Flow (GPM)	Time (min)	Tem (°F)	p I	Edit	
Single Bath Units 1 1/2 Bath Units		101		2.5	12	105				
					3	12	105			
	2 Bath Units	0			5	12	105			
Automatic Washi	ng Machines	8	15				130		~	
					1	1	E.	-	_	

MFG Tool 3

	Model	GX90-715 NG (🖈)	Quantity	2	
i 🖻 👕	Input	715000 BTU	Delivery	2293 US Gallons	
	Size	90 US Gallons	Recovery	1083 US GPH at 64 °F rise	
Fuel Ty	Fuel Type	Gas	Storage Tank	N/A	
	Efficiency	80%			


Input Number of Apartments Occupancy Rate ⁽¹⁾ Peak Gallons per Day per Person ⁽²⁾ California by Bedroom California - RASS Data 🛛 🛩 ASHRAE Medium ~ 49 0 1.37 **0**49 Studio 49 100 1.74 049 1 Bedroom 49 2 Bedroom 1 2.57 **0**49 49 3 Bedroom 0 3.11 049 49 0 049 4 Bedroom 4.23 49 5 Bedroom 0 3.77 049

EHPWH Tool

Water Temperature

Design Cold	Su	ylqqu		Hot Storage				ADVANO	ED OPTIONS
66 °	F	130	°F	130	°F	Aquastat Fraction Drawdown			
						40	%	85	%

se the shoet set seton the plot to setect a unit of the spotent



Daily Hot Water Usage 49 Gallons per Day per Person

Total Hot Water 8,651.93 Gallons per Day

Recirculation Loop Heat Loss 100 Watts per Apartment

SAVE RESULTS TO PDF

SEND US YOUR FEEDBACK

RECOMMENDATIONS

The recommended minimum heating capacity shown below is the **minimum** needed average output capacity of the selected equipment at the design cold air temperature in your climate zone. Note that you must also account for manufacturer specific defrost penalty.

Tank Volume 💿

2,231.00 Gallons

Swing Tank Volume ③ 120 Gallons

CA Title 24 Swing Tank Volume <a>

 168 Gallons

HOT WATER SIMULATION

Heating Capacity <a>? 271.20 kBTU/hr

Swing Resistance Element ⁽²⁾ 17.7 kW · 60.3 kBTU/hr